

City of Los Angeles Integrated Resources Plan

Summary Report

December 2006

Prepared for

City of Los Angeles
Department of Public Works
Bureau of Sanitation
and
Department of Water and Power

Prepared By:

CH:CDM, A Joint Venture

Final Report

Acknowledgements

Project Director

Adel Hagekhalil, Bureau of Sanitation
Tom Erb, Department of Water and Power (DWP)
Kellene Burn-Roy, CDM

Project Managers

Debbie Pham, Bureau of Sanitation
William Van Wagoner, DWP
Heather Boyle VanMeter, CDM
Kathleen Bullard, CH2M Hill

Facilities Plan Task Managers

Reina Pereira, Bureau of Sanitation
Judi Miller, CH2M Hill

Financial Plan Task Managers

Lisa Mowery, Bureau of Sanitation
Dan Rodrigo, CDM
Mike Matichich, CH2M Hill

Public Outreach Task Managers

Hyginus Mmeje, Bureau of Sanitation
Chris Harris, Harris & Company

Environmental Task Managers

Ara Kasparian, Bureau of Engineering
Jawahar Shah, Bureau of Sanitation
Louis Utsumi, Envicraft, LLC
Christine Roberts, CH2M Hill

Stakeholder Facilitator

Paul Brown, CDM

Management Advisory Committee and Technical Advisory Committee

Varouj Abkian/BOE	Yolanda Fuentes/Board of Public Works	Mike Mullin/BOS
Sam Alavi/BOS	Jose Gardea/CD1	Joe Mundine/BOS
Ralph Avila/Planning	Maria Gomez/BOS	Greg Nelson/DONE
Ron Bagel/LAUSD	Dan Griset/SCAG	Hiddo Netto/BOS
Vik Bapna/LACDPW	Aaron Gross/CD11	Reina Pereira/BOS
Bob Birk/BOS	Gerald Gubatan/CD1	Mark Pestrella/LACDPW
Melinda Bartlett/DEA	Keith Hanks/BOE	Susan Pfann/CAO
Allison Becker/CD13	Daniel Hackney/BOS	Debbie Pham/BOS
Angelo Bellomo/LAUSD	Adel Hagekhalil/BOS	Randy Price/BOS
Barry Berggren/BOS	Chris Harris/Harris & Company	Rafael Prieto/CLA
Dale Burgoyne/BOS	Bill Hartnett/EED	Ken Redd/BOE
Bee Campbell/CAO	Tim Haug/BOE	Phil Richardson/BOE
Jeff Catalano/CD9	Patricia Huber/CAO	Rita Robinson/BOS
Jeanne Chang/CD4	David Jensen/LAUSD	Dan Rosales/CD7
Emeverto Cheng/BOS	Robert Jensen/RAP	Bill Rosendahl/CD11
Donna Chen/BOS	Josh Kamensky/CD13	Cynthia Ruiz/ BPW
Dan Comorre/BOE	Ara Kasparian/BOE	Brian Sasaki/LACDPW
Froy Cornejo/BOS	Shahram Kharaghani/BOS	Shahrouzeh Saneie/BOS
Johne Crosse/CD11	Rod Kubomoto/LACDPW	Jawahar Shah/BOS
Joseph Cruz/BSS	Wayne Lawson/BOE	Susan Shu/BOE
Patricia Cruz/BOS	Julie Lee/CD8	Michael Shull/RAP
Paula Daniels/Board of Public Works	Andy Lipkis/TreePeople	Cathy Shuman/USACE
Steve Davis/RAP	Brent Lorscheider/BOS	Siegmund Shyu/CAO
Gus Dembegiotes/BOS	Carmelo Martinez/BOS	Jill Sourial/CD1
Ed Demesa/USACE	Mark Mackowski/ULARA Watermaster	Mike Spiker/LAG
John De Witt/Rec & Parks	Jim Marchese/BOS	Mark Starr/BOS
Mark Dierkin/CD7	Laura McLennan/CD7	William Steele/US Bureau of Reclamation
John Dierking/Office of Finance	Jon Mukri/RAP	Nancy Sutley/Mayor's Office
Rebecca Drayse/Tree People	Carl Mills/BOE	Raja Takidin/City of Glendale
Jim Doty/BOE	Traci Minamide/BOS	Wing Tam/BOS
Tom Erb/DWP	Hyginus Mmeje/BOS	Robert Tanowitz/BOS
Kurt Erikson/City of Glendale	Omar Moghaddam/BOS	Paul Thakur/Caltrans
Doug Failing/Caltrans	Lisa Mowery/BOS	Chuck Turhollow/BOS
Darryl Ford/RAP		Herman Van Buren/CLA - Planning

Lupe Vela/CD1

Bill Van Wagoner/DWP

Camille Walls/RAP

Doug Walters/BOS

Deborah Weintraub/BOE

Chris Westhoff/CAO

Judy Wilson/JW &
Associates

Robb Whitaker/Water
Replenishment District of
Southern California

Don Wolfe/LACDPW

Robert Wu/Caltrans

Clayton Yoshida/BOS

Steve Zurn/City of
Glendale

Contributing Staff and Consultants

Wastewater Management

Treatment

Chuck Turhollow, Bureau of Sanitation
Tim Haug, Bureau of Engineering
Varouj Abkian, Bureau of Sanitation
Ken Redd, Bureau of Engineering
Steve Fan, Bureau of Sanitation
Bob Birk, Bureau of Sanitation

Curt Roth, CH2M Hill
Hector Ruiz, CH2M Hill
Heather Boyle VanMeter, CDM
Glen Daigger, CH2M Hill
Ilknur Ahmad, CH2M Hill
Gary Guyll, CH2M Hill

Collection System

Farsheed Farhang, Bureau of Sanitation
Betty Dong, Bureau of Sanitation

John Wang, Bureau of Sanitation
Devang Parikh, MapVision
Judi Miller, CH2M Hill

Biosolids

Diane Gilbert Jones, Bureau of Sanitation
Omar Mogahaddam, Bureau of Sanitation

Ruth Roxburgh, CH2M Hill
Sava Nedic, CDM
Fred Soroushian, CH2M Hill

Water Management

William Van Wagoner, DWP
Tom Gackstetter, DWP
Alvin Bautista, DWP
Victoria Cross, DWP
Jennifer Barrack, DWP
Mike Mullin, Bureau of Sanitation

Dan Rodrigo, CDM
Scott Lynch, CH2M Hill
Megan Laetsch, CH2M Hill
Bob Kemmerle, E2
Kathleen Higgins, CH2M Hill
Mike Savage, CDM

Runoff Management

Shahram Kharaghani, Bureau of Sanitation
Morad Sedrak, Bureau of Sanitation
Robert Vega, Bureau of Sanitation
Mike Mullin, Bureau of Sanitation
Wing Tam, Bureau of Sanitation
Hampik Dekermenjian, CDM

Jennifer Gronberg, CDM
Don Schroeder, CDM
Judi Miller, CH2M Hill
Curt Roth, CH2M Hill
Andy Lipkis, TreePeople
Bob Kemmerle, E2

Decision Science

Dan Rodrigo, CDM
Enrique Lopez-Calva, CDM

Regulatory Forecast

Traci Minamide, Bureau of Sanitation
Shahram Kharaghani, Bureau of Sanitation
Adel Hagekhalil, Bureau of Sanitation
Donna Toy Chen, Bureau of Sanitation
Diane Gilbert Jones, Bureau of Sanitation
Lisa Mowery, Bureau of Sanitation
Reina Pereira, Bureau of Sanitation

William Van Wagoner, DWP
Carrie Takayama, DWP
Chris Westhoff, City Attorney's
Office
Judy Wilson, JW & Associates
Ruth Roxburgh, CH2M Hill
Heather Boyle VanMeter, CDM

Contents

Section 1	Introduction	1-1
1.1	Background	1-1
1.2	Stakeholder Driven Facilities Planning Process	1-3
1.3	Overview of Document	1-3
Section 2	Wastewater Management	2-1
2.1	Introduction.....	2-1
2.2	Planning Parameters	2-1
2.2.1	Wastewater Service Area.....	2-2
2.2.2	Population and Employment Projections	2-2
2.2.3	Regulatory Requirements.....	2-5
2.3	Guiding Principles Affecting Wastewater Management	2-7
2.4	Wastewater Flow Projections.....	2-8
2.5	Existing Collection System	2-9
2.6	Collection System Options	2-10
2.7	Existing Treatment Facilities.....	2-14
2.7.1	Hyperion Treatment Plant	2-15
2.7.2	Donald C. Tillman Water Reclamation Plant (TWRP).....	2-17
2.7.3	Los Angeles-Glendale Water Reclamation Plant	2-19
2.7.4	Terminal Island Treatment Plant	2-21
2.8	Treatment Options.....	2-23
2.8.1	HTP Treatment Option.....	2-24
2.8.2	WRP Treatment Options	2-25
2.8.3	LAG Treatment Options.....	2-27
2.8.4	TITP Options	2-29
2.8.5	New Water Reclamation Plant Options	2-29
2.9	Biosolids Management.....	2-32
2.10	Alternatives Analysis	2-37
Section 3	Water Management.....	3-1
3.1	Introduction.....	3-1
3.2	Planning Parameters	3-2
3.3	Potable Water	3-2
3.3.1	Demands.....	3-2
3.3.2	Supply	3-4
3.4	Water Conservation.....	3-5
3.4.1	Existing and Planned Conservation Measures.....	3-6
3.4.2	Potential Additional Conservation Measures	3-7
3.5	Recycled System	3-8
3.5.1	Existing Recycled Water System and Demands	3-8

3.5.2	Potential Demands for Recycled Water	3-10
3.5.2.1	Identifying DWP Top Water Customers.....	3-10
3.5.2.2	Mapping Potential Recycled Water Customers	3-12
3.6	Summary.....	3-14
Section 4	Runoff Management	4-1
4.1	Introduction.....	4-1
4.1.1	Runoff Service Area	4-1
4.2	Planning Parameters	4-3
4.2.1	IRP Guiding Principles	4-3
4.2.2	Regulatory Drivers.....	4-4
4.2.3	Runoff Planning Sheds	4-5
4.3	Approach	4-5
4.4	Dry Weather Runoff	4-8
4.4.1	Dry Weather Runoff Volume.....	4-8
4.4.2	Dry Weather Runoff Quality	4-10
4.4.3	Local/Neighborhood Solutions	4-11
4.4.4	Regional Solutions.....	4-12
4.4.4.1	Diversion to Wastewater system.....	4-12
4.4.4.2	Diversion to Urban Runoff Plants, Including Reuse	4-13
4.4.4.3	Diversion to Wetlands	4-16
4.5	Wet Weather Runoff.....	4-16
4.5.1	Wet Weather Runoff Volume	4-16
4.5.2	Wet Weather Runoff Quality	4-18
4.5.3	Local/Neighborhood Solutions	4-20
4.5.3.1	New/Redevelopment Areas – Onsite treatment/ discharge.....	4-20
4.5.3.2	New/Redevelopment Areas – On site percolation	4-20
4.5.3.3	Retrofit Area – Cisterns	4-21
4.5.3.4	Retrofit Areas – Onsite Percolation.....	4-22
4.5.3.5	Neighborhood Recharge	4-22
4.5.4	Regional Solutions.....	4-22
4.5.4.1	Non-Urban Regional Recharge.....	4-22
4.5.4.2	Treatment and Discharge or Beneficial Use	4-23
4.5.4.2.1	Treatment and Discharge	4-23
4.5.4.2.2	Treatment and Beneficial Use	4-24
4.6	Summary.....	4-26

Section 5	Alternatives Development and Analysis	5-1
5.1	Approach for Developing and Evaluating Alternatives	5-1
5.2	IRP Objectives, Sub-Objectives and Performance Measures	5-1
5.3	Preliminary Alternatives	5-2
5.3.1	Evaluation of Preliminary Alternatives	5-4
5.4	Hybrid Alternatives	5-4
5.4.1	Evaluation of Hybrid Alternatives.....	5-8
5.5	Recommended Draft Alternatives for Environmental Analysis.....	5-8
5.6	Recommend Alternative	5-10
Section 6	Adaptive Capital Improvement Plan (CIP).....	6-1
6.1	Introduction.....	6-1
6.2	Implementation Strategy	6-1
6.3	Capital Cost Data Assumptions	6-2
6.3.1	Cost Factors	6-2
6.3.2	Construction Cost Index Updates	6-3
6.4	Wastewater Projects	6-3
6.4.1	Wastewater Go-Projects	6-4
6.4.2	Wastewater Go If Triggered Projects.....	6-6
6.4.3	Wastewater Leadership Projects	6-8
6.4.4	Baseline Project Timing	6-8
6.5	Runoff Management Projects.....	6-8
6.5.1	Runoff Management Programmatic Projects	6-9
6.5.2	Proposition O Conceptual Projects	6-9
6.6	Recycled Water	6-10
6.6.1	Potential Recycled Water Projects.....	6-11
6.6.2	Parallel Projects Underway and Conceptual Projects	6-12
6.7	Water Conservation Projects.....	6-12
6.8	Implementation Tracking	6-13
6.8.1	Trigger Tracking Tools	6-13
6.8.2	IRP Progress Reporting	6-15
Section 7	Public Participation	7-1
7.1	Introduction.....	7-1
7.2	Roles of Stakeholders in the IRP Project.....	7-1
7.3	Steering, Advisory, and Information Groups.....	7-2
7.4	Stakeholders and Focused Outreach Related to the Environmental Impact Report.....	7-2
7.5	Public Hearings to Certify the Final EIR	7-3

Section 8	Environmental Impact Report	8-1
8.1	Introduction.....	8-1
8.2	Draft EIR	8-1
8.3	Final EIR.....	8-3
8.4	Recommended Alternative	8-3
8.4.1	Final Selected Alternative	8-5

Acknowledgements

List of Figures

Figure 1-1	Overall Approach.....	1-2
Figure 1-2	Final IRP Documentation	1-3
Figure 2-1	Wastewater Service Area.....	2-2
Figure 2-2	Los Angeles Service Area and Contract Agencies.....	2-4
Figure 2-3	IRP Objectives	2-7
Figure 2-4	Interceptor Sewers in City of Los Angeles.....	2-11
Figure 2-5	Wastewater System Flows and Capacity Gaps in Year 2020	2-12
Figure 2-6	Hyperion Treatment Plant	2-16
Figure 2-7	Tillman Water Reclamation Plant Site Plan.....	2-18
Figure 2-8	Los Angeles-Glendale Water Reclamation Plant Site Plan.....	2-20
Figure 2-9	Terminal Island Treatment Plant Existing Site Plan.....	2-22
Figure 2-10	Interrelationship of Upstream Plants with Hyperion Treatment Plant.....	2-25
Figure 2-11	Initial General Areas for a New Water Reclamation Plant.....	2-31
Figure 2-12	Biosolids Management Task Approach	2-33
Figure 3-1	DWP Historical and Projected Water Demand and Population.....	3-3
Figure 3-2	Principal Water Supply Sources	3-4
Figure 3-3	Summary of Water Supply for the Average of 10 Years.....	3-4
Figure 3-4	City Wastewater Plants and Sewersheds.....	3-8
Figure 3-5	Potential Recycled Water Demand	3-11
Figure 3-6	Potential Recycled Water Customers	3-13
Figure 4-1	Citywide Land Use.....	4-1
Figure 4-2	Runoff Watersheds for Los Angeles	4-2
Figure 4-3	Runoff Management Options	4-5
Figure 4-4	Runoff Planning Sheds	4-6
Figure 4-5	Non-Potable Demands Near Potential Runoff Treatment Locations.....	4-15
Figure 4-6	Soils Map	4-21
Figure 5-1	IRP Alternatives Analysis Process Chart	5-1
Figure 5-2	IRP Primary Objectives.....	5-2

Figure 5-3	Decision Modeling	5-4
Figure 5-4	Wastewater Components in Hybrid Alternatives	5-7
Figure 5-5	IRP Recommended Draft Alternatives	5-12
Figure 5-6	Hybrid Alternatives Costs and Benefits	5-13
Figure 6-1	Overview of Treatment Plants, Service Area, and Proposed Sewer Lines	6-5
Figure 6-2	Possible Schedules	6-7
Figure 6-3	Permit Flow Chart	6-13
Figure 7-1	Role of Stakeholders in the IRP	7-1
Figure 8-1	Final Selected Alternative: Alternative 4 - Tillman Expansion	8-6

List of Tables

Table 1-1	Summary Report	1-4
Table 2-1	Summary of Agencies and Businesses that Contract with the City of Los Angeles for Wastewater Service	2-3
Table 2-2	Summary of Population Projections and Percent Increase Compared to 2000	2-5
Table 2-3	Summary of Employment Projections and Percent Increase Compared to 2000	2-6
Table 2-4	Summary of Priority Regulations and Key Policy Issues for the Wastewater Program	2-6
Table 2-5	Summary of Average Dry Weather Flow (ADWF) Projections ADWF (mgd).....	2-9
Table 2-6	Tillman WRP Options for the Year 2020	2-27
Table 2-7	Los Angeles-Glendale Water Reclamation Plant Options for the Year 2020.....	2-28
Table 2-8	Criteria for New and Upgraded Facilities	2-29
Table 2-9	New Water Reclamation Plant Options for the Year 2020	2-32
Table 2-10	Summary of Initial Screening of Biosolids Product Technologies.....	2-34
Table 2-11	Summary of Initial Screening of Biosolids Product Technologies.....	2-35
Table 3-1	Projected Water Demands for Each Customer Class in Thousands of Acre-/ft ¹	3-3
Table 3-2	Potable Water Forecasts for the City of Los Angeles	3-5
Table 3-3	Existing Recycled Water Use in City of Los Angeles	3-10
Table 4-1	Summary of Runoff Planning Shed Areas.....	4-7
Table 4-2	Runoff throughout City Based on Estimated Runoff Rates	4-9
Table 4-3	Dry Weather Flows by Runoff Planning Shed	4-9
Table 4-4	Summary of Reported Dry Weather Runoff Water Quality Data	4-10
Table 4-5	Currently Available Treatment Plant Capacity	4-13
Table 4-6	Potential Non-Potable Water Demands Met with Treated Runoff ..	4-14

Table 4-7	Estimated Wet Weather Runoff Volume.....	4-17
Table 4-8	Wet Weather Flows by Runoff Planning Shed.....	4-18
Table 4-9	Water Quality Data in Ballona Creek and the Los Angeles River General Chemicals and Minerals	4-18
Table 4-10	Wet Weather Runoff Managed by On-Site Percolation	4-22
Table 4-11	Proposed Coastal Treatment Plants.....	4-24
Table 4-12	Underground Storage Potential throughout the City	4-25
Table 5-1	Objectives, Sub-objectives and Performance Measures for the IRP.....	5-3
Table 5-2	Integrated Resources Plan (IRP) – Preliminary Alternatives Matrix.....	5-5
Table 5-3	Integrated Resources Plan (IRP) – Hybrid Alternatives Matrix	5-9
Table 6-1	IRP Recommended Alternative Wastewater Estimated Capital Costs – Go-Projects	6-4
Table 6-2	IRP Alternative Four Wastewater Estimated Capital Costs – Go if Triggered Projects.....	6-6
Table 6-3	IRP Alternative Four Runoff Management Estimated Capital Costs	6-10
Table 6-4	IRP Recommended Alternative Recycled Water Estimated Capital Costs	6-11
Table 6-5	Plant Scenario.....	6-14
Table 6-6	IRP Go-Policy Directions.....	6-16

Section 1

Introduction

This Summary Report provides a brief description of the key facilities planning documents for the Integrated Resources Plan (IRP). The summaries provide an overview of each key documentation area, with more detailed information provided in the full volume of each report.

1.1 Background

The City of Los Angeles (City) has developed a wastewater facilities plan that utilized a unique approach of technical integration and community involvement to guide policy decisions and water resources facilities planning. The IRP has integrated a future vision of wastewater, water, and urban runoff management in the City that explicitly recognizes the complex relationships that exist among all of the City's water resources activities and functions. Addressing and integrating the wastewater, water, and runoff needs of the City in the year 2020, the IRP also takes an important step towards comprehensive basin-wide water resources planning in the Los Angeles area. This integrated process is a departure from the City's traditional single-purpose planning efforts for separate agency functions, and it will result in greater efficiency and additional opportunities for citywide benefits, including potential overall cost savings. This integrated process also highlights the benefits of establishing partnerships with other citywide and regional agencies, City departments, and other associations, both public and private.

The IRP sought to accomplish two basic goals as part of developing an implementable facilities plan:

- Integrate water supply, water conservation, water recycling, and runoff management issues with wastewater facilities planning through a regional watershed approach; and
- Enlist the public in the entire planning and design development process at a very early stage beginning with the determination of policy recommendations to guide planning.

The IRP is a multi-phase program:

- Phase I [Integrated Plan for the Wastewater Program (IPWP)] (completed in 2001): Focused on defining the future vision for the City by developing a set of guiding principles to direct future, more-detailed water resources planning.
- Phase II (Integrated Resources Plan): Focuses on the more detailed planning required to develop in a facilities plan, environmental impact report and financial plan.

- Projects (Implementation) (2005 and beyond): Includes future concept reports, studies, and design and construction projects to implement the capital improvement program (CIP) developed as part of Phase II.

The City is facing many challenges, including: the dynamic nature of current and projected regulations affecting the wastewater, recycled water, runoff programs; potential community concerns with siting new wastewater, runoff and recycled water facilities in neighborhoods, potential funding needs for the proposed facilities and programs, and the importance of inter-agency coordination to handle jurisdictional issues. By addressing these challenges now as part of the IRP, the City has improved the tools and organizational and policy structure to better adapt to changing conditions in the future.

The combination of Phases I and II constitute the documentation and overall implementation plan for the IRP, which is intended as an integration of the City's wastewater (collection, treatment and biosolids), water (water reuse/recycling and water conservation), and runoff (dry weather and wet weather) service functions. By using this integrated approach, the City has established a framework for a sustainable future for the Los Angeles basin, one where there are sufficient wastewater services, adequate water supply, and proper and proactive protection and restoration of the environment. Figure 1-1 illustrates the facilities planning approach and its relationship with the financial and environmental planning tasks.




Figure 1-1
Overall Approach

1.2 Stakeholder Driven Facilities Planning Process

One of the most striking characteristics of the IRP is that it was a stakeholder driven process where members of the community, interested stakeholders, and agency representatives comprised various formal groups that provided the City with valuable input throughout the IRP process and participated in the alternatives development and evaluation process. This stakeholder driven process is currently unparalleled in the City's facilities planning history.

1.3 Overview of Document

The IRP documentation includes a series of volumes that comprise of an Executive Summary, Summary Report, Facilities Plan (5 volumes), Final Environmental Impact Report/Environmental Impact Statement (EIR), Financial Plan, and Public Outreach report. Figure 1-2 illustrates the organization of these volumes.

This *Final Summary Report* summarizes each section of the IRP as listed in Figure 1-2.




Figure 1-2
Final IRP Documentation

Table 1-1 provides a description of each of the sections of this Summary Report.

Table 1-1 Summary Report	
Section	Description
1 – Introduction	Study objectives and background.
2 – Wastewater Management	Summarizes the Wastewater service function needs and options for addressing those needs, as described in Volume 1 of the Facilities Plan.
3 – Water Management	Summarizes the Water service function (recycled water) needs, and options for addressing those needs, and discusses the stand-alone <i>Recycled Water Master Plan</i> , as described in Volume 2 of the Facilities Plan.
4 – Runoff Management	Summarizes the Runoff service function needs and options for addressing those needs, as described in Volume 3 of the Facilities Plan.
5 – Alternatives Development and Analysis	Summarizes the process undertaken to integrate the needs of the three service functions into integrated alternatives that address these needs, and that identified the project alternatives evaluated in the Environmental Impact Report, as described in Volume 4 of the Facilities Plan.
6 – Adaptive Capital Improvement Program (CIP)	Summarizes the anticipated costs and implementation timing of the facilities that would be required (based on the approved Project Alternative), as described in Volume 5 of the Facilities Plan.
7 – Public Participation	Summarizes the public outreach activities and focus conducted throughout the IRP process, as described in the Outreach Volume.
8 – Environmental Impact Report	Summarizes the environmental process undertaken for the IRP, the alternatives analyzed in the EIR, and the selection of the Recommended Alternative that was approved for implementation.
References	Summarizes the sources of data, information, and contributions of others.

Section 2

Wastewater Management

2.1 Introduction

The Los Angeles Department of Public Works (LADPW) provides the services for the City's wastewater, stormwater and solid waste program needs. Within the LADPW, the Bureau of Sanitation (Bureau) is responsible for managing and operating the wastewater, stormwater and solid waste programs. The Bureau's mission is:

To protect the public and environment through legal, efficient, and effective collection, treatment, reuse, and disposal of liquid and solid wastes while enhancing relationships with the community, co-workers, elected and appointed officials, and business.

This section summarizes the wastewater management component of the *IRP Facilities Plan - Volume 1: Wastewater Management*, which focuses on the elements below. Refer to Volume 1 for detailed information.

- Projecting wastewater flow quantities and constituent concentrations.
- Identifying current and projecting future regulatory requirements.
- Determining the current capacity of existing collection and treatment facilities.
- Identifying the "gaps" between the projected flows and the current system capacities.
- Developing options to address the identified gaps for each system.
- Combining these options to form wastewater alternatives for collection and treatment.
- Integrating the wastewater alternatives with the recycled water needs/demands and runoff needs/demands.

2.2 Planning Parameters

In planning for the management of future wastewater flows, planning parameters were developed in order to estimate or projected the wastewater flow throughout the service area for the future planning horizon year (2020).

2.2.1 Wastewater Service Area

The City's wastewater service area consists of two distinct drainage basin areas: the Hyperion Service Area (HSA) and the Terminal Island Service Area (TISA). Figure 2-1 shows the overall service areas. The HSA covers approximately 515 square miles and serves the majority of the Los Angeles population. In addition, the service area includes non-City agencies that contract with the City for wastewater service as shown in Figure 2-2 and listed in Table 2-1.

The TISA is approximately 18 square miles and serves the Los Angeles Harbor area. The two service areas are connected geographically by a shoestring strip of land that extends from South Central Los Angeles to the City boundary in the harbor area. The Los Angeles County Sanitation District (LACSD) provides wastewater service to the shoestring portion of the City.




Figure 2-1
Wastewater Service Area

The City owns and operates four major wastewater treatment facilities:

Hyperion Treatment Plant (HTP) in Playa del Rey, the Donald C. Tillman Water Reclamation Plant (TWRP) in the Sepulveda Basin, Los Angeles-Glendale Water Reclamation Plant (LAGWRP) across the freeway from Griffith Park, and the Terminal Island Treatment Plant (TITP) in the vicinity of the Los Angeles Harbor.

Wastewater is conveyed to these treatment facilities through a collection system comprised of a network of underground pipes that extend throughout the City. The wastewater collection system's physical structure includes over 6,500 miles of major interceptors and mainline sewers, 46 pumping plants, and various diversion structures and other support facilities, such as corporation yards.

2.2.2 Population and Employment Projections

Wastewater generation is a function of population and employment within the wastewater service area. Estimating or projecting future population and employment growth was therefore a key consideration in the wastewater facilities planning effort. In developing the population projections for the wastewater service area, the City evaluated the following data sources:

<p>Table 2-1 Summary of Agencies and Businesses that Contract with the City of Los Angeles for Wastewater Service</p>	
<p><u>Per attached map</u></p> <ol style="list-style-type: none"> 1. Aneta Street Sewer Maintenance District 2. City of Beverly Hills 3. City of Burbank 4. County Sanitation District #1 5. County Sanitation District #4 6. County Sanitation District #6 7. County Sanitation District #8 8. County Sanitation District #18 9. County Sanitation District #27 10. Crescenta Valley Water District 11. Culver City 12. City of El Segundo 13. City of Glendale 14. City of Hidden Hills 15. City of Long Beach 16. City of Marina Del Rey 17. City of San Fernando 18. City of Santa Monica 19. Federal Facilities 20. Las Virgenes Municipal Water District – 1, 2, 3, and 4 21. Topanga Sewer Maintenance District 22. Triunfo County Sanitation District 23. Universal City 24. US Naval Base 25. VA Hospital 	<p><u>Others listed in IRP document</u></p> <ol style="list-style-type: none"> 1. County Sanitation District #5 2. County Sanitation District #9 3. County Sanitation District #11 4. County Sanitation District #16 <p><u>Others listed in Air Quality Master Plan</u></p> <ol style="list-style-type: none"> 1. Barrington Post Office 2. California National Guard 3. County Sanitation District #5 4. County Sanitation District #9 5. County Sanitation District #11 6. Federal Office Building 7. Karl Hoton Camp 8. U.S. Army Reserve Center 9. U.S. Army Reserve Training Center 10. Veterans Memorial Park 11. West Los Angeles Community College




Figure 2-2
Los Angeles Service Area and Contract Agencies

- United States Census Bureau
- Southern California Associations of Governments (SCAG)
- City of Los Angeles Department of City Planning
- State of California Department of Finance

Based on the analysis of population projections and uncertainties associated with them, the SCAG 2001 population projection was selected as the best single source of data to use for the IRP. This data source has population projections through year 2020 for the City and its wastewater contract agencies.

Table 2-2 summarizes the population growth projected to occur at key time intervals in the HSA and the TISA, as well as the growth percentage the increases represent.

Table 2-2					
Summary of Population Projections and Percent Increase Compared to 2000					
Tributary Area	Population Projection for IRP¹				
	2000	2005	2010	2015	2020
Hyperion Service Area	4,138,567	4,331,109	4,485,054	4,641,928	4,854,483
Terminal Island Service Area (TISA)	139,589	147,567	154,227	160,144	170,504
Total (HSA + TISA)	4,278,156	4,478,676	4,639,281	4,802,072	5,024,987
Tributary Area	Estimated Percent Increase In Population Compared to Year 2000				
	2000	2005	2010	2015	2020
Hyperion Service Area	--	5%	8%	12%	17%
Terminal Island Service Area	--	6%	10%	15%	22%
Total (HSA + TISA)	--	5%	8%	12%	17%

1. Based upon SCAG-01 projections

To estimate future employment, the City utilized employment data in the SCAG 2001 Regional Transportation Plan. Table 2-3 presents a summary of the wastewater service area employment projections for years 2000, 2005, 2010, 2015, and 2020; and the percent increase of these projections, compared to year 2000.

2.2.3 Regulatory Requirements

In addition to population and employment growth, the City also considered the regulatory framework (existing and future) as a facilities planning parameter. Table 2-4 provides a summary of the resulting priority issues identified for the IRP at the time of alternative development (Spring 2003). The IRP team recognizes that these issues continue to change in status and priority. Also refer to the document titled, "Regulatory Forecast Technical Memorandum" (CH:CDM, May 2003) is included in the *Facilities Plan Volume 1: Wastewater Management*, which provides detailed discussion of these issues.

Table 2-3 Summary of Employment Projections and Percent Increase Compared to 2000					
Tributary Area	Employment Projection for IRP ¹				
	2000	2005	2010	2015	2020
Hyperion Service Area	2,284,126	2,382,000	2,475,451	2,538,351	2,584,503
Terminal Island Service Area	45,383	47,691	49,728	51,092	51,995
Total (HSA + TISA)	2,329,509	2,429,691	2,525,179	2,589,443	2,636,498
Tributary Area	Estimated Percent Increase In Employment Compared to Year 2000				
	2000	2005	2010	2015	2020
Hyperion Service Area	--	4%	8%	11%	13%
Terminal Island Service Area	--	5%	10%	13%	15%
Total (HSA + TISA)	--	4%	8%	11%	13%

¹Based upon SCAG-01 projections

Table 2-4 Summary of Priority Regulations and Key Policy Issues for the Wastewater Program		
Priority Issues ¹	Revised Phase of Program	Timing of Issue
Beneficial use designations for all water bodies and narrative standards in the Basin Plan	Current	As National Pollutant Discharge Elimination System (NPDES) Permits are Renewed
Clean Water Act 303(d) listings for all water bodies (including urban lakes)	Current/ Proposed	Every 4 Years
Total Maximum Daily Load (TMDL) Development - Draft Strategy for Developing TMDLs and Attaining Water Quality Standards in the Los Angeles Region	Current and Proposed	Per Consent Decree – with a proposal to bundle different pollutant TMDLs for the same watershed and as NPDES Permits are Renewed
Clean Water Enforcement and Pollution Prevention Act of 1999, as amended in 2000 by SB2165	Current	Current and ongoing for all effluent limits in NPDES permits unless Time Schedule Order (TSO) in place
California Toxics Rule and the State Implementation Plan for the Inland Surfaces Waters and the Enclosed Bays and Estuaries of California	Emerging	As NPDES Permits are Renewed
Local County Ordinances on land application of Biosolids – Must be Class A/May have even stricter restrictions on quality and application—Exceptional Quality	Current/Emerging	1 to 10 years
Prohibition of bypass of the headworks for sanitary sewage and promulgation of Sanitary Sewer Overflow regulation for management of sanitary collection systems	Current and Proposed	New Regulation ~18 months
Sanitary System Management Plans in NPDES Permits	Emerging	As NPDES Permits are Renewed
Enforcement of Pretreatment requirements and standards on satellite systems	Proposed	As NPDES Permits are Renewed
Groundwater Recharge, notification levels, requirements and public health goals for nitrogen and TOC; new pollutants, endocrine disrupters and pharmaceutically active chemicals	Proposed/ Crystal Ball	With Adoption of SSO Rule early in 2005
VOCs & Ammonia from Biosolids Composting Facilities (Rule 1133) consistent with AB 1450	Current/Emerging	1-5 years
Odor as a result of VOCs & H ₂ S from treatment plants and collection systems General Order # 034 from AQMD and potential for requirements from LARWQCB in NPDES permits	Current/ Crystal Ball	2-20 years

¹See IRP Facilities Plan – Volume 1: Wastewater Management for detailed discussion of these priority issues

Additionally, the potential changes to the discharge permits for Tillman, LAG, and Hyperion, as well as current and future regulations related to the wastewater collection system were considered.

2.3 Guiding Principles Affecting Wastewater Management

In the first phase of the IRP the Steering Group created six primary objectives for the program (Figure 2-3).




Figure 2-3
IRP Objectives

The IRP objectives are the goals that define the essential purposes of the IRP in broad, overarching terms. The objectives can be seen as a set of goals that answer the question: Why do we want to have an IRP?

There are many different means to meet these objectives. The goal of Phase I of the IRP was to develop a set of guiding principles that provide the instructions or guidelines for building alternatives to meet the objectives. These guiding principles were recommended by the Steering Group and staff for consideration by the City Council in planning for the future of the City. On December 14, 2001, the City Council concurred with the Phase I guiding principles.

The guiding principles are essential planning parameters that were utilized in the more detailed facilities planning phase of the IRP. The complete set of guiding principles is included in a separate document titled *Summary of the Steering Group Process and their Steering Group Recommendations for Integrated Resources Planning Policy Development* (Summary Statement).

The wastewater planning effort focused on the several of the guiding principles that are specific to wastewater management, as follows:

- Building new wastewater facilities “upstream” in the system
- Under all conditions, there will be a need to construct and operate new or expanded wastewater facilities. Through the IPWP process, it has been shown that facilities placed upstream in the system offer greater opportunities for system operational flexibility, for beneficial reuse of treated effluent, and for reducing dependency on imported water for such uses as irrigation, industrial use, etc. Because there are adequate solids treatment processes downstream at the HTP and TITP, it was assumed that these new upstream treatment facilities would not include solids treatment processes.
- Producing and using as much recycled water as possible from the existing and planned facilities
- Reducing the amount of rainfall-dependent inflow and infiltration as much as possible
- Beneficially reusing biosolids
- Focusing on lower-cost solutions within the framework of the policy elements noted above

2.4 Wastewater Flow Projections

To plan for future wastewater conveyance and treatment needs, it was necessary to estimate the amount of wastewater that will be generated. In developing wastewater flow estimates, the IRP considered three distinct categories of wastewater flow. Their definitions, and how they are used in the IRP, are as follows:

- Average Dry Weather Flow (ADWF) – ADWF represents the estimated annual average flows for residential and commercial sanitary flows, average groundwater infiltration (GWI), and industrial flows. Historical residential and employment per capita flow rates were used to develop the ADWFs, which were estimated using the City’s Sewer Flow Estimating Model (SFEM). The ADWF were used to evaluate treatment plant process capacities.
- Peak Dry Weather Flow (PDWF) – PDWF represents the diurnal flow patterns typically found in wastewater collection systems. PDWFs are estimated using the City’s Model of Urban Sewer System (MOUSE), which includes and has been calibrated to the City’s primary sewer system. PDWF is the basis for selecting pipe size in the IRP planning studies when increased conveyance capacity is needed. These sizes should be refined in more detailed studies and designs. See Section 2.4.

- **Peak Wet Weather Flow (PWWF)** – PWWF is the sum of the PDWF and the rainfall-dependent infiltration and inflow (RDI/I), which occurs during storm events. A 10-year storm and an estimate of the magnitude of RDI/I into the system are used for estimating future PWWFs. RDI/I includes two components: stormwater inflow (SWI) and rainfall dependent infiltration (RDI). PWWF is used for the analysis of collection system and treatment plant hydraulic capacities. See Section 2.4.

A summary of the projected ADWF in the HSA (including major sub basins in the service area) and TISA is provided in Table 2-5.

Table 2-5 Summary of Average Dry Weather Flow (ADWF) Projections ADWF (mgd)									
Tributary Area	2000	2005	Percent of Total Flow Increase in 2005¹	2010	Percent of Total Flow Increase in 2010¹	2015	Percent of Total Flow Increase in 2015¹	2020	Percent of Total Flow Increase in 2020¹
Hyperion Service Area (HSA)									
TWRP Shed	88.3	92.4	21%	96.1	22%	99.8	23%	104.4	23%
Valley Spring Lane / Forman Avenue Shed	47.5	49.5	10%	51.7	12%	53.7	12%	56.1	12%
LAGWRP Shed	30.3	31.9	8%	32.9	7%	33.7	7%	34.8	6%
Tunnel Shed	41.6	43.1	8%	44.5	8%	45.9	8%	47.8	9%
Coastal Interceptor Sewer Shed	22.7	23.6	5%	24.2	4%	24.8	4%	25.5	4%
Metro Shed	212.6	221.3	45%	227.9	43%	234.5	43%	243.0	43%
Total HSA	443.1	461.8	96%	477.3	96%	492.3	96%	511.5	96%
Terminal Island Service Area (TISA)	17.1	17.8	4%	18.4	4%	19.0	4%	19.9	4%
Total (HSA + TISA)	460.2	479.6	100%	495.7	100%	511.3	100%	531.4	100%
Note: ¹ % increase is from year 2000 of Total (HSA + TISA) Example calculation: $[104.4-88.3]/(531.4-460.2) \times 100 = 23\%$									

2.5 Existing Collection System

The City's wastewater collection system includes approximately 6,500 miles of major interceptors and mainline sewers, 46 pumping plants, and various other support facilities, such as maintenance yards and diversion structures. Approximately 650 miles of the City's sewers are primary sewers, which by definition range in size from 16-inches to over 12½ feet in height or diameter. The rest of the sewers (approximately 5,850 miles) are smaller secondary sewers that by definition range in diameter from 6-inches to 15-inches. The backbone of the City's collection system is comprised of the major interceptor and outfall sewers in the HSA.

Figure 2-4 shows the major interceptor and outfall sewers and treatment/reclamation plants within HSA. The collection system in the TISA includes numerous pumping plants and force mains.

The PDWF evaluation of the existing collection system identified the major interceptor and outfall sewers in the wastewater service area and the percent full they would operate under during PDWF conditions (see Figure 2-5).

The City also has ongoing conditions assessment programs to monitor and evaluate the hydraulic flow and structural condition of the collection system.

2.6 Collection System Options

Collection system planning for the IRP focused on the City's major interceptor and outfall sewers within the HSA. The ability of the collection system to convey wastewater flows in the year 2020 is a function of the other hydraulic elements of the system, such as treatment, storage, and flow routing. To determine future system needs and develop options to address these needs, a step-wise approach to evaluating the sewer capacities under various hydraulic scenarios was conducted using MOUSE hydraulic model runs for dry and wet weather scenarios for current and future flow conditions.

The initial identification of collection system needs to accommodate the projected year 2020 PWWFs was based on the City's standard practice of collection system planning as defined Sewer Design Manual, Section F250, stated as follows:

"Sewers shall be sized so the depth of the PDWF, projected for the design period, shall be no more than one half the pipe diameter ($d/D = 0.5$). Where upstream treatment and/or storage reservoirs are planned or available, their effect on reducing peak flows shall be considered in sizing downstream sewers."

Using this planning parameter and the various treatment scenarios (including upstream treatment expansion, expanding Tillman, expanding LAG, or constructing a new reclamation plant), initial options for addressing year 2020 major collection system needs were developed by modeling "bookends" of potential options using the MOUSE model. Bookend Option 1 reflects a system configuration with the maximum anticipated upstream flow diversions (additional treatment and storage capacity), which would minimize the downstream collection system needs. Bookend Option 2 reflects a system configuration with minimum anticipated upstream flow diversions, where maximum flow is conveyed through the downstream collection system to HTP.




FIGURE 2-4
INTEGRATED RESOURCES PLAN
Interceptor Sewers in City of Los Angeles

Produced by GIS Unit
WASTEWATER ENGINEERING
SERVICES DIVISION
BUREAU OF SANITATION

Facilities Plan
Wastewater Management






Figure 2-5

Wastewater System Flows and Capacity Gaps in Year 2020

These bookend options provide a starting point for identifying variations of these options to match treatment plant option permutations and are described below:

Bookend Option 1 - Wet Weather Storage with Upstream Expansion

For the treatment system scenario with upstream expansion of TWRP and LAG to Micro-Filtration/Reverse Osmosis, and wet weather storage at both plants, the collection system modifications were determined through a series of dry and wet weather MOUSE model runs. The resulting plant configurations for this scenario were as follows:

- TWRP: 120 mgd with 6.5 percent sludge return to the downstream collection system and 25 percent MF/RO brine return; 30 million gallons of wet weather storage.
- LAG: 30 mgd with 5.8 percent sludge return and 25 percent MF/RO brine return; 20 million gallons of storage.
- HTP: 450 mgd.

Based on this scenario, the following collection system components were deemed to be needed for the treatment scenario with upstream plant expansions and wet weather storage:

- Glendale-Burbank Interceptor Sewer (GBIS)
- Northeast Interceptor Sewer Phase II (NEIS II)
- Vermont Avenue Relief Sewer (VARs)

Bookend Option 2 - Maximum Conveyance to HTP

For the treatment system scenario that maximizes conveyance to HTP, TWRP was assumed to be maintained at its existing derated capacity with MF/RO added and LAG was assumed to be operated as a skimming plant. A skimming plant operates during dry weather to produce recycled water for end users. However, during wet weather when end users are likely to be minimal since they are primarily for irrigation, the entire flow must be able to be conveyed back to the downstream collection system. The skimming plant was assumed to effectively have no flow diversion capacity during wet weather.

Collection system modifications were determined through a series of dry and wet weather MOUSE model runs. The resulting plant configurations for this scenario are as follows:

- TWRP: 64 mgd with 6.5 percent return sludge and 25 percent brine return
- LAG: 0 mgd

- HTP: 550 mgd

For this scenario, collection system capacity from TWRP to LAG needed expansion. The VARS was found to be needed to provide relief to the south branch of the North Outfall Sewer (NOS) at the Maze area. The following collection system components were determined to be needed for the treatment scenario with conveyance of maximum flows downstream and HTP expansion:

- Valley Spring Lane Interceptor Sewer (VSLIS)
- GBIS
- NEIS II
- Vermont Avenue Relief Sewer (VARS)

2.7 Existing Treatment Facilities

An essential tool for the IRP is the wastewater treatment and effluent discharge facility capacities. There are six wastewater treatment facilities within the wastewater service area. Five treatment plants are within the HSA as follows:

- Hyperion Treatment Plant (HTP) in Playa del Rey.
- Donald C. Tillman Water Reclamation Plant (TWRP) in the Sepulveda Basin in Van Nuys.
- Los Angeles-Glendale Water Reclamation Plant (LAGWRP) across the Golden State freeway from Griffith Park.
- Burbank Water Reclamation Plant (BWRP) in the City of Burbank.
- Los Angeles Zoo Treatment Facility (LAZTF) in Griffith Park.

The sixth treatment plant, TITP, serves the TISA and is in the vicinity of the Los Angeles Harbor. The locations of the HTP, TWRP, LAGWRP, and TITP are shown in Figure 2-1.

The HSA includes three plants operated by the City of Los Angeles: TWRP, LAGWRP and HTP. The TWRP treats flows from the San Fernando Valley. The LAGWRP serves the Glendale/Burbank area and can treat excess flows that by-pass the TWRP. The HTP serves the central Los Angeles area, treats excess flows from the San Fernando Valley and Glendale/Burbank area, and processes solids from the TWRP, LAGWRP, BWRP, and LAZTF.

The BWRP is owned and operated by the City of Burbank and the Los Angeles Zoo operates its own treatment plant. The TITP serves the TISA, which includes the Los Angeles Harbor, and nearby communities, including San Pedro and Wilmington.

2.7.1 Hyperion Treatment Plant

The HTP is located adjacent to Los Angeles World Airport in the beach community of Playa Del Rey, and is the City's oldest and largest wastewater treatment facility. HTP, shown in Figure 2-6, is located on a 144-acre site adjacent to the Pacific Ocean. The plant is bounded on the north by Imperial Highway, on the west by Vista Del Mar, on the south by the Scattergood Power Plant, and on the east by the City of El Segundo.

The HTP is a full-secondary, high-purity-oxygen, activated sludge treatment plant with unchlorinated ocean discharge. HTP was designed to provide full secondary treatment for a maximum-month flow of 450 mgd (which corresponds to an ADWF of 413 mgd) and PWWF of 850 mgd. Biosolids removed during treatment of the wastewater are treated by anaerobic digestion, and are then dewatered and trucked offsite for use through a diversified management plan utilizing 100 percent beneficial use. The biosolids produced at HTP are Class "A."

The HTP provides preliminary, primary, secondary, and solids handling facilities. The basic unit processes include:

- Preliminary Treatment: Flow metering, screening, grit removal.
- Primary Treatment: Flow metering, primary sedimentation, and raw sludge and scum removal and conveyance.
- Secondary Treatment: Intermediate pump station, oxygen reactors, oxygen generation and storage, final sedimentation, return activated sludge (RAS) and waste activated sludge (WAS) piping, and WAS thickening.
- Effluent Discharge System: Effluent pumping plant, one-mile emergency outfall, five-mile outfall, emergency storage facility and by-pass channels from primary clarifiers to effluent discharge system.
- Solids Handling and Treatment: WAS thickening, anaerobic digesters, sludge screening, sludge dewatering, dewatered sludge storage and truck loading facility, and digester gas handling.

The IRP utilized simulation modeling in the planning effort for HTP's treatment system; specifically, to evaluate existing wastewater treatment capacities; identify process bottlenecks and modifications; assess potential innovative treatment technologies; and evaluate options that provide upstream satellite treatment capabilities.



Facilities Plan Wastewater Management

The results of the liquid process train model runs indicate that, with a capacity of 350 to 450 mgd, the secondary clarifiers are the main bottleneck for increased flow capacity through the plant. The addition of the anaerobic selector zones to the biological reactors is assisting in resolving the issue. These improvements along with operational adjustments to balance the amount of filaments in the sludge will potentially allow the liquid process train to handle greater than 450 mgd. It may also be possible to improve the existing secondary clarifiers to achieve additional performance by implementing modifications to the mixing baffles.

With the addition of more secondary clarifiers, the treatment capacity could be increased to approximately 600 mgd based on the limitations of the primary clarifiers.

The results also indicated that the secondary reactors, even with the change to anaerobic selectors, will not limit the capacity of the plant until the capacity is well over 900 mgd (or new treatment requirements are instituted).

The solids process train modeling results indicated that primary sludge thickening can significantly expand the capacity of the existing digesters (up to 500 mgd firm). However, treatment redundancy will need to be addressed.

2.7.2 Donald C. Tillman Water Reclamation Plant (TWRP)

The TWRP is located in the San Fernando Valley on a 91-acre site within the Sepulveda Flood Control Basin in Van Nuys (see Figure 2-7). The plant site is south of Victory Boulevard, between Woodley Avenue and the San Diego Freeway (Interstate 405). TWRP is bounded on a 52-acre portion of the site by a retaining wall on the south and west, which protects the plant against floods in the Sepulveda Basin.

The TWRP is an upstream full tertiary treatment facility with capacity to provide Title 22 tertiary treatment for a rated average dry weather flow of 80 mgd. The TWRP provides preliminary, primary, secondary and tertiary treatment. The basic unit processes include the following:

- Preliminary Treatment: Screening, grit removal, influent pumping.
- Primary Treatment: Primary sedimentation, scum removal, equalization.
- Secondary Treatment: Air activated sludge, final sedimentation.
- Tertiary Treatment: Coagulation, filtration, disinfection, dechlorination.

TWRP does not process solids; rather, solids are discharged to the sewer system for conveyance and processing at HTP. Improved treatment process upgrades (nitrification/denitrification) are being implemented at TWRP.




FIGURE 2-7
Tillman Water Reclamation Plant Site Plan

An evaluation of the existing facilities at the TWRP was performed to determine available process and hydraulic capacity or limitations based on increased influent flows. The results indicated that the secondary clarifiers and the tertiary filters are the major unit process with capacity limitations for the liquid process train. With respect to the secondary clarifiers, pilot-testing results showed that the increased load on the secondary clarifiers from the nitrification/denitrification (NdN) converted aeration tanks (due to the higher mixed liquor concentration) will decrease the available capacity by approximately 20 percent (from 80 mgd to 64 mgd).

The tertiary filters reduced capacity stems from discussions with and experience of City personnel. It is the operational experience that the filters cannot consistently meet effluent turbidity requirements at flows greater than 64 mgd. The filters also have hydraulic constraints of 100 to 120 mgd during PWWF events.

The modeling efforts determined that the aeration tanks themselves should be able to treat up to the original capacity of 80 mgd with the addition of more secondary clarifiers. The IRP assumes that the existing capacity at TWRP is 64 mgd, based on limitations of the secondary clarifiers and tertiary filters. Pilot testing for NdN in 2006 indicated that TWRP may not require capacity derating to 64 mgd from 80 mgd.


2.7.3 Los Angeles-Glendale Water Reclamation Plant

The LAGWRP is located at the southeast junction of the LA River and Colorado Boulevard between Griffith Park and the City of Glendale. The LAGWRP is bounded to the west by the City of Burbank/City of Los Angeles border, to the north by the La Canada/Flintridge area, to the east by the Glendale/Pasadena border, and to the south by the Griffith Park area. Figure 2-8 shows an aerial view of the plant.

In 1968, the cities of Los Angeles and Glendale joined resources to build the first water recycling plant in Los Angeles. The LAGWRP has been operating since 1976 and began operation at full capacity in 1986. The LAGWRP is a full tertiary treatment facility with capacity to provide tertiary effluent for an ADWF of 20 mgd. The LAGWRP provides preliminary, primary, secondary and tertiary treatment. The basic unit processes include:

- Primary Treatment: Primary sedimentation, scum removal.
- Secondary Treatment: Air activated sludge, final sedimentation.
- Tertiary Treatment: Coagulation, filtration, disinfection, dechlorination.

The LAGWRP receives its influent wastewater from the NOS, thus providing hydraulic relief for the downstream interceptor conveyance facilities and the HTP, while producing recycled water. The disinfected plant effluent is pumped to the recycled water distribution system or flows by gravity to the LA River. All solids removed from the treatment process are returned untreated to the NOS for downstream treatment at the HTP.



HEADWORKS
AND BAR SCREENS

INFLUENT
PUMP STATION

Figure 2-8

Los Angeles-Glendale Water
Reclamation Plant Site Plan



An evaluation of the existing facilities at the LAGWRP was performed to determine available process and hydraulic capacity or limitations based on increased influent flows. The results of these efforts indicated that the secondary clarifiers are the major unit process with capacity limitations for the liquid process train. Pilot testing results showed that the increased load on the secondary clarifiers from the NdN converted aeration tanks (due to the higher mixed liquor concentration) will decrease the available capacity by approximately 25 percent (from 20 mgd to 15 mgd).

The modeling efforts determined that the aeration tanks themselves should be able to treat up to the original capacity of 20 mgd with the addition of more secondary clarifiers. The IRP assumed that the existing LAGWRP capacity is 15 mgd, based on the secondary clarifiers. Pilot testing for NdN in 2006 indicated that LAG may not require capacity derating to 15 mgd from 20 mgd.

2.7.4 Terminal Island Treatment Plant

The TITP is located on Terminal Island, which is approximately 20 miles south of downtown Los Angeles. It is situated on a 19.8-acre site at the northwest corner of Terminal Way and Ferry Street (see Figure 2-9).

The TITP serves the harbor area and has been operating since the 1935. Built originally as a primary facility, the plant was upgraded and expanded to secondary treatment (1973), to tertiary treatment (filtration) (1996), and to 6 mgd of advanced treatment (microfiltration and reverse osmosis) (2001). The TITP provides preliminary, primary, secondary, tertiary, advanced and solids handling and treatment facilities. The basic unit processes include:

- Preliminary Treatment: Flow metering, screening, grit removal.
- Primary Treatment: Flow metering, primary sedimentation, and raw sludge and scum removal and conveyance.
- Secondary Treatment: Air activated sludge, final sedimentation, and RAS, and WAS piping and WAS thickening.
- Tertiary Treatment: Deep-bed, multi-media filters.
- Advanced Treatment: Microfiltration and Reverse Osmosis (MF/RO).
- Effluent Discharge System: Effluent outfall to Los Angeles Harbor.
- Solids handling and Treatment: WAS thickening, anaerobic digesters, sludge screening, sludge dewatering, dewatered sludge storage and truck loading facility, and digester gas handling.




Figure 2-9
Terminal Island Treatment Plant Existing Site Plan

Currently, TITP has the capacity to provide tertiary treatment (secondary treatment and filtration) for an ADWF of 30 mgd. A portion of TITP effluent currently undergoes advanced treatment (microfiltration/reverse osmosis) and is recycled, with the tertiary treated effluent discharged to the Los Angeles Harbor. Future advance treatment process modifications at TITP will allow the plant to recycle more wastewater and eventually eliminate effluent discharge to the Los Angeles Harbor. Solids are thickened, anaerobically digested, dewatered, and beneficially used by land application and reuse as a soil amendment.

2.8 Treatment Options

The future wastewater flows to be treated by the City in the year 2020 were estimated to be 531 mgd for ADWF. The HSA would produce the majority of this flow at 511 mgd for ADWF. Figure 2-5 above also shows future wastewater flows by service area sub basins. To manage these future wastewater flows in the HSA, the Phase I (Integrated Plan for the Wastewater Program) guiding principles recommended building new wastewater facilities upstream in the system as well as focusing on lower-cost solutions.

The City evaluated the treatment options at each treatment plant, given the future anticipated wastewater flows, treatment plant limitations, and the Guiding Principles. For the HSA, four treatment options that were investigated for the Phase II IRP include:

1. New upstream water reclamation plant(s).
2. Expansion of the existing upstream treatment facilities TWRP and the LAGWRP.
3. Expansion of HTP.
4. Some combination of any or all of the above options.

The first step in developing the treatment options was to identify the needs or “gaps” in the treatment system. As indicated above, the total wastewater flow was estimated to be 531 mgd to the City treatment facilities, with the HSA estimated to be 511 mgd. The treatment facilities (TWRP, LAGWRP, HTP, and TITP) have a total capacity of about 550 mgd (520 mgd in HSA). This assumes the capacity reductions at TWRP and LAGWRP, as well as the discharge of the waste sludge to HTP for treatment.

These totals seemed to indicate that there is no need for expansion or upgrade of any facilities. However, National Pollutant Discharge Elimination System (NPDES) permit limits for TWRP and LAGWRP may require that those plants be upgraded to advanced treatment to discharge to the LA River. In this case, the options may include converting a portion or all of the plants to recycled water only with no LA River discharge. However, some recycled water must continue to be discharged to the Los Angeles River to support river habitat, so complete elimination of river discharge is not feasible. If the plants are upgraded to advanced treatment, an option may include

discharge of the waste brine to the sewer for treatment at HTP. Either of these cases will reduce the effective capacities of TWRP and LAGWRP. A worst-case application of these changes could lower the total system capacity to about 507 mgd (496 mgd in HSA). To handle this reduction in effective capacity, some expansion and upgrade within the treatment system was assumed to be required.

Another factor that was considered was the possible future diversion of dry weather urban runoff (DWUR) to the wastewater system. This is already being planned and constructed for areas in the Santa Monica Bay Watershed (see Runoff Management Volume). At a minimum, the amount of DWUR diversion would be about 8 mgd from these coastal diversions (in the HSA only). If DWUR within the rest of the City were diverted to the wastewater system, an additional 44 mgd would be added. If DWUR from the entire watersheds, which flow through the City, were also diverted, that would be an additional 29 mgd. Therefore, the range of possible DWUR flows is 8 to 81 mgd. The increased estimated year 2020 HSA flows would be 519 to 592 mgd. Again, it was assumed that these increases may require expansions and upgrades to the facilities.

One last factor that was considered in determining the system "gaps" was the effect of the treatment facilities on the collection system. The primary needs in the collection system are upstream of TWRP, downstream of TWRP to the Valley Spring Lane/Forman Avenue (VSL/FA_ gate, the Tunnel downstream of the VSL/FA gate to HTP. Options at the upstream treatment plants or a new plant may provide relief of the last two collection system needs.

2.8.1 HTP Treatment Options

The two basic options for HTP were determined to be either expansion or no expansion. As the influent flows to HTP are affected by the operation of the upstream water reclamation plants TWRP and LAGWRP, the need to expand HTP is determined by the treatment capacity of these facilities and the resulting flow to HTP. Figure 2-10 illustrates the interrelationship between the upstream plants and HTP.

The no expansion option would primarily be associated with the options of expansion at the upstream plants or construction of a new facility (or facilities), which would result in a flow at HTP of less than its current dry weather capacity of 450 mgd.

For the expansion of HTP, the buildout capacity of HTP was assumed to be about 550 mgd for ADWF, based on information presented in the last published *Wastewater Facilities Plan* (DMJM/BV, 1990) and discussions with HTP plant, Wastewater Engineer Services Division (WESD), and Environmental Engineering Division (EED) staff.

The first step in developing the option to expand HTP to 550 mgd was to identify the unit processes that would require upgrades. The higher influent flow rate of 550 mgd was inputted into the planning model. The individual processes were then evaluated to determine the "bottlenecks" or shortfalls.

The results of the evaluation are indicated in the following:




Figure 2-10
Interrelationship of Upstream Plants with Hyperion Treatment Plant

- Between 2 and 8 additional secondary clarifiers would be needed in the future. While the existing configuration of the secondary clarifiers is circular. Any new secondary clarifiers may be rectangular, due to possible space savings and enhanced treatment capacity with this configuration.
- New secondary clarifiers would first be located in the parking lot just north of Reactor Module 9. After this space is filled, they will either be placed in the location of the existing emergency storage basins just west of the parking lot or in the location of the former administration building. Another possibility is to demolish two reactor modules (since there is excess capacity) and place the new clarifiers in the resulting space. Either way, installation of new clarifiers will present a challenge with respect to the flow conveyance from the reactors. Further study will be needed in the future on this topic.
- Between 6 to 12 additional modified egg shaped digesters would be needed depending on redundancy requirements. The location of the new modified egg shaped digesters will start in the area of the existing Conventional Digester Battery C and be in line with the existing modified egg shaped digesters.

2.8.2 WRP Treatment Options

In the initial development of the options for the upstream treatment facilities three factors were considered: the projected year 2020 flow generated by the tributary area

(including potential dry weather urban runoff diversion), the recycled water demand, and environmental goals.

The general assumptions used for evaluating the TWRP treatment options were as follows:

- Any discharge to the LA River requires advanced treatment.
- Assume brine disposal will be discharged to the sewer. Note that further study will be needed to determine the effects on HTP. A local or regional brine line will be considered as an alternate.
- Other recycled water applications must only meet current Title 22 requirements, except for groundwater replenishment which would require advanced treatment if implemented.
- Discharge limits will be the same for dry and wet weather at the upstream facilities. Note that currently they have a different limit for turbidity during storm events, which gives them the option to bypass the tertiary filters. However, all the other constituents in the 1998 NPDES Permit do not have different limits.
- Nitrification/ denitrification (NdN) conversion is considered to be an existing situation.
- NdN conversion at TWRP will require derating by 20 percent.
- Replacement of tertiary filters at TWRP is considered to be the existing situation.
- Waste sludge discharged back to sewer is assumed to be 6.5 percent of influent flow for TWRP. The sludge waste is based on historical information provided by the City.
- The assumed brine return rates are 10 percent for MF and 15 percent for RO.

The evaluation determined that there are three general options for TWRP are as follows:

- A. No expansion or advanced treatment upgrade.
- B. Full advanced treatment upgrade
- C. Adding storage to provide collection system and treatment relief during PWWF.

These three general options were further defined (see Table 2-6) for IRP Alternatives planning purposes.

Table 2-6 Tillman WRP Options for the Year 2020				
Description		Rated ADWF Capacity	Rated PWWF Capacity	Potential Recycled Water Produced***
1A	No expansion or advanced treatment upgrade without operational storage	64 mgd*	0 mgd	64 mgd**
1B	No expansion or advanced treatment upgrade with operational storage	64 mgd*	0 mgd	64 mgd
2A	Partial advanced treatment upgrade without wet weather or operational storage	64 to 120 mgd*	27 to 90 mgd	51 to 92 mgd**
2B	Partial advanced treatment upgrade with 60 mgd wet weather/ operational storage	64 to 120 mgd*	67 to 130 mgd	51 to 92 mgd
3A	Full advanced treatment upgrade without wet weather or operational storage	64 to 120 mgd	64 to 120 mgd	51 to 92 mgd**
3B	Full advanced treatment upgrade with 60 mgd wet weather/ operational storage	64 to 120 mgd	104 to 160 mgd	51 to 92± mgd****
Notes: * Depending on the recycled water demand ** Subject to diurnal constraints *** After brine and waste sludge discharge **** Could be more depending on operation of added storage				

2.8.3 LAG Treatment Options

As with other upstream plants, the evaluation of LAGWRP options also considered the same three factors: the projected year 2020 flow generated by the tributary area (including potential dry weather urban runoff diversion), the recycled water demand, and environmental goals.

The general assumptions used for the LAGWRP options were as follows:

- Any discharge to the LA River requires advanced treatment.
- Assume brine disposal will be discharged to the sewer. Note that further study will be needed to determine the effects on HTP. A local or regional brine line will be considered as an alternate.
- Other recycled water applications must only meet current Title 22 requirements.
- Discharge limits will be the same for dry and wet weather at the upstream facilities. Note that currently they have a different limit for turbidity during storm events, which gives them the option to bypass the tertiary filters. However, all the other constituents in the 1998 NPDES Permit do not have different limits.
- Nitrification/ denitrification (NdN) conversion is considered existing situation.
- NdN conversion at LAGWRP will require derating by 25 percent.

- Waste sludge discharged back to sewer is assumed to be 5.8 percent of influent flow for LAGWRP. The sludge waste is based on historical information provided by the City.
- The assumed brine return rates are 10 percent for MF and 15 percent for RO.

The evaluation determined that there are three general options for LAGWRP are as follows:

- A. No expansion or advanced treatment upgrade.
- B. Expansion and no advanced treatment upgrade.
- C. Full advanced treatment upgrade.

Table 2-7 lists the general LAGWRP options, which were used to develop the integrated IRP alternatives.

Table 2-7 Los Angeles-Glendale Water Reclamation Plant Options for the Year 2020				
Description		Rated ADWF Capacity	Rated PWWF Capacity	Potential Recycled Water Produced***
1A	No expansion or advanced treatment upgrade without operational storage	15 mgd*	0 mgd	15 mgd**
1B	No expansion or advanced treatment upgrade with operational storage	15 mgd*	0 mgd	15 mgd
2A	Expansion with no advanced treatment upgrade without wet weather or operational storage	15 to 50 mgd*	0 mgd	15 to 50 mgd**
2B	Expansion with no advanced treatment upgrade with 20 mgd wet weather/ operational storage	15 to 50 mgd*	0 mgd	15 to 50 mgd
3A	Full advanced treatment upgrade without wet weather or operational storage	15 to 50 mgd	15 to 50 mgd	11 to 36 mgd**
3B	Full advanced treatment upgrade with 20 mgd wet weather/ operational storage	15 to 50 mgd	28 to 63 mgd	11 to 36± mgd****
Notes: * Depending on the recycled water demand ** Subject to diurnal constraints *** After brine and waste sludge discharge **** Could be more depending on operation of added storage				

2.8.4 TITP Options

Because the TITP is currently operating at well below its capacity (the ADWF is 19 mgd whereas capacity is 30 mgd), TITP options were not required at this time.

2.8.5 New Water Reclamation Plant Options

As with other upstream plants, planning for a new treatment facility considered the same three factors: the projected year 2020 flow generated by the tributary area (including potential dry weather urban runoff diversion), the recycled water demand, and environmental goals.

In order to help with the process of evaluating a site and new water reclamation plant (WRP), the IRP team posed the question, “What criteria should be used in evaluating a new WRP?” to the Steering Group, the Technical Advisory Committee (TAC) and the Management Advisory Committee (MAC). Table 2-8 summarizes the resulting criteria.

Table 2-8 Criteria for New and Upgraded Facilities	
Category	Description
Location	
Upstream VS. Downstream	Generally, if the facility is located in or near the San Fernando Valley
Zoning/ Environmental Justice	Appropriate zoning on actual site and within surrounding area. Consider also environmental justice issues
Not Using Existing Open Space	Preferred to not use existing open space for new facility location. Look for opportunities for better use of site or creating open space
Low Cost	
Land Purchase	Cost of land acquisition
Mitigation	Cost of mitigation for public acceptance (i.e. buried tanks, architectural treatments, etc.)
Operational	Excessive pumping, accessibility issues, etc.
High Beneficial Use of Water Resources	
Recycled Water Opportunities	Proximity to recycled water demands
Runoff Treatment Opportunities	Ability to intercept dry weather urban runoff
Multiple Benefits	
Recreational	Opportunity to include park, lake, wetlands, etc.
Commercial	Opportunity to integrate with commercial possibilities for the site
Educational	Opportunity for public education
Inter-Agency/Inter-Project Opportunities	Opportunity for the integration with other agencies plans and projects (i.e. share costs, planning, etc.)
Environmental	Opportunities to enhance the environment within Los Angeles
Revitalization/ Redevelopment Opportunities	Opportunities to help revitalize and/or redevelop areas of Los Angeles

Table 2-8 (Continued) Criteria for New and Upgraded Facilities	
Category	Description
Most Adaptable	
Site Location and Characteristics	Site would have flexibility to incorporate changes in flow, regulations, or technology. It would also allow for phasing
Least Risk	
Technology	Tied to the site size. Smaller sites would need innovative processes to achieve same treatment capacity as larger sites
Collection System Relief	Location helps to relieve collection system needs
Site Characteristics	Includes seismic, flooding, etc.
Environmental	Site does not have existing environment constraints or potential problems
Project Implementation	Site has less environmental, regulatory, political, and public acceptance issues
More Decentralized	
Site Location	Treats local flow and reuses it locally


Although determining actual sites for a new plant would require a significant amount of time and input from stakeholders and the public, the IRP team identified some general areas for new plant locations based on system needs.

These locations were based only on the proximity to collection system needs, recycled water demands, excess wastewater flow, and a discharge location (LA River). The other criteria listed in Table 2-8 were to be evaluated during the alternatives analysis. The general locations identified for a new treatment plant were:

- *Valley Spring Lane/ Foreman Avenue (VSL/FA)* – A new WRP in this location could help to relieve the collection system downstream (the tunnel). It could also help to provide recycled water to the central San Fernando Valley. It may even be connected to the TWRP and LAGWRP recycled water system to provide redundancy to the system.
- *Downtown Southeast* – A new WRP in this area would primarily function to provide recycled water to the demands in the downtown area. It could be connected to LAGWRP to help with any new recycled water demand.
- *Downtown West/Westside* – A new WRP in this location would help to serve recycled water needs to the westside as well as possibly to downtown. It could help the collection system downstream, although much of the need is upstream of this area. Locating a place to discharge (other than returning to the sewer) from a plant may be difficult in this area. Figure 2-11 identifies these general areas.

The general assumptions used for the new WRP options were as follows:

- Any discharge to the LA River requires advanced treatment.
- Assume brine disposal will be discharged to the sewer. Note that further study will be needed to determine the effects on HTP. A local or regional brine line will be considered as an alternate.
- Other recycled water applications must only meet current Title 22 requirements.
- Discharge limits will be the same for dry and wet weather at the upstream facilities.
- Waste sludge discharged back to sewer is assumed to be 6.0 percent of influent flow for a new WRP.
- The assumed brine return rates are 10 percent for MF and 15 percent for RO.



2-11
Initial General Areas for a New Water Reclamation Plant

The three general options for a new WRP are similar to the options for LAGWRP and were as follows:

- A. No new WRP
- B. New WRP with no advanced treatment
- C. New WRP with full advanced treatment

Table 2-9 lists the general options that were used to develop the integrated IRP alternatives.

Table 2-9 New Water Reclamation Plant Options for the Year 2020				
Description		Rated ADWF Capacity	Rated PWWF Capacity	Potential Recycled Water Produced***
1A	No new WRP	0 mgd	0 mgd	0 mgd
2A	New WRP with no advanced treatment and without wet weather or operational storage	10 to 60 mgd*	0 mgd	9.4 to 56 mgd**
2B	New WRP with no advanced treatment upgrade with wet weather/ operational storage	10 to 60 mgd*	0 mgd	9.4 to 56 mgd
3A	New WRP with full advanced treatment and without wet weather or operational storage	10 to 60 mgd	10 to 60 mgd	7 to 42 mgd**
3B	New WRP with full advanced treatment and wet weather/ operational storage	10 to 60 mgd	17 to 73 mgd	7 to 42± mgd****
Notes: * Depending primarily on the recycled water demand ** Subject to diurnal constraints ** After brine and waste sludge discharge *** Could be more depending on operation of added storage				

2.9 Biosolids Management

The approach used for evaluating biosolids management options is depicted in Figure 2-12. First, the existing biosolids management situation was reviewed, including an analysis of drivers, current biosolids production and quality and current management contracts. Following this, the available technologies for creating biosolids products were reviewed in parallel with the markets for these products. This then led to development of the recommended planning direction and associated cost projections and identification of potential triggers for change. The recommended strategy aimed to assist in providing direction for future biosolids management by the City in a manner that meets the goals and objectives of the City's Biosolids Environmental Management System (EMS) and outlined in this task.

Several environmental goals were identified to guide the development of a sustainable biosolids management program. These goals were based on the City's Biosolids EMS as follows:

- Management should be in line with the Biosolids EMS
- Comply with all regulations, federal, state and local
- Provide good stewardship of resources - both biosolids and finances
- Maximize the reliability of the long-term biosolids management program
- Improve public perception and confidence
- Realize innovative, cost-effective & environmentally sound ideas




Figure 2-12
Biosolids Management Task Approach

- Provide multiple processing options
- Maintain in-basin management options
- Continued use of private sector hauling and land application
- Diversify markets
- Identify and maintain back-up options

Various factors and drivers affecting biosolids management were considered in the development of biosolids management options, including existing biosolids quality, biosolids production quantities, regulations, public perception, product market options, and practices of other agencies. Technologies considered in the evaluation included the following:

- | | |
|----------------------------------|-----------------------------|
| ■ Composting | ■ Gasification |
| ■ Heat Drying | ■ Combustion |
| ■ Chemical Treatment | ■ Renewable Energy Recovery |
| ■ Pyrolysis | ■ Thermophilic Digestion |
| ■ Super Critical Water Oxidation | |

Market options considered included the following:

- Land Application for Non-food crops
- Land Application at City Farm, EQ biosolids
- Horticulture - City Uses
- Horticulture – ornamental & nursery
- Horticulture – blending & bagging for retail
- Silviculture – Shade Tree Program
- Biomass/Ethanol crops
- Citrus, avocado, vineyard & orchard
- Ag-Lime Applications
- Direct Energy
- Erosion Control
- Direct Landfilling
- Landfill Partnering – Daily Cover
- Construction Market
- Non-construction Market
- Dedicated Land Disposal
- Fuel usage

The approach to evaluation of the biosolids management options for the City focused on coordinating two key aspects, the biosolids markets and the product technologies that can process the biosolids to form a product that is compatible with the available markets. Sustainable biosolids management needs to consider a business-type approach, where suitable markets are first identified and then the steps necessary to provide suitable products are implemented. The evaluation of biosolids management, therefore, first pre-screened the available biosolids product technologies to identify any that are inappropriate for further consideration in the IRP, and then identified the types of products provided by the range of technologies. This was followed by a more detailed ranking of the main product technology categories, to assistance in developing planning recommendations. A summary list of the product technologies and the preliminary screening conducted is provided in Table 2-10.

Table 2-10 Summary of Initial Screening of Biosolids Product Technologies		
No.	Process	Appropriate for IRP
1	Thermophilic Digestion	Y
2	Composting	Y
3	Heat Drying	Y
4	Solar Drying	N – footprint, pathogen reduction control
5	Bactericides	N – not EQ process, handling & dosing of toxin
6	Chemical Treatment	Y
7	Combustion	Y
8	Super Critical Water Oxidation	Y
9	Gasification	Y
10	Pyrolysis	Y
11	Renewable Energy Recovery	Y
Note: * For processes identified to be inappropriate, details were provided in the text below		

The results of the initial screening step showed that of the 11 broad categories of product technologies, two were considered to have fatal flaws, while nine categories were carried forward for more detailed evaluation of the viable technologies.

To evaluate the wide range of available biosolids product technologies, four broad objectives were identified that should be met by any product technology. These objectives listed below reflect key issues of concern for the City, the IRP, and biosolids management in Southern California:

- Protect Public Health and the Environment
- Provide System Reliability
- Enhance Cost Efficiency
- Implementation/Quality of Life

The product technology options that were not considered to have fatal flaws were ranked based on the objectives described above, and measurable criteria developed from those objectives. Evaluating the technologies was based on information from City staff and the IRP team with regard to specific technologies, experience with specific technologies and knowledge of the status of development of technologies.

Table 2-11 summarizes the total scores for the established and emerging technology categories. In the established technologies, thermophilic digestion, as currently conducted by the City, ranked the highest, with composting and heat drying being next ranked technologies. The TIRE project was the clear winner among the emerging technologies. These processing options may be conducted after thermophilic digestion, unless in the future the City selects an option to handle a sufficient volume of digested or undigested solids to allow some or all of the City's biosolids to be processed without prior thermophilic digestion and/or dewatering. This may be the case if the TIRE demonstration project is successful.

Table 2-11				
Summary of Initial Screening of Biosolids Product Technologies				
No.	Established Technologies	Score	Emerging Technologies	Score
1	Thermophilic Digestion	62	Renewable Energy Recovery (TIRE)	60
2	Composting	57	Super Critical Water Oxidation	49
3	Heat Drying	56	Pyrolysis	47
4	Combustion	52	Gasification	46
5	Chemical Treatment	48		

The following recommendations were made for long term direction of biosolids management, based on the evaluation and ranking of the biosolids product technologies, the evaluation of biosolids product markets, and consideration of the City's Biosolids EMS:

1. Continue thermophilic digestion and bulk land application at the Green Acres Farm:
 - Application at the farm should be restricted to 550 wet tons per day (wtpd) (as per initial estimate for 50-year farm life), unless a different suitable nutrient and metal loading rate is determined for long term sustainability;
 - Conduct a detailed evaluation of agronomic uptake rates and groundwater interactions at the farm;
 - Identify and implement farm improvements to maximize nutrient uptake, plant yields and revenues, such as addition of gypsum to sodic soils;
 - Provide biosolids storage facility at the farm for conditions when spreading is limited by adverse weather or other conditions; and
 - Conduct demonstration projects to showcase benefits of biosolids land application and encourage the use of biosolids for non-food farming.
2. Implement the TIRE demonstration project to determine true feasibility and costs for renewable energy recovery. If successful it is anticipated that the TIRE facility will be able to treat the equivalent of 200 wtpd of digested cake on average, with a maximum capacity of 400 wtpd for a short duration. This will provide diversification with an energy-based biosolids management option, rather than reliance on options that use the nutrient value of biosolids
3. Diversify biosolids management through consideration of other biosolids management options, such as private or City-owned composting or heat drying facilities. Although the current volume of 750 wtpd can be managed with the above two options, management of projected future increases to over 900 wtpd will require additional capacity. For an agency such as the City, which produces large volumes of biosolids, heavy reliance on one management option can contribute to public perception issues and leaves the City more vulnerable to changes in regulations or other factors that may impact costs of a biosolids management option.

As a closing note, biosolids management is a very dynamic area, with changes in regulations, public perception, technologies and costs. Biosolids management plans therefore would need to provide flexibility to respond to changing situations. Triggers for change that would lead to a re-consideration of the biosolids management strategy were identified and included:

- Changes in local county ordinances, particularly Kern County;
- Changes in the Part 503 regulations
- Increasing need for diversification

- Successful demonstration of the TIRE project
- Support for regional biosolids processing facilities

2.10 Alternatives Analysis

The collection system options described in Section 2.5 above; the treatment options described in Section 2.7 above for the HTP, TWRP, LAG, TITP, a new water reclamation plant; and the biosolids management options described in Section 2.8 above; along with the recycled water options (see Section 3 of this volume) and runoff options (Section 4 of this volume), were then carried forward and assembled into integrated system-wide alternatives. The integrated alternatives were then evaluated, refined, and subjected to a cost-benefit analysis to identify the four highest ranked alternatives that were then analyzed in an environmental impacts report (see Section 8 of this volume). Section 5 of this volume and Volume 4 of the IRP Facilities Plan provides more details on the alternatives development, evaluation, and ranking process.

Section 3

Water Management

3.1 Introduction

The Los Angeles Department of Water and Power (DWP) provides potable water for single-family residences, multi-family residences, industries, commercial businesses, and government agencies throughout the City. DWP's mission is "to provide our customers with reliable, high quality and competitively priced water services in a safe and publicly and environmentally responsible manner."

In an arid region like Southern California, managing water demands and available supplies is an important issue. The California Urban Water Management Planning Act requires water suppliers to develop water management plans that:

- Outline their efforts to use water efficiently;
- Describe their current and future efforts for the development of alternative supplemental water supplies to meet growing water needs; and update their water resources management plan to coincide with changing needs and the diversity of water supply options available.

Consistent with this legislation, the City's *Year 2005 Urban Water Management Plan* (UWMP) described the DWP's efforts to promote efficient use and management of its water resources.

The IRP complements the UWMP by providing input to DWP's UWMP process. The water management component of the IRP focused on the following elements:

- Water conservation and its impact on potable water demands, wastewater flows, and dry weather urban runoff quantity
- Recycled water and its impact on water supply
- Beneficial use of runoff and its impact on water supply

Detailed discussion of the Recycled Water elements of the IRP is included in a separate document, titled *Los Angeles Recycled Water Master Plan*.

The data presented in this section is a summary of that data presented in the *Facilities Plan, Volume 2: Water Management* (July 2004), which was taken from the City's *Year 2000 Urban Water Management Plan* (UWMP) and fiscal year 2002 annual update. Subsequent to the development of *Facilities Plan, Volume 2: Water Management*, DWP has prepared the year 2005 UWMP.

3.2 Planning Parameters

The City's water service area is aligned with the City boundary. The City encompasses approximately 465 square miles and serves a population of nearly 3.8 million (per SCAG 2001 population data). DWP manages the City's water system. Refer to the *Facilities Plan, Volumes 1-3* for the planning parameters and guiding principles that apply to the IRP. Several of the guiding principles are specific to water management. These guiding principles include as follows:

- Producing and using as much recycled water as possible from the existing and planned facilities
- Increasing the level of water conservation beyond what is currently planned
- Focusing on lower-cost solutions within the framework of the policy elements noted above

3.3 Potable Water

Understanding the current and future issues related to potable water was an important element to the IRP. Although the IRP primarily focused on facilities planning for the wastewater, recycled water and runoff systems, options and alternatives in those areas could provide additional source water for non-potable or potable demands.

3.3.1 Demands

There are several factors influencing water usage including demographics, climate, the economy, water pricing, and water conservation programs. The DWP projects water demands using population, housing forecast, historical demand data, and future conservation efforts. Population and conservation are key factors influencing water use. Based on these factors, the water projections for each customer class were developed as is summarized in Table 3-1. It is expected that the actual water usage between 2000 and 2020 should fall within plus or minus six percent of these projections (DWP, 2000).

Table 3-1 Projected Water Demands for Each Customer Class in Thousands of Acre-ft¹					
Customer Category	2005	2010	2015	2020	Average Annual Growth Rate
Single Family Residential	234	240	249	260	0.8%
Multi Family Residential	216	240	260	283	2.2%
Commercial	121	124	128	131	0.7%
Industrial	26	27	28	30	1.3%
Government	42	44	45	47	0.7%
Subtotal	639	675	710	751	1.2%
Unaccounted Water ²	40	43	46	49	1.6%
Total	679	718	756	800	1.3%

Notes:
¹Source: Urban Water Management Plan (DWP, 2000)
²6 percent of the subtotal (DWP, 2000)

The total projected water demands are shown in Figure 3-1.




Figure 3-1
DWP Historical and Projected Water Demand and Population

3.3.2 Supply

The City has four principal water supply sources as shown in Figure 3-2:

Figure 3-3 shows the average year percentage of total annual usage for the last 10 years supplied by each source (DWP).

- Los Angeles Aqueduct System (Los Angeles Owens River, 1st and 2nd Aqueducts)
- Local groundwater
- Purchased water imported by the Municipal Water District of Southern California (MWD) through the State Water Project and Colorado River Aqueduct
- Recycled water



Figure 3-2
Principal Water Supply Sources




Figure 3-3
Summary of Water Supply for the Average of 10 Years

Summary of Water Supply Projections

A summary of the City's projected water supply sources is presented in Table 3-2, which summarizes the anticipated supply sources and demands for normal and dry climate conditions.

Table 3-2 Potable Water Forecasts for the City of Los Angeles												
Year	Projected Demand (1000 acre-ft)		Projected Supply ¹ (1000 acre-ft)									
			Local Groundwater		Los Angeles Aqueducts		Metropolitan Water District ⁴		Recycled Water ³		Seawater Desalination	
	Normal	Dry ²	Normal	Dry	Normal	Dry	Normal	Dry	Normal	Dry	Normal	Dry
2005	679	720	108	135	296	135	267.35	442.35	44.15	44.15	0	0
2010	718	761	108	135	296	135	284.4	461.4	60.055	60.055	11.2	11.2
2015	757	802	108	135	296	135	318.15	497.15	72.75	72.75	11.2	11.2
2020	799	847	108	135	296	135	354.45	536.45	78.45	78.45	11.2	11.2
Notes: ¹ Source: Urban Water Management Plan (DWP 2000) and as updated in June 2003. ² The DWP defines a dry year as a year in which the total rainfall is at the 10 th percentile (exceeded nine out of ten years). An estimated additional 6 percent of the projected demand will be required under these conditions (DWP, 1995). ³ The recycled water values listed reflect what is included in draft 2003 UWMP update (Van Wagoner 2003) and include recycled water discharges to the Los Angeles River as an environmental enhancement. As part of the IRP, these values will be evaluated and modified as additional recycled water users are identified. See Section 5 for additional information. ⁴ The MWD values reflect what is included in 2000 UWMP (DWP 2000) and as updated in June 2003. The IRP will evaluate potential reductions in these values as recycled water usage is increased.												

In March 2003, MWD released a *Report on Metropolitan's Water Supplies*, which outlines MWD's water resources development plans and reliability outlook for at least the next twenty years. Additionally, MWD and its member agencies prepared the *MWD Integrated Water Resources Plan, 2003 Update* (May 2004), which is an updated version of *MWD's 1993 Integrated Resources Plan*. Both reports contain in detail the various elements of MWD's long-term plans to deliver Colorado River and State Water Project supplies.

3.4 Water Conservation

Water conservation has become a way of life in California and is a critical part of the state's overall strategy for managing water resources efficiently. The City operates one of the most successful conservation programs in the United States and has reduced its annual potable water demand by more than 15 percent since 2001. [DWP – UWMP FY 2001/02 Update].

Despite the fact that total water demand has slowly increased since the end of water rationing in 1992, water conservation levels remain above 15 percent. The conservation efforts correspond to actual water savings that have occurred as a result of changes in hardware and water usage patterns of residents and businesses within the City. The City's nationally recognized water conservation programs are largely responsible for the significant reduction in the City's water use over the last decade. According to DWP's UWMP, by 2020 hardware-based conservation alone is projected to contribute to a ten percent savings in water use.

In December of 1991 DWP, along with 120 urban water agencies, environmental groups and other interested groups, signed the Memorandum of Understanding (MOU) on Urban Water Conservation. The MOU identified “Best Management Practices” (BMPs), as proven conservation measures, as determined by the California Urban Water Conservation Council (CUWCC). All signatories to the MOU are committed to implement BMPs, subject to the condition that the BMPs are cost effective for the individual water agencies.

The implementation of conservation programs not only saves water, but also delays the need for costly expansions of sewer and stormwater facilities by reducing wastewater discharge into the sewer collection and treatment system and reducing runoff. However, even with aggressive conservation measures, City water demands are expected to increase with population growth.

3.4.1 Existing and Planned Conservation Measures

DWP has implemented a plethora of water conservation measures, including tiered water pricing, financial incentives for the installation of ultra-low-flush (ULF) toilets and water efficient clothes washing machines, technical assistance programs for business and industry, and large scale irrigation efficiency programs. These programs and their associated water savings are described in the 2000 Urban Water Management Plan (UWMP) and the FY 2001/02 Annual Update (DWP). Conservation programs can be grouped into five categories:

- Support and Education
- Residential
- Commercial /industrial/governmental
- Landscape
- System maintenance measures

The programs include traditional demand-side management measures, as well as infrastructure improvement programs that contribute to reductions in water consumption. Combined with a conservation pricing structure, these programs increase system reliability, efficiency, and in some cases provide water quality benefits. A conservation water pricing structure encourages consumers to reduce water consumption as the cost of water increases per unit with increased consumption.

3.4.2 Potential Additional Conservation Measures

As discussed in Section 3.2, one of the IRP guiding principles was increasing the level of water conservation beyond what is currently planned. This guiding principle is aligned with DWP's water conservation program, which continues to investigate new conservation measures. Following is a summary of these additional measures that DWP is investigating for consideration into the conservation program.

- "Smart Irrigation" implemented Citywide - "Smart Irrigation regulates the amount of irrigation on a property which reduces over-watering. If installed at 70 percent of all single-family homes, multi-family homes, and commercial/institutional properties by 2020, it was estimated that Citywide there could be a maximum reduction in water consumption of up to 15,800 acre-feet/yr. Additionally, if smart irrigation were implemented City wide, it would reduce dry weather runoff by up to 11 mgd (see Section 4 of this document for details on runoff reduction from smart irrigation).
- X-Ray Film Processor Water Saving Rebate Program - Existing x-ray processing systems in hospital applications consume large volumes of water during the film washing process. New technology has been developed that, when installed on the x-ray film processing systems, enables this equipment to save extraordinary amounts of water. Recent studies have demonstrated that the addition of a specially designed package system to the existing x-ray film processor systems can save an average of about 3.2 acre-ft annually, per system, in hospital settings.
- Retrofit of Existing Car Washes - There are 499 permitted car washes within the City of Los Angeles. Approximately 10 percent of these facilities were contacted as a part of this study. Based upon the information the car washes provided, only 60 percent of the car washes recycle their water. Further investigations would need to be done to determine the amount of water savings that could be achieved through retrofits.
- Waterless urinals (no water is required for their use) if approved for use in the City. This technology is currently being studied by the Los Angeles Department of Building and Safety.
- A pre-rinse kitchen sprayer rebate program for restaurants. The savings associated with the reduction of water may cover the full cost of the kitchen device. Estimated annual savings per kitchen is 75,000 gallons.

3.5 Recycled System

The use of “recycled” water (i.e., highly treated wastewater) for non-potable needs was an important area of focus for the IRP. One of the guiding principles from Phase I was to produce and use as much recycled water as possible from existing and planned facilities. Recognizing the importance of recycled water, the City continues to develop recycled water projects to help meet increasing demands by augmenting the City’s water supply. In fact, the City’s commitment to investigating and developing a plan for recycled water use is demonstrated by the development of a stand-alone *Los Angeles Recycled Water Master Plan* as part of the IRP. This section provides a short summary of the existing recycled water systems and potential demands.

3.5.1 Existing Recycled Water System and Demands

Wastewater in the City of Los Angeles is collected and transported through some 6,500 miles of major interceptors and mainline sewers, more than 11,000 miles of house-sewer connections, 46 pumping plants, and four treatment plants. The Department of Public Works, Bureau of Sanitation (BOS) is responsible for the planning and operation of the wastewater program. Figure 3-4 shows the City’s four wastewater treatment plants and seven sewersheds that feed into the plants.

A portion of the treated effluent from the wastewater plants is provided to DWP to meet recycled water demands. DWP is responsible for planning, construction and operations of recycled pipelines and connections that will take the treated effluent water to its customers.

At the core of the existing recycled water system there are four wastewater treatment plants.




Figure 3-4
City Wastewater Plants and Sewersheds

Donald C. Tillman Water Reclamation Plant

The Donald C. Tillman Water Reclamation Plant (Tillman) has a rated capacity of 80 million gallons per day (mgd). The current level of treatment is Title 22 (tertiary) plus nitrogen removal (NdN). Currently, this plant is providing recycled water to the Japanese Garden, Wildlife Lake, and Lake Balboa. The remaining tertiary-treated water is discharged into the Los Angeles River.

Los Angeles-Glendale Water Reclamation Plant

The Los Angeles-Glendale Water Reclamation Plant (LAG) has a design capacity of 20 mgd. LAG provides landscape irrigation for Griffith Park and the Los Angeles Greenbelt Project, the remainder is discharged to the Los Angeles River.

Terminal Island Treatment Plant

The Terminal Island Treatment Plant (TITP) provides tertiary treatment with a capacity of 30 mgd, with average flows being about 16 mgd, which discharges to the Los Angeles Harbor. There is an Advanced Wastewater Treatment Facility, with MF/RO treatment for 6 mgd of the wastewater effluent, after which this recycled water can be used for seawater barrier and industrial and landscaping uses in the harbor area.

Hyperion Treatment Plant

The Hyperion Treatment Plant treats to full secondary treatment. A majority of the treated water is discharged into the Santa Monica Bay, and the rest is delivered to the West Basin Water Reclamation Plant to meet recycled demands in the West Basin Municipal Water District service area and parts of the City of Los Angeles. Currently about 34,000 acre-ft/ yr of water from HTP is sold to the West Basin Municipal Water District for additional treatment and then used to meet recycled water demands in its service area. The current capacity of HTP is 450 mgd, with an average wastewater flow of 350 mgd.

There are eight recycled water projects that the City has developed. Four of these projects are currently providing recycled water for landscape irrigation and commercial uses.

- Japanese Garden
- Wildlife Lake
- Lake Balboa
- Griffith Park
- Los Angeles Greenbelt Project
- Westside Water Recycling Project
- East Valley Water Recycling Project
- Harbor Water Recycling Project

Table 3-3 summarizes the existing recycled water use that is occurring in the City of Los Angeles. The existing recycled water use is broken down into three main categories: (1) irrigation; (2) environmental/recreation; and (3) wholesale sales to West Basin Municipal Water District.

Table 3-3 Existing Recycled Water Use in City of Los Angeles		
Type of Use/Project	Source of Supply	Amount of Supply
Irrigation		
-Griffith Park and LA Greenbelt	LAGWRP	1,600 acre-ft/ yr
-Westside	HTP/West Basin Plant	<u>350 acre-ft/ yr</u>
Sub-Total		1,950 acre-ft/ yr
Environmental/ Recreation		
-Japanese Garden	TWRP	4,400 acre-ft/ yr
-Wildlife Lake	TWRP	7,800 acre-ft/ yr
-Lake Balboa	TWRP	<u>16,300 acre-ft/ yr</u>
Sub-Total ¹		28,500 acre-ft/ yr
Wholesale Sales to West Basin		
Municipal Water District ²	HTP	34,000 acre-ft/ yr
Total Beneficial Use		64,450 acre-ft/ yr
¹ The water provided to Japanese Garden, Wildlife Lake and Lake Balboa is ultimately discharged into the Los Angeles River and is providing additional environmental benefits. ² Secondary treated water provided to West Basin MWD, which is further treated to meet recycled water demands in its service area.		

3.5.2 Potential Demands for Recycled Water

DWP's implementation of recycled water factors in economics, water quality regulations, and public acceptance. DWP's approach for identifying recycled water customers takes into account the following criteria:

- *Size of potential customer* – initial focus on larger customers
- *Type of water use* – treatment requirements area based on the end use
- *Proximity to existing recycled water system* – costs to deliver water is lower for those potential customers nearest to existing wastewater treatment (due to costs of pipelines and pump stations)
- *Willingness to use recycled water* – not all potential water customers have a desire to use recycled water; in most cases the City may need to provide proper incentives.

3.5.2.1 Identifying DWP Top Water Customers

The following summarizes the number of customers that were identified as representing the potential for recycled water:

- Irrigation customers with separate metered connections for irrigation:
 Number of customers 768

Range of water demand	1 acre-ft/ yr to 2,296 acre-ft/ yr
Total water demand potential	20,200 acre-ft/ yr

- Industrial customers that may use the water for process use, and would likely incur user retrofit costs for installing separate plumbing for non-potable process demands:

Number of customers	30
Range of water demand	15 acre-ft/ yr to 2,249 acre-ft/ yr
Total water demand potential	8,453 acre-ft/ yr

- Other customers that may use the water for irrigation, but would likely incur user retrofit costs for installing separate plumbing for non-potable irrigation demands:

Number of customers	1,574
Range of water demand	1 acre-ft/ yr to 2,021 acre-ft/ yr
Total water demand potential	73,205 acre-ft/ yr

Figure 3-5 plots the potential recycled water customers with respect to their potential water demand.

Figure 3-5 shows that 2,372 potential water customers can use approximately 103,000 acre-ft/ yr of recycled water. The graph also shows that the first 145 customers (which only represent 6 percent of the total number of customers) account for 50 percent of the total water demand. Furthermore, 500 customers (which represent 21 percent of the total) account for 70 percent of the total water demand.




Figure 3-5
Potential Recycled Water Demand

3.5.2.2 Mapping Potential Recycled Water Customers

After identifying the potential recycled water customers, the next step was to map them in order to determine their proximity to the existing (or planned) recycled water system. This was accomplished using GIS. Figure 3-6 shows this plot of the potential customers.

The pink shaded areas represent the Tier 1 potential for recycled water – the customers in these areas are the closest to the existing (or immediately planned) recycled water system. The green shaded areas represent the Tier 2 potential for recycled water – the customers in these areas are further away from the existing (or immediately planned) recycled water system. In general, the Tier 1 customers should be less expensive to serve than the Tier 2 customers.

Figure 3-6 shows four areas of the City where delivery of recycled water is the most economical to achieve:

1. **The Valley** – which has a Tier 1 recycled water demand potential of 14,200 acre-ft/ yr, and a Tier 2 potential of 42,400 acre-ft/ yr
2. **Central City** – which has a Tier 1 recycled water demand potential of 2,000 acre-ft/ yr, and a Tier 2 potential of 29,500 acre-ft/ yr
3. **Westside** – which has a Tier 1 recycled water demand potential of 4,000 acre-ft/ yr, and a Tier 2 potential of 14,300 acre-ft/ yr
4. **Harbor** – which has a Tier 1 recycled water demand potential of 9,300 acre-ft/ yr, and a Tier 2 potential of 10,900 acre-ft/ yr
5. **Total** – Tier 1 recycled water demand potential is 29,500 acre-ft/ yr, while the Tier 2 recycled water demand potential is 97,100 acre-ft/ yr

There are approximately 158 water customers that are a considerable distance from existing City facilities and therefore do not meet Tier 2 criteria. This accounts for about 5,800 acre-ft/ yr of the 103,000 acre-ft potential (shown in Figure 3-6).

It should be noted that this potential for recycled water demand does not factor in the capacity limitations of the wastewater treatment plants. Wastewater flows, current and projected, could limit the amount of water that is available to be reused.




Figure 3-6
Potential Recycled Water Customers

Furthermore, the recycled water demands are based on DWP's customer data base and need to be verified to determine actual potential demand. Groundwater replenishment with advanced treated DCT effluent was identified as an option requiring future analysis and public acceptance, which could use up to 36,000 acre-feet per year in the east San Fernando Valley for this purpose.

3.6 Summary

The two main water management options for the IRP include increasing levels of conservation and increasing recycled water use. Unlike the wastewater system, described in Section 2 of this document, in which the options are on an either/or basis, for water management the options build upon one another, indicating varying levels of water management. This is further detailed in Section 5 Alternatives Development and Analysis.

Section 4

Runoff Management

4.1 Introduction

The City is responsible for meeting the requirements of the various regulations pertaining to water quality and runoff management, which are discussed in Section 4.2.2. The following sections of this document serve to summarize the *Facilities Plan, Volume 3: Runoff Management*. As such, the *Facilities Plan, Volume 3: Runoff Management* should be referred to for a more detailed analysis.

4.1.1 Runoff Service Area

The City's runoff service area is comprised of portions of the following four major watershed management areas (WMAs):

- LA River (including Reaches 1, 2, 3, 4, 5, and 6)
- Ballona Creek
- Dominguez Channel
- Santa Monica Bay (the portion within the City of LA)

The Citywide land use breakdown is presented in the pie chart in Figure 4-1. As shown in Figure 4-2, portions, but not all, of the WMAs are within the City of Los Angeles' boundary. For the purposes of the IRP, facility planning was focused on runoff derived from the watershed service areas within the City of Los Angeles. However, many stormwater runoff management solutions are appropriate to implement on a watershed-wide basis. Los Angeles River WMA




Figure 4-1
Citywide Land Use



Figure 4-2
Runoff Watersheds for Los Angeles

The Los Angeles River WMA is one of the largest in the region. The Los Angeles River is 51 miles long and drains 834 square miles (533,760 acres) of watershed. Approximately 30 miles of river and 289 square miles (185,000 acres) of watershed lie within the City. Approximately 324 square miles (207,000 acres) of the watershed are covered by forest or open space land, including the area near the headwaters, which originate in the Santa Monica, Santa Susana, and San Gabriel Mountains. The remaining 510 square miles (326,500 acres) of the watershed, and approximately 231 square miles (148,000 acres) of the City portion, is highly developed

Ballona Creek/Urban Santa Monica Bay WMA

The entire Santa Monica Bay watershed, which encompasses an area of 414 square miles, is quite diverse. The WMA includes a number of watersheds; the two largest are Malibu Creek (to the north) and Ballona Creek (to the south). The remaining are smaller watersheds, some of which discharge to the bay entirely through local storm

drain systems. Only 149 square miles combined of the Ballona Creek WMA and Santa Monica Bay WMA fall within the City.

Dominguez Channel/Los Angeles Harbor WMA

The Dominguez Channel/Los Angeles Harbor WMA drains 110 square miles of watershed (LACDPW and URS Greiner Woodward Clyde, 2000), of which approximately 23 square miles of the watershed lie within the City.

4.2 Planning Parameters

The main focus of managing runoff, wherever possible, was on maximizing reuse and recycling of runoff, as recommended by the IRP guiding principles. Because the majority of the Total Maximum Daily Loads (TMDLs) were not published at the time of development, the intent of the IRP was not to ensure TMDL compliance but instead it focused on maximizing runoff management opportunities to supplement water supply needs, and in the process improve the water quality of the receiving water bodies.

4.2.1 IRP Guiding Principles

In Phase I of the IRP (the Integrated Plan for the Wastewater Program), several guiding principles were identified and were used in the preparation of the Facilities Plan. Several of the guiding principles were specific to runoff management. These guiding principles included:

- Increasing the amount of dry weather urban runoff that is diverted and treated or captured and beneficially used

The primary benefit of increased dry weather diversion will result from reduced pollution throughout the City's waterways; this, in turn, will have a major impact on the region's quality of life.

In addition, dry weather urban runoff could potentially provide additional beneficial water use opportunities. To protect all beneficial uses, the City recommends an extensive dry weather urban runoff capture and beneficial use program. The IPWP assumed that one of the requirements of any project would be that dry weather diversions would not impair the beneficial uses of other receiving waters in the Los Angeles basin.

- Increasing the amount of wet weather urban runoff that can be captured and beneficially used

By capturing and beneficially using wet weather urban runoff, the City has the opportunity to make some significant restrictions in its dependence on imported water. For this reason, both the Steering Group and the City supported capturing and beneficially using wet weather urban runoff.

- Focusing on lower-cost solutions within the framework of the policy elements noted above

Providing for improvements in, and maintenance of, wastewater, recycled water, stormwater and water services that are adequate for meeting future treatment and quality needs may require increased investments in these programs, and paying for these improvements will result in some level of increased user costs. A wide range of possible costs for future actions was indicated by the alternatives studied in the Phase I process. In fact, individual economic preferences were considered in selecting alternatives. While alternatives will require significant investments, they will also offer the added value of achieving both the level-of-service and the environmental goals that are important for the City and its residents, and they may result in economic savings over time. Nonetheless, it was possible, within the scope of the desired options and policies outlined above, to strive for the lowest cost solutions that meet performance requirements. For these reasons, the Steering Group supported the use of lower cost solutions where they were available within the framework of the other policy elements.

4.2.2 Regulatory Drivers

The primary regulatory drivers affecting the stormwater program are the issuance of National Pollutant Discharge Elimination System (NPDES) stormwater permits and the development of TMDLs. The Los Angeles County Stormwater permit requires implementation of a comprehensive stormwater program, Best Management Practices (BMPs), and TMDLs. TMDLs will limit pollutant loading to a number of impaired waters in the City, including the Los Angeles River, which is a major receiving water for both urban runoff and wastewater effluent, as well as Ballona Creek and Santa Monica Bay.

One of the specific requirements of the NPDES program is the Standard Urban Stormwater Management Plan (SUSMP), which is intended to address storm water pollution from new development and redevelopment by the private sector as well as equivalent public works projects. As adopted by the Los Angeles Regional Water Quality Control Board (RWQCB), the countywide SUSMP requires that BMPs be implemented to meet specific design standards to achieve the following goals (RWQCB, 2000b):

- Mitigation (i.e., infiltration or treatment) of storm water runoff
- Control of peak-flow discharge to provide stream channel and over-bank flood protection, based on flow design criteria selected by the local agency.

At the time of development, there were four TMDLs that had numerical limits or other quantifiable targets such as days of exceedance:

- Los Angeles River Trash TMDL

- Los Angeles River Nitrogen TMDL
- Santa Monica Bay Dry Weather Bacteria TMDL
- Santa Monica Bay Wet Weather Bacteria TMDL

4.2.3 Runoff Planning Sheds

For the IRP, the major watersheds (Los Angeles River, Ballona, Santa Monica Bay, and Dominguez Channel) were divided into smaller runoff planning sheds, resulting in 21 areas that drain to major channels or that are tributary to major receiving water bodies. These locations were considered logical points of collection as they already drain larger tributary areas and the flows can be captured at a point prior to discharge to the Los Angeles River or other water body. A map of these runoff planning sheds is included in Figure 4-4. Table 4-1 presents a summary of the acreage of these sheds. These runoff planning sheds will be used throughout this document.

4.3 Approach

The first step in developing runoff management options for the stormwater program was to evaluate the regulatory drivers and other planning parameters that pertain to runoff. The second step was to estimate the amount and the quality of both dry and wet weather runoff that will need to be managed to meet regulatory requirements and to meet any other environmental goals developed by the City. The third step was to identify existing City programs and runoff facilities and assess how they might impact future planning and needs. The information resulting from the analysis outlined above was then used to develop runoff management options that can be integrated into a Citywide stormwater program.




Figure 4-3
Runoff Management Options




Figure 4-4
Runoff Planning Sheds

Table 4-1 Summary of Runoff Planning Shed Areas				
Watershed Management Area	Runoff Planning Shed	Total Area (acres)	Portion within City of Los Angeles	
			(acres)	(Percent)
Los Angeles River	Bell Creek	17,000	11,500	68%
	Browns Creek	23,000	12,000	52%
	Aliso Wash	9,500	9,500	100%
	Wilbur Wash	5,000	4,000	80%
	Limekiln Canyon	8,000	6,000	75%
	Caballero Canyon	5,500	5,500	100%
	Bull Creek	13,500	13,500	100%
	Tujunga Wash	32,500	32,500	100%
	Pacoima Wash	143,200	28,000	20%
	Arroyo Seco	78,500	13,500	17%
	Los Angeles River Reach 3	45,000	13,900	31%
	Los Angeles River Reach 2	73,000	15,000	21%
	Burbank Western Channel	9,300	9,000	97%
	Verdugo Wash	1,000	1,000	100%
	Compton Creek	14,000	10,100	72%
	Subtotal	478,000	185,000	39%
Ballona Creek	Ballona Creek	17,000	17,000	100%
	Sepulveda Channel	67,000	50,000	75%
Santa Monica Bay	Santa Monica Bay 1	21,100	21,100	100%
	Santa Monica Bay 2	5,900	5,900	100%
	Santa Monica Bay 3	1,000	1,000	100%
Dominguez Channel	Dominguez Channel	70,000	15,000	21%
Area not Tributary to City (not in planning shed)		209,000	NA	NA
Total		869,000	295,000	
Source: City's GIS database.				

Managing the quality of runoff includes meeting the following goals:

- Address all existing TMDLs (listed above) and regulations in all alternatives (considered minimum requirements);
- Provide leadership by including additional runoff management projects with multiple benefits (e.g., on-site storage/use, or infiltration trenches), which will provide beneficial use as well as some water quality benefits;
- Develop a range of management options to meet future regulations;
- Develop an IRP Implementation Plan that will include a schedule with potential regulatory triggers to allow the City to check whether the IRP projects will satisfy compliance with new TMDLs as they are issued. Whether and how to

modify/expand the IRP plan will be detailed as part of each TMDL's Implementation Plan.

The following are the key objectives relating to managing runoff quality and quantity;

- Bacteria TMDL goals for the Santa Monica Bay for dry and wet weather which serves to eliminate or treat all dry weather flow entering the Santa Monica Bay, and that has set a numeric limit of 17 exceedance days for bacterial concentration at Santa Monica Bay beaches
- Trash TMDL goal for Ballona Creek and Los Angeles River that establishes a zero target for trash in receiving waters from all runoff
- NPDES permit goal to reduce or eliminate non-stormwater runoff flows and to reduce pollutants entering the receiving waters, which includes reducing all dry weather flows
- SUSMP goals, which is a model guidance document for use by builders, land developers, and public agencies

4.4 Dry Weather Runoff

Dry weather runoff is runoff that occurs when in the absence of rainfall. Dry weather runoff is generally associated with activities such as landscape irrigation and street washing.

To estimate the volume of dry weather runoff, the average monthly flow data from several locations throughout the WMAs during the dry months from October 1996 to September 2001 was used. At the time, this was the most recent data released by the County of Los Angeles Department of Public Works (Los Angeles County, 2002).

For the IRP, a "dry month" was defined as a month in which less than 0.25 inches of rain fell. The rainfall measured at the Los Angeles International Airport (LAX) rain gauge was used to determine which months during the study period were dry.

4.4.1 Dry Weather Runoff Volume

The following Table 4-2 summarizes the runoff rates and total estimated dry weather runoff flow for each of the watersheds. Refer to the *Facilities Plan Volume 3: Runoff Management* for the calculations and methodology associated with this data. Table 4-3 summarizes the estimated dry weather flows from each subwatershed.

Table 4-2 Runoff throughout City Based on Estimated Runoff Rates					
Watershed Management Area	Area (acres)		Runoff Rate (gpd/ac)	Flow (mgd)	
	Watershed	City		Watershed	City
Los Angeles River	533,000 (311,000 Measured Developed)	185,000 (148,000 Measured Developed)	190	59	28
Ballona Creek	84,000	67,000	230	20	16
Urban Santa Monica Bay	182,000	28,000	320	15	10
Dominguez Channel/Los Angeles Harbor	70,000	15,000	230	16	4
Total	869,000	295,000	NA	110	58

Table 4-3			
Dry Weather Flows by Runoff Planning Shed			
No.	Runoff Planning Shed		Flow (mgd)
1	Los Angeles River WMA	Bell Creek	3
2		Browns Creek	3
3		Aliso Wash	2
4		Wilbur Wash	1
5		Limekiln Canyon	2
6		Caballero Canyon	1
7		Bull Creek	2
8		Tujunga Wash	6
9		Pacoima Wash	7
10		Arroyo Seco	5
11		LA River Reach 3	4
12		LA River Reach 2	12
13		Burbank Western Channel	2
14		Verdugo Wash	0
15		Compton Creek	3
16	Ballona Creek WMA	Ballona Creek	3
17		Sepulveda Channel	16
18	Dominguez Channel WMA	Dominguez Channel	16
19	Santa Monica Bay WMA	Santa Monica Bay 1	10
20		Santa Monica Bay 2	
21		Santa Monica Bay 3	
	Total		97
Source: Calculated data based on City's GIS database and runoff rates, wet weather based on based on areas and 0.45-inch target storm, 0.47 runoff coefficient, as detailed in <i>Facilities Plan Volume 3: Runoff Management</i> .			
Note that the total 97 mgd differs from the 110 mgd presented in Table 4-2 as there are 13 mgd of flow in the LA River watershed that does not reach the City and is therefore not included here.			

4.4.2 Dry Weather Runoff Quality

The following Table 4-4 represents the runoff water quality data that was available for the IRP.

Table 4-4 Summary of Reported Dry Weather Runoff Water Quality Data								
Constituent	Unit	Ashland Storm Drain ¹	Ballona Creek ¹	Pico-Kenter Storm Drain ¹	Sepulveda Channel ¹	Sawtelle Blvd ²	Overland Overpass ³	Storm Drains ⁴
General Constituents								
pH	N/A	7.6	8.8	7.6	8.7	-	-	-
Chemical Oxygen Demand (COD)	mg/L	252	51	88	73	-	-	-
Biochemical Oxygen Demand (BOD)	mg/L	-	-	-	-	5.6	<10	-
Dissolved Oxygen (DO)	mg/L	1.6	>15	6.6	>15	-	-	-
Total Dissolved Solids (TDS)	mg/L	6,058	1,625	1,493	4,071	-	-	-
Total Suspended Solids (TSS)	mg/L	299	8	103	13	-	-	-
Volatile Suspended Solids (VSS)	mg/L	86	5	42	7	-	26	-
Dissolved Organic Compounds (DOC)	mg/L	34	9	15	16	-	-	-
Salinity	ppm	2.2	1.2	0.9	2.1	-	-	-
Alkalinity	mg/L	357	212	260	145	-	-	-
Hardness	mg/L	1,080	722	353	1,434	-	-	-
Conductivity	mu/cm	-	-	-	-	1,141	1110	-
Detergent	ppm	2.5	0.75	0.75	0.5	-	-	-
Oil and Grease	mg/L	-	-	-	-	2.2	3.5	-
Bacteria								
e.coli	mg/L	-	-	-	-	-	-	21,199
Enterococcus	(mpn/100 ml)	-	-	-	-	-	-	4,124
Fecal Coliform	(mpn/100 ml)	-	-	-	-	8,000	1,000	-
Total Coliform	(mpn/100 ml)	-	-	-	-	190,000	>1,600	79,593
Metals								
Chromium	mg/L	-	-	-	-	-	-	<0.01
Copper	mg/L	-	-	-	-	0.019	0.012	<0.01
Iron	mg/L	-	-	-	-	-	-	0.54
Lead	mg/L	-	-	-	-	0.019	<.1	<0.01
Nickel	mg/L	-	-	-	-	-	-	<0.02

Table 4-4 Summary of Reported Dry Weather Runoff Water Quality Data								
Constituent	Unit	Ashland Storm Drain ¹	Ballona Creek ¹	Pico-Kenter Storm Drain ¹	Sepulveda Channel ¹	Sawtelle Blvd ²	Overland Overpass ³	Storm Drains ⁴
Zinc	mg/L	-	-	-	-	0.061	0.02	0.01
Nutrients								
Ammonia (NH ₃)	mg/L	0.76	0.05	0.11	0.06	-	-	<0.02
Nitrate	mg/L	-	-	-	-	-	-	2.7
Total Kjeldal Nitrogen (TKN)	mg/L	-	-	-	-	-	-	1.5
Total Phosphorus (Total-P)	mg/L	-	-	-	-	-	-	0.3
Notes: 1. Southern California Coastal Water Research Project Authority (SCCWRP) 1992 - 93 Annual Report. Toxicity Identification of Dry Weather Urban Discharge. (www.sccwrp.org) 2. Ballona Creek Treatment Facility, Feasibility Study/Preliminary Design Draft Report. Sampling at the Sawtelle Blvd sampling station from 1981 to 1993. 3. Ballona Creek Treatment Facility, Feasibility Study/Preliminary Design Draft Report. Six dry weather samples collected from October to December 1993 in Ballona Creek 4. Drew Ackerman, Kenneth Schiff, Heather Trim, Mike Mullin. Characterization of Water Quality in the Los Angeles River. Sampling of storm drain outfalls into the Los Angeles River on September 10, 2000.								

4.4.3 Local/Neighborhood Solutions

Source Control Options

Source control options involve reducing or eliminating dry weather urban runoff or improving the quality of that runoff at its source. Source control options include those that reduce the amount of flow generated, those that reduce or minimize the introduction of pollutants in dry weather flow, and options that can retain both dry and wet weather flow on site. Source control options would be used in conjunction with other runoff management options.

Source control options to reduce the amount of flow generated include the following:

- Smart irrigation – the use of evapotranspiration devices that regulate when and how much irrigation is used;
- Increase public education and participation;
- Washing vehicles (i.e. not in driveways but on grassy areas or at designated carwashes);
- Sweeping instead of washing sidewalks and driveways.

Of the aforementioned source controls that reduce the amount of flow generated, the smart irrigation option has a quantifiable estimate. Based on information derived from past studies, if smart irrigation were implemented City-wide, dry weather flow could be reduced by approximately 11 mgd. However, as this is an estimate, more

detailed studies would be needed to determine the full benefits of a smart irrigation program.

Improving water quality can be done through a variety of source controls. Following is a list of some ways to improve water quality on-site:

- Eliminate littering
- Pick up pet waste
- Recycle motor oil
- Provide employee training
- Provide storm drain system stenciling & signage
- Protect trash storage areas
- Cover outdoor material handling and storage areas
- Maintain fleet vehicles
- Repair & clean maintenance bays
- Sweep parking areas, driveways, and sidewalks
- Install clarifiers/ oil-water separators
- Maintain loading docks
- Use proper waste handling and disposal methods

These methods of improving water quality were not quantified.

4.4.4 Regional Solutions

Regional solutions to managing runoff are solutions that serve to manage runoff from a regional or subwatershed wide basis. As opposed to managing or reducing the runoff at its source, these solutions serve to manage a larger amount of flow after it has been generated. Regional solutions would be used in conjunction with local solutions.

4.4.4.1 Diversion to Wastewater system

This option involves diverting dry weather runoff that has reached the storm drain system to the wastewater collection system for treatment at existing wastewater treatment plants. This option is not a viable option for wet weather runoff due to the high flow volume during storm events.

To analyze the option for managing dry weather flows, as a first step the available capacity of the existing treatment plants was reviewed. A summary of the existing flow conditions at the four treatment plants is presented in Table 4-5. It should be noted that the Burbank Water Reclamation Plant was not included in this analysis since it is not in the City's jurisdiction.

Table 4-5 Currently Available Treatment Plant Capacity				
Plant	Existing ADWF Capacity (mgd)	Current Flow (mgd)	Currently Available Capacity (mgd)	Available Capacity in 2020 (mgd)
Tillman WRP (TWRP)	64	51	13	0
Los Angeles/Glendale WRP (LAGWRP)	15	18	0	0
Hyperion Treatment Plant (HTP)	450	340	110	0
Terminal Island Treatment Plant (TITP)	30	17	13	11
Notes: 1. City of Los Angeles Monthly Performance Report for HTP, TITP, TWRP, LAGWRP. 2. TWRP and LAG ADWF capacity based on derated capacity.				

As shown previously in Table 4-3, the total watershed-wide flow to the sewersheds is 97 mgd and the total City flow to the sewersheds equals 58 mgd. Based on this information and the capacities of the wastewater treatment plants shown in Table 4-5, the City could not manage the entire flow by diverting it to the wastewater system. Therefore, for this option to be considered the treatment plants would need additional capacity.

At each of the diversion locations, the following would need to be built: temporary storage, pumping stations, diversion structures to the wastewater system or pipelines diverting the runoff directly to the treatment plant, collection piping to capture runoff prior to discharging into rivers or creeks that are 303d listed waterbodies.

4.4.4.2 Diversion to Urban Runoff Plants, Including Reuse

Another option for managing dry weather urban runoff is to capture and treat the runoff and either discharge it back to the intended receiving water to improve water quality, or divert it to a beneficial use. Used in conjunction with source controls, this option will meet current and future dry weather TMDLs.

Treatment requirements will depend upon the specific water quality objectives to be met for regulatory compliance. Potential types of contaminants generated in each planning shed were determined based on land use. Dry weather urban runoff is a significant source of several, but certainly not all, constituents

The same runoff planning sheds that were discussed in Section 4.3.2 (shown in Figure 4-4 and flows shown in Table 4-3) are utilized, with the collection points representing the locations of the treatment facilities. The target total flow that would need to be managed is 97 mgd, however since 10 mgd is already being managed by the existing coastal diversions, the City would have to treat and discharge up to 87 mgd of flow.

Treatment and Beneficial Use


For this option, treated runoff would be beneficially used rather than discharged to receiving waters. The treatment plants described above for treatment and discharge would be built, but rather than discharging the effluent back into the receiving waters, the flow would be beneficially reused. For dry weather runoff most of the runoff could potentially be diverted directly to beneficial use, particularly during the summer months when demands for non-potable water are high (due to the higher irrigation demands in the summertime).

To evaluate additional potential demand for recycled water or other non-potable sources such as urban runoff, DWP's top users were analyzed. A computer modeling analysis was performed based on the recycled water demands in the City and the available dry weather runoff.

Based on this data, the model determined which of the recycled water demands could be realistically met through treated runoff. Table 4-6 identifies the amount of this runoff that could, after treatment, be used to meet the recycled water demands. Figure 4-5 shows the locations of the potential recycle water users.

Table 4-6		
Potential Non-Potable Water Demands Met with Treated Runoff		
Service Area	Total Demand Served	
	(acre-ft/year)	(million gallon/year)
Aliso Wash	1,400	460
Canoga	3,250	1,050
Reseda	2,900	950
Tujunga / Burbank	9,050	2,950
LA River Reach 3	1,100	360
Dominguez Channel	8,500	2,770
Compton Creek	1,450	470
Ballona	10,850	3,530
Verdugo Wash	100	30
LA River/Arroyo	9,600	3,130
Total	48,200	15,700
Note: Source: Calculated data based on the recycled water model developed by the Southern California Comprehensive Water Reclamation and Reuse Study (Allocation and Distribution Model (ADM), a GIS based computer model). See <i>Facilities Plan Volume #: Water Management</i> for details on the model.		

Figure 4-5 Non-Potable Demands Near Potential Runoff Treatment Locations



Draft Runoff Alternatives

6 0 6 12 Miles



Pipelines

Features

- Brine - Existing/Future
- Reclaimed Water - Existing/Future
- Outfall/Discharge Lines - Existing/Future
- Reclaimed Water - Existing/Future
- Existing Pipelines with Available Capacity

- Major Highways
- Major Body of Water
- Major Rivers

- Supply in Analysis
- Supply Not in Analysis
- Demands Connected
- Potential Demands

In meeting these recycled water demands, facilities that would need to be constructed include: runoff diversion facilities, possibly with operating storage, treatment facilities (as in the Treatment and Discharge Option section above) treated to Title 22 standards, pipeline for collection and distribution and pumping stations.

4.4.4.3 Diversion to Wetlands

Wetlands are another type of project that may be used to implement the beneficial use option. Wetlands are considered a beneficial use as they do many things to improve the community and environment (such as restore habitat), are aesthetically pleasing, are considered a public amenity, etc.

Current empty land is the optimum place for constructing new wetlands, and open space and vacant land within the City was considered as potentially suitable areas. The approximate maximum acreage available is 2,700 acres. For planning purposes, 10 percent of the open space acreage (or approximately 300 acres) was considered as potentially suitable for development of wetlands. Typical loading rates for wetlands range from 2 to 10 cm/day (0.066 to 0.328 ft/day). The optimum loading rate depends on a variety of factors including type of wetland and flow (i.e., surface or subsurface) and would be determined on a site specific basis. Based on these values, 7,200 to 35,900 acre-ft/yr (2,350 to 11,700 MG/yr) of runoff flow could be beneficially used as wetland areas.

4.5 Wet Weather Runoff

Wet weather runoff is any runoff that occurs as a direct result of rainfall. Wet weather runoff represents a significantly larger volume of water than dry weather runoff. For this reason, it is not reasonable to expect that all wet weather flows can be managed. The wet weather runoff volume to be managed is primarily dependant on either meeting TMDLs or maximizing beneficial uses. Based on the anticipated TMDL requirements and on historical rainfall information, an average amount of runoff per storm to be captured and treated or diverted was determined.

4.5.1 Wet Weather Runoff Volume

The City of Los Angeles covers approximately 295,000 acres (465 square miles) and receives a long-term annual average rainfall of about 14.95 inches of rain per year (based on National Weather Service Data). For purposes of runoff management planning, long-term annual average precipitation and existing land use distribution were used to calculate total runoff for each of the watersheds, and assuming a 2 percent new development in by the year 2020. The long-term average annual total wet weather runoff from land within the City jurisdiction was calculated to be 174,000 acre-feet/yr.

For the purposes of IRP planning, needs were assessed and facility planning conducted for runoff generated from the City only. The management of runoff from outside the City was not evaluated as part of this effort, though during implementation in some instances, the City may partner with other jurisdictions for

finding the most appropriate solutions. Therefore managing runoff volumes depended on Citywide land use, but the watershed values were defined as well.

Estimated wet weather runoff volumes are presented in Table 4-7.

Table 4-7 Estimated Wet Weather Runoff Volume						
	City of Los Angeles				Entire Watershed	
Watershed	Area ¹ (Acres)	Average Annual Rainfall ² (acre-feet/yr)	Average Annual Runoff ³ (acre-feet/yr)	Average Annual Volume (million gallons)	Area ¹ (Acres)	Average Annual Rainfall (acre-feet/yr)
Los Angeles River	185,000	230,500	108,300	35,300	533,000	664,000
Ballona Creek	67,000	83,500	39,000	12,700	84,000	104,700
Santa Monica Bay (excl. Ballona Creek)	28,000	34,900	16,300	5,300	182,000	226,700
Dominguez Channel	15,000	18,700	8,700	2,900	70,000	87,200
Increase from Total New Development by 20204	NA	NA	2,000	NA	NA	NA
Total	295,000	367,600	174,300	56,200	869,000	1,082,600

Notes:
1 Areas from City of LA GIS database.
2 Rain gauge. rainfall = Area x 14.95 inches of rain per year, rainfall from National Weather Service Data, measured at LAX rain gauge.
3 Calculation based on a runoff coefficient of 0.47, derived from the Watershed Protection Division's Pollutant Load Model.
4 Total runoff reflects the assumed 2% new developments by 2020.

The targeted wet weather flows were determined based on an analysis of historic rainfall data and the 17 exceedence days allowed, assuming that similar requirements will be set for other watersheds, and it was determined that the 0.45 inch storm was assumed to be the “largest targeted storm” that needs to be managed in order to meet the Santa Monica Bay Bacterial TMDL. Assuming that similar requirements will be set for other emerging TMDLs, it was assumed that the 0.45 inch storm is the largest targeted storm.

Since the current requirements at the time of development only included managing the runoff from the Santa Monica Bay WMA, the requirement for managing wet weather runoff was 160 million gallons in one event. In anticipating potential regulations for wet weather runoff, the planning assumption used was to assume that similar implementation requirements to the current Santa Monica Bay TMDLs would affect the rest of the City. If these requirements were to be implemented, the City would potentially need to manage up to 5,200 acre-feet (1,700 million gallons) of runoff per event.

Estimate wet weather flows per runoff planning shed are presented in Table 4-8.

Table 4-8			
Wet Weather Flows by Runoff Planning Shed			
No.	Runoff Planning Shed		Flow (mgd)
1	Los Angeles River WMA	Bell Creek	65
2		Browns Creek	70
3		Aliso Wash	50
4		Wilbur Wash	25
5		Limekiln Canyon	35
6		Caballero Canyon	30
7		Bull Creek	75
8		Tujunga Wash	190
9		Pacoima Wash	160
10		Arroyo Seco	75
11		LA River Reach 3	80
12		LA River Reach 2	85
13		Burbank Western Channel	50
14		Verdugo Wash	5
15		Compton Creek	60
16	Ballona Creek WMA	Ballona Creek	90
17		Sepulveda Channel	285
18	Dominguez Channel WMA	Dominguez Channel	110
19	Santa Monica Bay WMA	Santa Monica Bay 1	125
20		Santa Monica Bay 2	30
21		Santa Monica Bay 3	5
	Total		1,700
Notes:			
1. Assumes all captured flow from a 0.45 inch storm event would be drained from operational storage and treated for discharge over a 24-hour period.			
Source: Calculated data based on City's GIS database and runoff rates, wet weather based on based on areas and 0.45-inch target storm, 0.47 runoff coefficient, as detailed in <i>Facilities Plan Volume 3: Runoff Management</i> .			

4.5.2 Wet Weather Runoff Quality

The following Table 4-9 represents the runoff water quality data that was available for the IRP.

Table 4-9 Water Quality Data In Ballona Creek and the Los Angeles River General Chemicals and Minerals			
Parameter	Water Quality Data		
	Units	Ballona Creek (1994 – 2000 Mean)	Los Angeles River (1994 – 2000 Mean)
General Chemicals and Minerals			
pH	N/A	7.3	7
Hardness	mg/L	103	79
Turbidity	NTU	74	127

Table 4-9
Water Quality Data In Ballona Creek and the Los Angeles River
General Chemicals and Minerals

Parameter	Water Quality Data		
	Units	Ballona Creek (1994 – 2000 Mean)	Los Angeles River (1994 – 2000 Mean)
Sulfate (SO ₄)	mg/L	39	28
Chloride	mg/L	24	16
Total suspended solids (TSS)	mg/L	191	366
Detergents (as MBAS)	mg/L	0.1	0.05
Fluoride	mg/L	0.2	0.15
Cyanide	mg/L	S.I.D.	S.I.D.
Total dissolved solids (TDS)	mg/L	199	144
Calcium	mg/L	27	23
Magnesium	mg/L	8	5.9
Potassium	mg/L	3.2	3.7
Sodium	mg/L	20	17
Bicarbonate	mg/L	67	45
Nitrate	mg/L	4.1	4.5
Alkalinity	mg/L	63	42
Chemical Oxygen Demand (COD)	mg/L	103	79
Specific Conductance	umhos/cm	317	227
Volatile Suspended Solids (VSS)	mg/L/hr	57	66
Total Organic Carbon (TOC)	mg/L	10	10
Total Petroleum Hydrocarbons (TPH)	mg/L	2.5	2.5
Oil and Grease	mg/L	3.8	2.5
Biochemical oxygen demand (BOD)	mg/L	29	26
Bacteria			
Total Coliform	MPN/100 mL	1,704,131	2,213,291
Fecal Coliform	MPN/100 mL	917,648	1,477,645
Fecal Streptococcus	MPN/100 mL	531,761	757,013
Fecal Enterococcus	MPN/100 mL	433,639	358,468
Nutrients			
Ammonia (NH ₃)	mg/L	0.53	0.56
Nitrite-N (NO ₃)	mg/L	0.14	0.15
Dissolved Phosphorus	mg/L	0.25	0.42
Total Phosphorus	mg/L	0.36	0.62
NH ₃ -N	mg/L	0.43	0.47
Nitrate-N	mg/L	0.9	0.8
Total Kjeldal Nitrogen (TKN)	mg/L	3.3	3.5
Metals			
Arsenic (As)	µg/L	S.I.D.	4
Barium (Ba)	µg/L	54	106

Table 4-9 Water Quality Data In Ballona Creek and the Los Angeles River General Chemicals and Minerals			
Parameter	Water Quality Data		
	Units	Ballona Creek (1994 – 2000 Mean)	Los Angeles River (1994 – 2000 Mean)
Cadmium (Cd)	µg/L	S.I.D.	1.9
Copper (Cu)	µg/L	22	49
Lead (Pb)	µg/L	12	109
Nickel (Ni)	µg/L	6.4	14.5
Zinc (Zn)	µg/L	136	253
Notes: Monitoring Locations: Ballona Creek-Stream Gage No. F38C-R between Sawtelle Blvd and Sepulveda Blvd in the City of Los Angeles; Los Angeles River: Stream Gage No. F319-R between Willow St. and Wardlow Rd. in the City of Long Beach. S.I.D. Statistically Invalid Data, not enough data. Only the constituents who had data available are listed in this table. Source of data: LOS ANGELES COUNTY, 1994-2000 INTEGRATED, RECEIVING WATER IMPACTS REPORT, found at: http://ladpw.org/wmd/NPDES/Int_report/Tables/Table_4-5a.pdf			

4.5.3 Local/Neighborhood Solutions

Several options that are designed to provide source control of wet weather urban runoff will also impact dry weather urban runoff. While these options would be designed to manage the higher wet weather flows, once they are in place they would be able to manage dry weather flows as well.

4.5.3.1 New/Redevelopment Areas - Onsite treatment/discharge

An option identified for onsite treatment and discharge is a bioretention area. In this option, runoff is directed into shallow landscaped depressions, and these depressions and the surrounding areas are designed to provide onsite treatment, incorporating many of the pollutant removal mechanisms that operate in forested ecosystems.

4.5.3.2 New/Redevelopment Areas - On-site percolation

The following three BMPs require soils that allow for infiltration:


- Retention Grading - a "sunken garden" that holds runoff and rainwater until it can be absorbed into the ground;
- Driveway Dry Well - involve adding a grate at the end of the driveway designed to capture and store stormwater until the water percolates into the subsurface soils, essentially acting as a small dry pond;
- Porous Pavement - Porous pavement is a special type of material used to allow water to pass through while being strong enough to support vehicular traffic.

Based on the City's GIS database, an analysis of historic rainfall data and average water use information, an estimate of the amount of runoff that could be managed by these onsite capture and treatment options was determined for various land uses in the east San Fernando Valley. These values are presented in Table 4-10. Figure 4-6 shows the areas in the City where soils are "good" for infiltration (i.e. optimal for implementing infiltration options), "fair" or "poor" for infiltration. As shown, only the east San Fernando Valley was targeted for this study, as only the soils in this area are optimal for infiltration.

4.5.3.3 Retrofit Areas - Cisterns

Rain Barrels and Cisterns - Rain barrels and cisterns are low-cost water conservation devices that can be used to reduce runoff volume and, for smaller storm events, delay and reduce the peak runoff flow rates. They store and divert runoff from impervious roof areas. This stored runoff can provide a source of chemically untreated 'soft water' for gardens and compost, free of most sediment and dissolved salts.

Cisterns were analyzed to determine the amount of runoff that could be managed. Cisterns store and divert runoff from impervious roof areas. The cistern analysis consisted of estimating the potential runoff volume reduction and potable water savings by irrigating residential landscaping with captured storm water for cistern systems ranging in size from 60 to 10,000 gallons. In addition, the size of a system to capture and use all of the captured rainwater over a selected 11-year historical rainfall period was determined. The effect of installing cisterns on all residences in the City to manage runoff from the design storm (0.45 inches) was also analyzed. Of the estimated 1,700 million gallons of runoff from a 0.45-inch storm, approximately 440 million gallons could be captured in cisterns, assuming 1,000-gallon cisterns are installed to capture runoff from the roofs of all single and multi-family residences. While this provides a substantial amount of water conservation and can significantly reduce the amount of runoff to be managed in the storm drain system, it is not a reliable method by itself for meeting TMDL requirements since the cisterns may be full at the start of the storm.



**Figure 4-6
Soils Map**

Table 4-10 Wet Weather Runoff Managed by On-Site Percolation		
Land Use	Runoff Generated Citywide	Runoff Managed in East Valley
Residential	123 mgd	26 mgd
Commercial	185 mgd	39 mgd
Government Facilities	4 mgd	1 mgd
Schools	15 mgd	3 mgd
Recreational Areas and Cemeteries	5 mgd	1 mgd
Total	332 mgd	71 mgd

4.5.3.4 Retrofit Areas – Onsite Percolation

Onsite percolation at retrofit areas are the same as those discussed above in Section 4.5.3.2 for onsite percolation at the new and redevelopment areas.

4.5.3.5 Neighborhood Recharge

Another method of managing runoff at the source is neighborhood recharge. Neighborhood recharge involves installing recharge facilities in portions of vacant urban lots, abandoned alleys, and City parklands, where the soil is highly permeable. This option involves installing underground storage, such as a honeycomb shaped device that allows the runoff to be stored underground, while still maintaining a safe area above ground for human activity. Again only the east San Fernando Valley was assumed to be suitable for neighborhood recharge. Based on known infiltration rates, land use and flow from the 0.45 inch storm, it was determined that the entire 500 million gallons of flow from the east San Fernando Valley could be managed by neighborhood recharge.

4.5.4 Regional Solutions

Regional solutions to managing runoff are solutions that serve to manage runoff from a regional or subwatershed wide basis. As opposed to managing or reducing the runoff at its source, these solutions serve to manage a larger amount of flow after it has been generated. Regional solutions would be used in conjunction with local solutions.

4.5.4.1 Non-Urban Regional Recharge

This option considered regional recharge of captured dry and wet weather runoff to groundwater storage in basins from which the City receives water. The regional recharge option focused on large scale projects to capture and infiltrate runoff from large areas within the City. As such, regional recharge is primarily a viable option for managing wet weather runoff. However, if the facilities were in place to manage wet weather runoff, the same facilities could be used for dry weather runoff as well.

As protection of groundwater quality is of paramount importance, runoff source quality, including considerations of pre-treatment, plays a key role in determining options.

Basin Characteristics and Potential Locations

In order to consider groundwater recharge as an option for beneficial use of runoff, appropriate locations with adequate capacity for infiltrating the runoff into local groundwater basins were identified.

Based on available storage information from the document *Groundwater and Surface Water in Southern California, A Guide to Conjunctive Use* (Published by the Association of Groundwater Agencies), as well as geology within the basins, it was determined that the basin in the eastern part of the San Fernando Valley is the only basin suitable for groundwater infiltration. Here, the soil is sandy with a deep groundwater level, which is optimal for infiltration, as discussed in Section 4.5.3.2, and shown in Figure 4-6, the areas in the City where soils are “good” for infiltration (i.e. optimal for implementing infiltration options), “fair” or “poor” for infiltration.

Based on these basin characteristics, the IRP primarily looked at regional recharge options within the east San Fernando Valley Basin only, with the possibility of also transporting flows from the west San Fernando Valley to the basins in the east.

For wet weather runoff, the total runoff generated in the Valley from a 0.45 inch storm event is 4,000 acre-feet (1,300 million gallons) watershed-wide, and 2,900 acre-feet (750 million gallons) for the City only. This amount could potentially all be diverted to the groundwater basins in the East Valley. Additionally, since dry weather flows are less than the flow from the 0.45 inch storm, the spreading grounds could manage all of the dry weather flow. However, the water quality of dry weather flow would need to be addressed prior to diverting any flow to the basins.

These amounts account for the runoff from the 0.45-inch storm only. As this represents approximately 25 percent of the total annual runoff generated in the City, there is a great deal more runoff available to recharge. Once the capture, storage, and diversion facilities are in place, flows from storms that exceed 0.45 inches can be diverted as well.

Considerations for Regional Recharge

The regional recharge option includes using existing regional spreading grounds such as Hansen, Pacoima, or a new constructed facility. Discussions with DWP has determined several challenges to this use including the following: the necessity of seasonal storage because the spreading grounds are currently being used during storm events, the possibility of seasonal storage at several gravel pits, and the necessity of ensuring that only high quality water is infiltrated to the groundwater.

4.5.4.2 Treatment and Discharge or Beneficial Use

4.5.4.2.1 Treatment and Discharge

Under this option, runoff from the target storm event (up to 160 mgd to meet the current requirement at the time of development) would be diverted, held in temporary operational storage, treated and discharged. For example, for the adopted bacteria TMDL, three conceptual treatment plants were identified along the coast,

which are shown in Figure 4-4 and listed in Table 4-11, with operational storage up to the volume of runoff in one day. The flow to each of these treatment plants is shown in Table 4-11.

Table 4-11 Proposed Coastal Treatment Plants	
Proposed Treatment Facility	Volume of Runoff in One Day (million gallons)
Santa Monica Bay 1	125
Santa Monica Bay 2	30
Santa Monica Bay 3	5
Note: Source: Calculated based on City GIS data and runoff rate (see Section 4).	

In order to divert the flows to a treatment and discharge facility, the runoff would have to be captured and a collection system installed, then possibly pumped to the facility, and treated. Treatment considerations will depend upon the target constituents. Additionally, storage equal to at least the daily volume would need to be provided. The plant would need to be designed to treat that volume in one day in order to be prepared for another storm event the following day.

Meeting Potential Future Requirements

To meet potential future regulations using treatment and discharge as the option, up to 21 diversion and treatment plants would be needed. These treatment plants could be located at the same diversion points shown in Figure 4-4. Table 4-8 identifies the potential design flow rate for each of these treatment plants. Each plant would also need operational storage equal to the amount of runoff generated in one day. A collection system and pumping stations would also be required.

4.5.4.2.2 Treatment and Beneficial Use

For this option, treated runoff would be beneficially used instead of discharged to receiving waters. Basically, the same treatment plants described in the previous section for treatment and discharge would be built, but rather than discharging the effluent back into the receiving waters, the flow would be beneficially reused.

For the Santa Monica Bay watershed, the design flows indicated in Table 4-11 could be met through treatment and beneficial use. The volume would require seasonal storage up to the amount of runoff flow in one day.

Seasonal Storage for Beneficial Use

When addressing the potential future requirements throughout the City, identifying storage possibilities is the controlling factor. The total wet weather volume for the entire City that would need to be managed in order to meet potential TMDL implementation requirements is 43,000 acre-feet/yr (14,000 million gallons annually).

The ability to beneficially use wet weather runoff will greatly depend on the seasonal storage capacity, since the primary beneficial use of runoff is to meet irrigation

demands. Since these demands are typically non-existent during rain events and low throughout the rainy season, the wet weather runoff would need to be stored until the demand exists.

There are two ways to store wet weather runoff throughout the City the first is a regional approach and the second is a more localized approach.

A regional approach would include the use of out-of-service reservoirs for seasonal storage. Conversion of the out-of-service Chatsworth Reservoir is one option for storing the wet weather runoff. The total volume available in the Chatsworth Reservoir is 10,600 acre-feet (3,500 million gallons). Assuming that the reservoir has an available operating capacity of 50 percent, there is the potential to store approximately 5,300 acre-feet (1,750 million gallons). This leaves up to 32,400 acre-feet (12,250 million gallons) that would need to be stored elsewhere. Using the Chatsworth Reservoir would require that runoff be diverted to it, which would require a collection system, pumping stations, and treatment either before storage or before the beneficial use. Additionally, the Chatsworth Reservoir was taken out of service due to seismic concerns and significant structural improvements and studies would be needed in order to make it useable.

A more localized approach to seasonal storage would be to construct distributed underground storage facilities, locally located in open spaces, parks, schools, etc. throughout the City, as summarized in Table 4-12. There are several types of underground storage facilities that can be considered, including modular storage media which is a honeycomb-like box that is installed underground.

Table 4-12 Underground Storage Potential throughout the City		
Open space	Acres (acres)	Potential Storage Volume¹ (million gallons)
Schools (assume only ~ 25 percent suitable land)	6,000	15,000
Alleys	1,500	4,000
Total	900 count	Unknown
	7,500	19,000
Note: 1. Assuming 2.44 million gallons of storage per acre of land (based on modular storage media, 8-ft deep. Source: SCAG land use data; storage volume based on area and 8-feet of depth.		

Based on these values, the City theoretically has the potential to store the entire volume of wet weather runoff in order to meet the potential future regulations if the Chatsworth Reservoir as well as the underground storage options were utilized. This stored water could then draw down and be beneficially used during the dry weather months. Ways of beneficially reusing wet weather runoff are similar to those discussed for dry weather runoff.

4.6 Summary

There are five main categories of runoff management options for the IRP including: source controls, diversion to the sewer system, treatment and discharge, direct beneficial use and regional recharge. Unlike the wastewater system, described in Section 2 of this document, in which the options are on an either/or basis, for runoff management the options build upon one another and can be combined in various ways, indicating varying levels of runoff management. This is further detailed in Section 5, Alternatives Development and Analysis.

Section 5

Alternatives Development and Analysis

5.1 Approach for Developing and Evaluating Alternatives

The approach to developing and evaluating alternatives took into account the integration of options from each of the service functions (i.e., wastewater, recycled water and runoff). This section summarizes the approach used to create alternatives, evaluate them using criteria developed by the IRP stakeholders, revise them based on the evaluation and ultimately recommend a short list to continue through the environmental analysis. A complete description of the steps taken is described in the *Facilities Plan Volume 4: Alternatives Development and Analysis*.

Figure 5-1 illustrates the steps that were taken to identify the final alternatives.




Figure 5-1
IRP Alternatives Analysis Process Chart

5.2 IRP Objectives, Sub-Objectives and Performance Measures

An essential role of the Steering Group during the first phase of the IRP was to determine the objectives for the planning process. These objectives provided the framework for developing and evaluating alternatives, and they were eventually reflected in the IRP Guiding Principles. This section will summarize IRP objectives and performance measures, which combined constitute the evaluation criteria used to analyze alternatives.

The following terms will be used throughout this document in describing the alternatives and their performance:

- **Objectives:** The goals that define the essential purposes of the IRP in broad, overarching terms. The objectives can be seen as a set of goals that answer the question: *Why* do we want to have a wastewater program in place? The primary IRP objectives are shown in Figure 5-2.




Figure 5-2
IRP Primary Objectives

- **Guiding Principles:** The instructions or guidelines for building alternatives. These guiding principles were developed during Phase I of the IRP.
- **Alternatives:** The means of accomplishing the stated IRP Objectives, which include options for each service function. The alternatives answer the question: *How* are we meeting the desired objectives?
- **Performance Measures:** The quantifiable indicators or indices of how an alternative performs relative to the objectives. Performance measures answer the question: *How well* does an alternative meet the desired objectives?

Table 5-1 presents the complete list of objectives, sub-objectives and performance measures.

5.3 Preliminary Alternatives

Preliminary alternatives were designed as integrated solutions that will meet the objectives and guiding principles generated from the Integrated Plan for the Wastewater Program (IPWP). The preliminary alternatives were each constructed with a clear emphasis on a particular focus (i.e., high adaptability, water resources, etc). A summary of the alternatives can be found in Table 5-2, the “Rainbow Chart” for the preliminary alternatives. The following represents the different focuses or themes on which these alternatives were configured:

**Table 5-1
Objectives, Sub-objectives and Performance Measures for the IRP**

Objectives and Sub-objectives		Performance Measures
1 Protect Health and Safety of Public		
1.1 Comply with all regulations protecting the public health		Alternative complies with all current and proposed regulations (YES/NO)
1.2 Provide for the safe use of recycled water		Alternative complies with all current and proposed Department of Health regulations (Y/N)
1.3 Provide adequate wastewater collection system capacity		Alternative meets current and proposed regulations for groundwater recharge (Y/N/NA)
1.4 Protect public from environmental health hazards related to water		Alternative provides for adequate wastewater collection capacity (Y/N)
1.5 Maximize system reliability		Amount of runoff managed
2 Effectively Manage System Capacity		
2.1 Provide for adequate wastewater treatment and discharge		Alternative provides security measures and redundancy to reduce vulnerability (Yes/NO)
2.2 Enhance the efficient use of system assets		Alternative provides for adequate wastewater treatment capacity (Y/N)
		Miles of additional pipelines (and their diameter) required for appropriate conveyance
3 Protect the Environment		
3.1 Comply with all regulations protecting the environment		Additional process area required for wastewater treatment
3.2 Protect the ocean, beaches and watersheds and their associated beneficial uses		Alternative complies with all current and proposed regulations (YES/NO)
		Reduction in pollutant loading to receiving waters due to urban runoff
		Dry weather urban runoff managed
3.3 Properly manage biosolids		Percent biosolids reused
3.4 Enhance the efficient use of natural resources and promote water self-sufficiency (conservation, recycling, beneficial use of stormwater)		Potable water demand reduced through conservation programs
		Urban runoff beneficially used
3.5 Promote water self-sufficiency		Amount of effluent recycled
		Savings from reductions in imported water - Accounted for in 3.4
3.6 Protect Air Quality		Total net energy use
4 Enhance Cost Efficiency		
4.1 Provide services cost effectively		Present Value cost of alternative
		Rate impact of alternative (to be determined in Financial Plan)
4.2 Allocate costs equitably		Costs paid balance the benefits accrued (YES/NO)
4.3 Maximize external funding opportunities		Potential for external funding (Low/mid/high)
5 Protect Quality of Life		
5.1 Promote environmental justice		Potential impacts to low income and minority communities
5.2 Maximize economic benefits to Los Angeles		Number of jobs created
5.3 Comply with EIR/EIS Requirements		Impacts to water quality, air quality, noise, and traffic due to construction/operations of alternative (to be measured in EIR)
5.4 Enhance public lands where possible		Potential positive impacts on public lands due to implementation of alternative (total acres of beneficial projects associated with the alternative)
6 Promote Education		
6.1 Provide education on the benefits of recycled water		All alternatives should include appropriate education and outreach
6.2 Provide outreach on technology and operations		All alternatives should include appropriate education and outreach
6.3 Provide education on stormwater issues		All alternatives should include appropriate education and outreach

Note: Sub-Objectives in BOLD represent those expected to vary from alternative to alternative.

- **Low cost/minimum requirements:** Alternative includes lower cost solutions to meet minimum requirements
- **High beneficial use of water resources:** Alternatives offer higher levels of water recycling, conservation and beneficial use of runoff to reduce imported water supplies
- **High adaptability :** Alternatives provide adaptability to respond to changing conditions (e.g., changing flows, technology, or regulations)
- **More decentralized:** Alternative includes more and smaller local projects rather than fewer and larger regional projects.
- **Lower risk:** Alternatives offer relatively lower risk from either regulatory or from an ease-of-implementation perspective. Because these two definitions can be contradictory, several different low risk alternatives were created.

5.3.1 Evaluation of Preliminary Alternatives

The alternatives analysis approach required a decision model to process the complex technical information and to synthesize it according to the objectives and preferences of each Steering Group member that participated in the surveys. Decision modeling is a tool used to aid in selecting one or more preferred alternatives - a process that rapidly increases in complexity as the numbers of alternatives, evaluation criteria, and stakeholders increase. Figure 5-3 represents the steps involved in the decision modeling process.




Figure 5-3
Decision Modeling

5.4 Hybrid Alternatives

To create the hybrid alternatives, the team sought feedback from the Steering Group and identified key concepts to carry forward. The goal was to create alternatives that combined the best elements of the preliminary alternatives, thereby allowing them to perform better than the original preliminary alternatives.

Table 5-2
City of Los Angeles
Integrated Resources Plan (IRP) - Preliminary Alternatives Matrix

		Low Cost/Min. Requirements (LCMR)		High Beneficial Use of Water Resources (WR)					High Adaptability (HA)		More De-centralized (MD)		Low Risk (LR)	
Option		LCMR	WR1a	WR1b	WR2a	WR2b	WR3a	WR3b	HA1	HA2	MD		LR1	LR2
Wastewater Treatment														
Tillman - Upgrade treatment (64 mgd) (Advanced Treatment)		64 mgd					64 mgd	64 mgd			64 mgd		64 mgd	64 mgd
Tillman - Upgrade and increase capacity to 80 mgd (Advanced Treatment)									80 mgd					
Tillman - Upgrade and increase capacity to 100 mgd (Advanced Treatment)					100 mgd	100 mgd								
Tillman - Upgrade and increase capacity to 120 mgd (Advanced Treatment)			120 mgd	120 mgd						120 mgd				
Los Angeles-Glendale - Maintain existing capacity (15 mgd) (Title 22)		15 mgd									15 mgd			15 mgd
Los Angeles-Glendale - Increase capacity to 20 mgd (Title 22)			20 mgd	20 mgd	20 mgd	20 mgd								
Los Angeles-Glendale - Increase capacity to 30 mgd (Title 22)							30 mgd	30 mgd						
Los Angeles-Glendale - Upgrade treatment (15 mgd) (Advanced Treatment)													15 mgd	
Los Angeles-Glendale - Upgrade and increase capacity to 30 mgd (Advanced Treatment)									30 mgd	30 mgd				
New Reclamation Plant - Build 10 mgd capacity near downtown (Title 22)					10 mgd	10 mgd								
New Reclamation Plant - Build 30 mgd capacity in valley (Title 22)							30 mgd	30 mgd						
New Reclamation Plant - Build 10 mgd capacity near downtown (Advanced Treatment)											10 mgd			
New Reclamation Plant - Build 30 mgd capacity in valley (Advanced Treatment)											30 mgd			
Hyperion - Maintain existing capacity (450 mgd)			450 mgd	450 mgd	450 mgd	450 mgd			450 mgd	450 mgd	450 mgd			
Hyperion - Increase capacity to 500 mgd		500 mgd					500 mgd	500 mgd						500 mgd
Hyperion - Increase capacity to 550 mgd													550 mgd	
Terminal Island - Maintain existing capacity (30 mgd)		30 mgd	30 mgd	30 mgd	30 mgd	30 mgd	30 mgd	30 mgd	30 mgd	30 mgd	30 mgd		30 mgd	30 mgd
Wastewater Sewer System														
Build new interceptor sewer - Valley Spring Lane Interceptor Sewer		X	X	X	X	X	X	X			X		X	X
Build new interceptor sewer - Glendale Burbank Interceptor Sewer (GBIS)		X	X	X	X	X	X	X	X	X	X		X	X
Build new interceptor sewer - North East Interceptor Sewer (NEIS) Phase 2		X	X	X	X	X	X	X	X	X	X		X	X
Build new interceptor sewer - for New Plant (10 mgd - 2 miles)					X	X					X			
Build new interceptor sewer - for New Plant (30 mgd - 2 miles)							X	X			X			
Build new buried storage tank - 60 MG at Tillman									X	X				
Build new buried storage tank - 20 MG at Los-Angeles Glendale			X*	X*	X*	X*	X*	X*	X*	X*	X*			
Build new buried storage tank - 10 MG at new plant					X*	X*					X*			
Build new buried storage tank - 20 MG at new plant							X*	X*			X*			
Recycled Water (Non-Potable Demands)														
Meet Los Angeles River minimum requirements using treated wastewater		X	X	X	X	X	X	X	X	X	X		X	X
Meet Irrigation/Industry demands using treated wastewater (low/medium/high)		Low	High	Medium	High	High	High	High	Low	Low	Medium		Low	Low
Recharge groundwater basin using treated wastewater				High										
Meet Irrigation/Industry demands using treated runoff (low/medium/high)						Low		Low						
Recharge groundwater basin using treated runoff			High	High	High	High	High	High						
Conservation Programs														
Increase conservation efforts to DWP's planned 2020 levels		X	X	X	X	X	X	X	X	X	X		X	X
Increase conservation efforts further			X	X	X	X	X	X	X	X	X			
Dry Weather Urban Runoff														
Local/Neighborhood Solutions														
Smart Irrigation			X	X	X	X	X	X	X	X	X			
Increase public education and participation		X	X	X	X	X	X	X	X	X	X		X	X
Regional Solutions														
Diversion to Wastewater System (WW) or Divert to Urban Runoff Plant or wetlands and Beneficially Use (URP) ¹														
Divert - coastal (10 mgd)		WW	WW	WW	WW	WW	WW	WW	WW	WW	WW		WW	WW
Divert - inland (Bell Creek 2.8 mgd)			WW	WW		URP		URP					WW	
Divert - inland (Browns Creek 3 mgd)			WW	WW		URP		URP					WW	WW
Divert - inland (Aliso Wash 1.8 mgd)			WW	WW									WW	
Divert - inland (Wilbur Wash 1 mgd)						URP		URP					WW	WW
Divert - inland (Limekiln Canyon 1.5 mgd)						URP		URP					WW	WW
Divert - inland (Caballero Canyon 1mgd)			WW	WW									WW	WW
Divert - inland (Bull Creek 2.4 mgd)			WW	WW									WW	WW
Divert - inland (Tujunga Wash 6 mgd)													WW	
Divert - inland (Pacoima Wash 7 mgd)													WW	WW
Divert - inland (Arroyo Seco 5 mgd)													WW	
Divert - inland (Reach 3 LAR 4 mgd)													WW	
Divert - inland (Reach 2 LAR-12 mgd)													WW	
Divert - inland (Burbank Western Channel 1.8 mgd)													WW	
Divert - inland (Compton Creek 2.6 mgd)						URP		URP					WW	
Divert - inland (Ballona Creek 3.3 mgd)						URP		URP					WW	
Divert - inland (Sepulveda Channel 16 mgd)													WW	
Divert - inland (Dominguez Channel 16 mgd)													WW	
Percent of Dry Weather Runoff Managed (of watershed - 97 mgd)		10%	30%	30%	21%	28%	21%	28%	21%	21%	21%		100%	20%
Wet Weather Urban Runoff														
Local/Neighborhood Solutions														
New/Redevelopment Areas - On-site treatment/discharge		X	X	X	X	X	X	X	X	X	X		X	X
New/Redevelopment Areas - On-site percolation		X	X	X	X	X	X	X	X	X	X		X	X
Retrofit Areas - Cisterns (On-site storage/use)														
Residential (Low/Medium/High)			Low	Low	High	High	High	High			High			
Schools (Low/Medium/High)			Low	Low	High	High	High	High			High		High	
Government (Low/Medium/High)			Low	Low	High	High	High	High			High		High	
On-site percolation (infiltration trenches/basins, reduce paving/hardscape)														
Residential			X	X	X	X	X	X			X			
Schools			X	X	X	X	X	X			X			X
Government			X	X	X	X	X	X			X			X
Commercial			X	X	X	X	X	X			X			
Rec/Cemetaries			X	X	X	X	X	X			X			X
Neighborhood recharge														
Vacant Lots (East Valley) (Low/Medium/High)			Medium	Medium	Low	Low	Low	Low	High	High	Low			High
Parks/Open Space (East Valley) (Low/Medium/High)			Medium	Medium	Low	Low	Low	Low	High	High	Low			High
Abandoned Alleys (East Valley) (Low/Medium/High)			Medium	Medium	Low	Low	Low	Low	High	High	Low			High
Regional Solutions														
Non-urban regional recharge			X	X	X	X	X	X						
Runoff treatment and beneficial use/discharge														
Treat and benefical use/discharge (coastal area)		X	X	X	X	X	X	X	X	X	X		X	X
Treat and benefical use/discharge (all areas)													X	
Percent of Representative storm (1/2-inch) managed (of citywide 1,700 mgd)		10%	48%	48%	58%	58%	58%	58%	39%	39%	55%		100%	42%
Current/Anticipated Regulations Level of Compliance														
California Toxics Rule		Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes		Yes	Yes
Current Total Maximum Daily Loads (TMDLs) - Bacteria (Santa Monica Bay), Trash		Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes		Yes	Yes
Future Total Maximum Daily Loads (projection)		No	Partial	Partial	Partial	Partial	Partial	Partial	Partial	Partial	Partial		Yes	Partial
Notes:														
*Storage for daily (diurnal) peaks														
¹ Flows indicated assume no smart irrigation. Implementing smart irrigation citywide would reduce total dry weather runoff estimates by ~11 mgd														
Definitions of areas of focus:														
Low Cost/Minimum Requirements: alternative includes lower cost solutions or low initial investment by meeting minimum requirements.														
High Beneficial Use of Water Resources: alternatives that include high levels of recycled water, conservation, and beneficial use of runoff that reduces use of imported water.														
High Adaptability: alternatives that are most able to adjust to changing conditions, such as population, wastewater flows and regulations.														
More Decentralized: alternatives with solutions based on many small-scale projects centered on small neighborhoods, households or even individuals, rather than fewer and larger regional projects.														
Lower Risk: alternatives that are lower in risk from a regulatory perspective (LR1) or in terms of ease of implementation from a technical, environmental and/or political and public acceptance perspective (LR2).														

Wastewater Story

The following were identified as key concepts for the wastewater system:

- Need more treatment capacity due to increased flows and runoff management
- Do not need a brand new plant, it is more cost effective and less disruptive to add treatment capacity at the existing plants
- Adding capacity of existing facilities (e.g., Tillman, LAG or Hyperion) has tradeoffs such as costs and flexibility

Based on these concepts, the hybrid alternatives built on three series of wastewater treatment combinations:

- 1) Expand Hyperion to 500 mgd and upgrade Tillman to advanced treatment
- 2) Expand Tillman to 80 mgd and LAG to 30 mgd (and upgrade both to advanced treatment)
- 3) Expand Tillman to 100 mgd (advanced)

Figure 5-4 shows the three wastewater combinations.

For each of the wastewater combinations, the same collection system components are included. These are described below:

- Build new Glendale Burbank Interceptor Sewer (GBIS)
- Build new North East Interceptor Sewer (NEIS) Phase 2
- Build a new 60 million gallon (MG) buried wet weather storage tank with real-time control at Tillman and/or construction of the Valley Spring Lane Interceptor Sewer (VSLIS)
- The NEIS Phase 2 project is included in the City's baseline CIP, however, the odor control portion of this project will be identified as part of the IRP.

Water Management Story

For the water components, the following were identified as key concepts that were important to the Steering Group member, staff, and the technical team:



Figure 5-4
Wastewater Components in Hybrid Alternatives

- Increase levels of conservation
- Increase recycled water use
- Beneficially use runoff
- Balance costs

Based on these concepts, a series of options for meeting the water management needs were defined. While for the wastewater system each of the three options were on an either/or basis, for the water management, these three options built upon one another, indicating varying levels of water management. These include three levels of recycled water, dry weather runoff and wet weather runoff options:

- A - Meet minimum (current) regulatory requirements with coastal diversions and treatment; meeting DWP's currently planned recycled water program.

- B –Provide additional benefits: in addition to the previous task, add smart irrigation and some urban runoff reuse plants for dry weather runoff, add some neighborhood recharge for wet weather runoff, and add additional recycled water.
- C –Provide more benefits: in addition to the previous tasks, add additional urban runoff reuse plants and/or wetland treatment for dry weather runoff, add cisterns and regional recharge for wet weather and add higher levels of recycled water.

Based on these criteria, a set of nine hybrid alternative were developed, as detailed in Table 5-3 below, the “Rainbow Chart” for hybrid alternatives.

5.4.1 Evaluation of Hybrid Alternatives

To evaluate the hybrid alternatives, the team used a simpler method to evaluate the hybrid alternatives. The team used a quadrant analysis method to evaluate the costs and benefits of the alternatives. The concept of the quadrant analysis is to use a grid to plot the benefits and costs of each alternative. The complete quadrant analysis can be found in the *Facilities Plan Volume 4: Alternatives Development and Analysis*.

In summary, the alternatives performed:

- Alternative Hyb3C (clear winner for wastewater, recycled water and wet weather runoff)
- Alternative Hyb1C (clear winner for both dry and wet weather runoff, and possible second choice for wastewater and recycled water)
- Alternative Hyb2C (clear winner for wet weather runoff and recycled water)
- Alternative Hyb3B (clear winner for wastewater, and possible second choice for recycled water)

5.5 Recommended Draft Alternatives for Environmental Analysis

Using preference information from the IRP Steering Group (see Section 7), the following draft alternatives were recommended to continue through the environmental impact analysis and financial analysis:

- Alternative 1 (Hyb1C): Hyperion Expansion with moderate potential for water resources projects
- Alternative 2 (Hyb2C): Tillman and Los Angeles Glendale Water Reclamation Plant expansions with high potential for water resources projects
- Alternative 3 (Hyb3B): Tillman expansion with moderate potential for water resources projects

Table 5-3 City of Los Angeles
Integrated Resources Plan (IRP) - Hybrid Alternatives Matrix

1	Option	LCMR	WR3a	HA1	LR1	Hyb1A	Hyb1B	Hyb1C	Hyb2A	Hyb2B	Hyb2C	Hyb3A	Hyb3B	Hyb3C
2	Wastewater Treatment													
3	Tillman - Upgrade treatment (64 mgd) (Advanced Treatment)	64 mgd	64 mgd		64 mgd	64 mgd	64 mgd	64 mgd						
4	Tillman - Upgrade and increase capacity to 80 mgd (Advanced Treatment)			80 mgd					80 mgd	80 mgd	80 mgd			
5	Tillman - Upgrade and increase capacity to 100 mgd (Advanced Treatment)											100 mgd	100 mgd	100 mgd
6	Tillman - Upgrade and increase capacity to 120 mgd (Advanced Treatment)													
7	Los Angeles-Glendale - Maintain existing capacity (15 mgd) (Title 22)	15 mgd				15 mgd	15 mgd	15 mgd				15 mgd	15 mgd	15 mgd
8	Los Angeles-Glendale - Increase capacity to 20 mgd (Title 22)													
9	Los Angeles-Glendale - Increase capacity to 30 mgd (Title 22)		30 mgd											
10	Los Angeles-Glendale - Upgrade treatment (15 mgd) (Advanced Treatment)				15 mgd									
12	Los Angeles-Glendale - Upgrade and increase capacity to 30 mgd (Advanced Treatment)			30 mgd					30 mgd	30 mgd	30 mgd			
13	New Reclamation Plant - Build 10 mgd capacity near downtown (Title 22)													
14	New Reclamation Plant - Build 30 mgd capacity in valley (Title 22)		30 mgd											
15	New Reclamation Plant - Build 10 mgd capacity near downtown (Advanced Treatment)													
16	New Reclamation Plant - Build 30 mgd capacity in valley (Advanced Treatment)													
17	Hyperion - Maintain existing capacity (450 mgd)			450 mgd					450 mgd	450 mgd	450 mgd	450 mgd	450 mgd	450 mgd
18	Hyperion - Increase capacity to 500 mgd	500 mgd	500 mgd			500 mgd	500 mgd	500 mgd						
19	Hyperion - Increase capacity to 550 mgd				550 mgd									
20	Total Effective Hyperion Service Area Treatment Capacity ² (mgd)	546	546	529	607	546	546	546	529	529	529	521	521	521
21	Terminal Island - Maintain existing capacity (30 mgd)	30 mgd	30 mgd	30 mgd	30 mgd	30 mgd	30 mgd	30 mgd	30 mgd	30 mgd	30 mgd	30 mgd	30 mgd	30 mgd
22	Wastewater Sewer System													
23	Build new interceptor sewer - Valley Spring Lane Interceptor Sewer	X	X		X									
24	Build new interceptor sewer - Glendale Burbank Interceptor Sewer (GBIS)	X	X	X	X	X	X	X	X	X	X	X	X	X
25	Build new interceptor sewer - North East Interceptor Sewer (NEIS) Phase 2	X	X	X	X	X	X	X	X	X	X	X	X	X
26	Build new interceptor sewer - for New Plant (10 mgd - 2 miles)													
27	Build new interceptor sewer - for New Plant (30 mgd - 2 miles)		X											
28	Build new buried storage tank - 60 MG at Tillman ³			X		X	X	X	X	X	X	X	X	X
	Build new buried storage tank - 10 MG at Los-Angeles Glendale					X*	X*	X*	X*	X*	X*	X*	X*	X*
29	Build new buried storage tank - 20 MG at Los-Angeles Glendale		X*	X*										
30	Build new buried storage tank - 10 MG at new plant													
31	Build new buried storage tank - 20 MG at new plant		X*											
32	Recycled Water (Non-Potable Demands)													
33	Meet Los Angeles River minimum requirements using treated wastewater	X	X	X	X	X	X	X	X	X	X	X	X	X
34	Meet Irrigation/Industry demands using treated wastewater	X	X	X	Low	X	X	X	X	X	X	X	X	X
37	Recharge groundwater basin using treated wastewater													
39	Meet Irrigation/Industry demands using treated runoff (low/medium/high)						Low	Low		Low	Low		Low	Low
42	Recharge groundwater basin using treated runoff		High											
43	Conservation Programs													
44	Increase conservation efforts to DWP's planned 2020 levels	X	X	X	X	X	X	X	X	X	X	X	X	X
45	Increase conservation efforts further		X	X			X	X		X	X		X	X
46	Dry Weather Urban Runoff													
47	Local/Neighborhood Solutions													
48	Smart Irrigation		X	X			X	X		X	X		X	X
49	Increase public education and participation	X	X	X	X	X	X	X	X	X	X	X	X	X
50	Regional Solutions													
	Diversion to Wastewater System (WW) or Divert to Urban Runoff Plant or wetlands and Beneficially Use (URP) ¹													
51														
52	Divert - coastal (10 mgd)	WW	WW	WW	WW	WW	WW	WW	WW	WW	WW	WW	WW	WW
53	Divert - inland (Bell Creek 2.8 mgd)				WW									
54	Divert - inland (Browns Creek 3 mgd)				WW			WW			URP ⁴			URP ⁴
55	Divert - inland (Aliso Wash 1.8 mgd)				WW									
56	Divert - inland (Wilbur Wash 1 mgd)				WW			WW			URP ⁴			URP ⁴
57	Divert - inland (Limekiln Canyon 1.5 mgd)				WW			WW			URP ⁴			URP ⁴
58	Divert - inland (Caballero Canyon 1mgd)				WW			WW			URP ⁴			URP ⁴
59	Divert - inland (Bull Creek 2.4 mgd)				WW			WW			URP ⁴			URP ⁴
60	Divert - inland (Tujunga Wash 6 mgd)				WW									
61	Divert - inland (Pacoima Wash 7 mgd)				WW			WW			URP ⁴			URP ⁴
62	Divert - inland (Arroyo Seco 5 mgd)				WW									
63	Divert - inland (Reach 3 LAR 4 mgd)				WW									
64	Divert - inland (Reach 2 LAR-12 mgd)				WW									
65	Divert - inland (Burbank Western Channel 1.8 mgd)				WW									
66	Divert - inland (Compton Creek 2.6 mgd)				WW		URP	URP		URP	URP		URP	URP
67	Divert - inland (Ballona Creek 3.3 mgd)				WW		URP	URP		URP	URP		URP	URP
68	Divert - inland (Sepulveda Channel 16 mgd)				WW									
69	Divert - inland (Dominguez Channel 16 mgd)				WW									
73	Percent of Dry Weather Runoff Managed (of watershed - 97 mgd)	10%	21%	21%	100%	10%	26%	42%	10%	26%	42%	10%	26%	42%
75	Wet Weather Urban Runoff													
76	Local/Neighborhood Solutions													
77	New/Redevelopment Areas - On-site treatment/discharge	X	X	X	X	X	X	X	X	X	X	X	X	X
78	New/Redevelopment Areas - On-site percolation	X	X	X	X	X	X	X	X	X	X	X	X	X
79	Retrofit Areas - Cisterns (On-site storage/use)													
80	Residential		X											
81	Schools		X					X			X			X
82	Government		X					X			X			X
83	On-site percolation (infiltration trenches/basins, reduce paving/hardscape)													
84	Residential		X											
85	Schools		X					X			X			X
86	Government		X					X			X			X
87	Commercial		X											
88	Rec/Cemetaries		X											
89	Neighborhood recharge													
90	Vacant Lots (East Valley) (Low/Medium/High)		Low	High			High	Med		High	Med		High	Med
91	Parks/Open Space (East Valley) (Low/Medium/High)		Low	High			High	Med		High	Med		High	Med
92	Abandoned Alleys (East Valley) (Low/Medium/High)		Low	High			High	Med		High	Med		High	Med
102	Regional Solutions													
106	Non-urban regional recharge		High					Med			Med			Med
107	Runoff treatment and beneficial use/discharge													
108	Treat and beneficial use/discharge (coastal area)	X	X	X	X	X	X	X	X	X	X	X	X	X
109	Treat and beneficial use/discharge (all areas)				X									
110	Percent of Representative storm (1/2-inch) managed (of citywide 1,700 mgd)	10%	58%	39%	100%	10%	39%	47%	10%	39%	47%	10%	39%	47%
111	Current/Anticipated Regulations Level of Compliance													
112	California Toxics Rule	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
113	Current Total Maximum Daily Loads (TMDLs) - Bacteria (Santa Monica Bay), Trash	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
114	Future Total Maximum Daily Loads (projection)	No	Partial	Partial	Yes	No	Partial	Partial	Partial	Partial	Partial	Partial	Partial	Partial
115	Notes:													
116	*Storage for daily (diurnal) peaks													
117	¹ Flows indicated assume no smart irrigation. Implementing smart irrigation citywide would reduce total dry weather runoff estimates by ~11 mgd													
118	² Effective Capacity is the total treatment capacity, minus solids and brine return flows to the sewer													
119	³ Includes new GBIS extension from NOS to GBIS.													
120	⁴ Runoff is treated and discharged. Runoff can potentially be treated and beneficially used if future demands are identified.													
121	Definitions:													
122	LCMR - Low Cost/Minimum Requirements: alternative includes lower cost solutions or low initial investment by meeting minimum requirements.													
123	WR - High Beneficial Use of Water Resources: alternatives that include high levels of recycled water, conservation, and beneficial use of runoff.													
124	HA - High Adaptability: alternatives that are most able to adjust to changing conditions, such as population, wastewater flows and regulations.													
125	LR - Lower Risk: alternatives that are lower in risk from a regulatory perspective (LR1) or in terms of ease of implementation from a technical,													
126	environmental and/or political and public acceptance perspective (LR2).													

- Alternative 4 (Hyb3C): Tillman expansion with high potential water resources projects

These alternatives reflect a full spectrum of wastewater assumptions, provide leadership in water resources and balance today's financial realities. Figure 5-5 provides a snapshot of the projects included in each of these alternatives. Figure 5-6 shows the summary of the costs and benefits for the four recommended alternatives.

5.6 Recommended Alternative

The Draft EIR evaluated the Project Alternatives at a co-equal level and did not identify a preferred or recommended alternative for implementation. Rather, a Recommended Alternative was selected following public review of the Draft EIR. The identification of the Recommended Alternative and the factors that formed the basis of its recommendation were described in the Final EIR.

The Recommended Alternative is Alternative 4 and includes:

- Expand the Hyperion biosolids handling capacity (new digesters and truck loading facility)
- Add secondary clarifiers at Hyperion to meet existing treatment requirements
- Expand and upgrade the Tillman capacity to 100 mgd with advanced treatment
- Add wastewater storage at Tillman
- Add operational storage at LAG for wastewater and recycled water and maintain the option to upgrade LAG to advance treatment
- Construct NEIS II
- Construct GBIS
- Construct VSLIS

The Recommended Alternative would meet future recycled water demand by expanding the existing recycled water distribution system to serve new nonpotable water uses (up to 56,100 acre-feet per year. As an option, Alternative 4 could use some recycled water (advanced treatment) for groundwater recharge at the Hansen Spreading Grounds and Pacoima Spreading Grounds with reduced expansion of the recycled water distribution system for nonpotable reuse. If groundwater recharge is implemented, an additional 23,800 acre-feet per year could be used above the strictly nonpotable options. Alternative 4 could use up to 56,100 acre-feet per year for nonpotable or up to 79,900 acre-feet per year if groundwater recharge is added.

The Recommended Alternative would manage future urban runoff through the following measures:

- Minimize dry weather urban runoff with Smart Irrigation devices throughout the City of Los Angeles
- Treat dry weather urban runoff via Low-Flow Diversions to the sewer system in coastal areas
- Treat dry weather runoff in URPs or treatment wetlands at Compton Creek and Ballona Creek
- Manage wet weather urban runoff with capture and percolation facilities and cisterns
- Treat wet weather urban runoff from the Santa Monica Bay watershed in URPs
- Use regional non-urban runoff in the San Fernando Valley for groundwater recharge at the Hansen Spreading Grounds

On November 14, 2006, the Los Angeles City Council certified the EIR and approved the staff Recommended Alternative (Alternative 4) for implementation.


The *Integrated Resources Plan Draft Environmental Impact Report* (Draft EIR) and the *Integrated Resources Plan Final Environmental Impact Report* (Final EIR) detail the entire process, while a summary is included in Section 8 of this document.

This Recommended Alternative was the basis for the CIP and final financial analysis. The IRP is a road map that can change course as key triggers are encountered. These triggers include actual population increases, development of new technologies, demonstrated effectiveness of leadership projects, changes in regulatory requirements, availability of project funding, and public acceptance. Project components are categorized as “Go” projects, “Go if Triggered” projects and “Go” policies. The *Facilities Plan, Volume 5: Adaptive Capital Improvement Program* presents the CIP and documents the framework for tracking the triggers and adjusting the CIP.

<p><u>Alternative 1 (Hyb1C) – Hyperion Expansion and Moderate Potential for Water Resources Projects</u></p> <p>Wastewater</p> <ul style="list-style-type: none"> Expand Hyperion Treatment Plant to 500 mgd Build new digester tanks, solids handling facility, & secondary clarifiers at Hyperion Upgrade Tillman to advanced treatment Build 5 MG diurnal storage and 5 MG recycled water storage at LAG Build 60 MG wastewater storage at Tillman Build New Sewers: <ul style="list-style-type: none"> Glendale-Burbank Interceptor Sewer (GBIS) Northeast Interceptor Sewer (NEIS) Phase 2 Valley Spring Lane Interceptor Sewer (VSLIS); <p>Recycled Water</p> <ul style="list-style-type: none"> Use up to 38,700 acre-feet/year (42,000 including reuse of dry weather runoff) of recycled water for irrigation and industrial users; and provide baseline flows to LA River. <p>Conservation</p> <ul style="list-style-type: none"> Increase efforts beyond planned 2020 levels <p>Dry Weather Runoff</p> <ul style="list-style-type: none"> Reduce dry weather runoff by installing “Smart Irrigation” devices Divert dry weather runoff from coastal area, Browns Creek, Wilbur Wash, Limekiln Canyon, Caballero Canyon, Bull Creek, and Pacoima Wash to sewer system and convey to Hyperion for treatment. Divert dry weather runoff from Compton Creek and Ballona Creek and treat/beneficially use through urban runoff plants <p>Wet Weather Runoff</p> <ul style="list-style-type: none"> Onsite treatment/discharge or percolation for new or redeveloped areas Retrofit for onsite storage (cisterns) and beneficial use of runoff at schools and government properties Retrofit for onsite percolation of runoff at schools and government properties Onsite percolation of runoff in vacant lots, parks/open space, and abandoned alleys in the East Valley (moderate level of implementation) Regional recharge of runoff in spreading basins in the East Valley Urban runoff plants on the Westside. <p>Leadership Projects</p> <ul style="list-style-type: none"> Full scale and pilot 	<p><u>Alternative 2 (Hyb2C) – Tillman and LAG Expansion and High Potential for Water Resources Projects</u></p> <p>Wastewater</p> <ul style="list-style-type: none"> Expand and upgrade Tillman to 80 mgd Expand and upgrade LAG to 30 mgd Build 5 MG diurnal storage and 5 MG recycled water storage at LAG Build 60 MG wastewater storage at Tillman Build new digester tanks, solids handling facility, & secondary clarifiers at Hyperion Build New Sewers: <ul style="list-style-type: none"> Glendale-Burbank Interceptor Sewer (GBIS) Northeast Interceptor Sewer (NEIS) Phase 2 Valley Spring Lane Interceptor Sewer (VSLIS) <p>Recycled Water</p> <ul style="list-style-type: none"> Use up to 49,900 acre-feet/year (53,000 including reuse of dry weather runoff) of recycled water for irrigation and industrial users; and provide baseline flows to LA River. <p>Conservation</p> <ul style="list-style-type: none"> Same as Alt 1 <p>Dry Weather Runoff</p> <ul style="list-style-type: none"> Reduce dry weather runoff by installing “Smart Irrigation” devices Divert dry weather runoff from coastal area to sewer system and convey to Hyperion for treatment Divert dry weather runoff from Browns Creek, Wilbur Wash, Limekiln Canyon, Caballero Canyon, Bull Creek, and Pacoima Wash to urban runoff plants or constructed wetlands for treatment and discharge back to creeks. Divert dry weather runoff from Compton Creek and Ballona Creek and treat/beneficially use through a constructed wetlands or urban runoff plant <p>Wet Weather Runoff</p> <ul style="list-style-type: none"> Same as Alt 1 <p>Leadership Projects</p> <ul style="list-style-type: none"> Full scale and pilot
<p><u>Alternative 4 (Hyb3C) – Tillman Expansion and High Potential for Water Resources Projects</u></p> <p>Wastewater</p> <ul style="list-style-type: none"> Expand and upgrade Tillman to 100 mgd Build 5 MG diurnal storage and 5 MG recycled water storage at LAG Build 60 MG wastewater storage at Tillman Build new digester tanks, solids handling facility, & secondary clarifiers at Hyperion Build New Sewers: <ul style="list-style-type: none"> Glendale-Burbank Interceptor Sewer (GBIS) Northeast Interceptor Sewer (NEIS) Phase 2 Valley Spring Lane Interceptor Sewer (VSLIS) <p>Recycled Water</p> <ul style="list-style-type: none"> Use up to 52,800 acre-feet/year (56,000 including reuse of dry weather runoff) of recycled water for irrigation and industrial users; and provide baseline flows to LA River. <p>Conservation</p> <ul style="list-style-type: none"> Same as Alt 1 <p>Dry Weather Runoff</p> <ul style="list-style-type: none"> Same as Alt 2 <p>Wet Weather Runoff</p> <ul style="list-style-type: none"> Same as Alt 1 or Alt 2 <p>Leadership Projects</p> <ul style="list-style-type: none"> Full scale and pilot 	<p><u>Alternative 3 (Hyb3B) – Tillman Expansion and Moderate Potential for Water Resources Projects</u></p> <p>Wastewater</p> <ul style="list-style-type: none"> Expand and upgrade Tillman to 100 mgd Build 5 MG diurnal storage and 5 MG recycled water storage at LAG Build 60 MG wastewater storage at Tillman Build new digester tanks, solids handling facility, & secondary clarifiers at Hyperion Build New Sewers: <ul style="list-style-type: none"> Glendale-Burbank Interceptor Sewer (GBIS) Northeast Interceptor Sewer (NEIS) Phase 2 Valley Spring Lane Interceptor Sewer (VSLIS) <p>Recycled Water</p> <ul style="list-style-type: none"> Use up to 40,100 acre-feet/year (43,000 including reuse of dry weather runoff) of recycled water for irrigation and industrial users; and provide baseline flows to LA River. <p>Conservation</p> <ul style="list-style-type: none"> Same as Alt 1 <p>Dry Weather Runoff</p> <ul style="list-style-type: none"> Reduce dry weather runoff by installing “Smart Irrigation” devices Divert dry weather runoff from coastal area to sewer system and convey to Hyperion for treatment. Divert dry weather runoff from Compton Creek and Ballona Creek and treat/beneficially use through urban runoff plants <p>Wet Weather Runoff</p> <ul style="list-style-type: none"> Onsite treatment/discharge or percolation for new or redeveloped areas. Onsite percolation of runoff in vacant lots, parks/open space, and abandoned alleys in the East Valley (high level of implementation) Urban runoff plants on the Westside. <p>Leadership Projects</p> <ul style="list-style-type: none"> Full scale and pilot

Figure 5-5
IRP Recommended Draft Alternatives





Benefits	Alt 1 (Hyb1C)	Alt 2 (Hyb2C)	Alt3 (Hyb3B)	Alt4 (Hyb3C)
Potential Potable Water Demand Reduction through conservation ¹ (AF/yr)	103,200	103,200	103,200	103,200
Additional Recycled Water Usage (AF/yr)	38,700	49,900	40,100	52,800
DWUR Managed (% of watershed - 97 mgd)	42%	42%	26%	42%
WWUR Managed (% of citywide 1,700 mgd)	49%	49%	40%	49%
DWUR and WWUR Beneficially Used (AF/yr)	37,700	37,700	32,500	37,700
Positive Impacts on Public Lands (acres)	353	353	580	353

*Does not include baseline CIP costs, new costs for future TMDLs (except LR1), or budget for leadership projects.

¹Future implementation would depend on available funding, customer acceptance, reliability, and commercial availability of smart irrigation controllers. More detailed studies would be needed to determine the full benefits of a smart irrigation program.

Acronyms

DWUR- Dry Weather Urban Runoff
 WWUR-Wet Weather Urban Runoff
 AF/yr- Acre-feet per year
 MGD- Million gallons per day
 LAG-Los Angeles-Glendale

**Figure 5-6
Hybrid Alternatives Costs and Benefits**

Section 6

Adaptive Capital Improvement Plan (CIP)

6.1 Introduction

The IRP *Facilities Plan, Volume 5: Adaptive Capital Improvement Program (CIP)* has been developed to reflect the staff-recommended alternative, as summarized in Section 5 of this document. The CIP includes the anticipated capital and Operation and Maintenance (O&M), project timing and the implementation strategy for tracking and monitoring triggers. The costs were originally developed as part of the *Facilities Plan, Volumes 1-4* and updated as part of the *Volume 5: Adaptive CIP*. The staff-recommended alternative has component projects and policy directions that are ready for initiation, as well as projects that are contingent on specific conditions that could trigger the need for implementation. It is this flexibility that characterizes the adaptive nature of this CIP, and drives the establishment of a working group to monitor these trigger conditions. A framework for this group is provided as part of the *Facilities Plan Volume 5: Adaptive CIP* and is also summarized in this section.

6.2 Implementation Strategy

Through the EIR process, Alternative 4 was determined to be the Recommended Alternative. Alternative 4 included various recycled water benefits. However, it was determined that if, in the future, the use of recycled water from Tillman for groundwater replenishment or other recycled water uses is considered infeasible based on a combination of factors, (including public acceptability, costs, future regulations, and the need for additional treatment capacity) then Alternative 1 would be considered the Recommended Alternative.

Additionally, project components of the Recommended Alternative were categorized as “go projects” and “go if triggered projects”. The go projects represent projects that have been evaluated at a project-level in the EIR, and are recommended for immediate implementation because the flow or regulatory triggers have already been met. The go if triggered projects include potential projects that will go if triggered by an action, flow, or regulation. If triggered, these projects will be included in the WCIP as part of the annual budget process.

The implementation of these projects is contingent on their need, as determined through pertinent “triggers”. These triggers may be related to regulatory actions such as new discharge or recycled water permit requirements, population increases and associated wastewater flow increases, operational requirements, and/or changes in public perception. The primary mechanism for monitoring these triggers will be an IRP Implementation Strategy Committee that will meet quarterly to review the trigger status and determine project readiness for initiation. The *Facilities Plan volume 5: Adaptive CIP* discusses this trigger tracking process.

6.3 Capital Cost Data Assumptions

To estimate the probable capital cost of IRP recommended projects, cost factors (including overhead, profit, bond and insurance, overhead and contingency) and assumed cost indices were established.

Estimated capital cost data and associated assumptions used to develop the data were originally developed in the *IRP Facilities Plan, Volumes 1 through 3 (Wastewater Management, Water Management, and Runoff Management)* and presented in the *IRP Facilities Plan, Volume 4: Alternatives Development and Analysis Appendix S, Unit Costs (Wastewater, Recycled Water, and Runoff)* (July 2004). This cost data was utilized as a starting point and updated with revised assumptions to reflect current conditions. Cost factors and cost index adjustments were applied to the original capital costs to arrive at the Adaptive CIP. All capital costs presented in the Adaptive CIP are expected to be greater than listed as a result of inflation as projects will be constructed in the future. Not included in the costs presented here are the costs associated with the City's baseline Wastewater Capital Improvement Program (WCIP), stormwater CIP, and Department of Water and Power CIP, which are significant and needed for rehabilitation of the current system, near-term regulatory and system requirements, and security purposes.

6.3.1 Cost Factors

Capital costs presented include both estimated construction costs and construction mark-ups. Total construction mark-ups included in the estimated capital cost include: overhead at 7 percent, profit at 7 percent, mobilization at 7 percent, bond and insurance at 2 percent, and contingency at 15 percent unless otherwise noted. Total construction mark-ups are cumulative resulting in a total mark-up of 44 percent. For example, if a project's construction cost estimate was \$1,000,000, then the following would represent the total markup:

$$(1) \$1,000,000 \text{ (raw construction cost estimate)} \times 1.07 \text{ (overhead)} = \$1,050,000$$

$$(2) \$1,070,000 \text{ (new subtotal)} \times 1.07 \text{ (profit)} = \$1,144,900$$

$$(3) \$1,144,900 \text{ (new subtotal)} \times 1.07 \text{ (mobilization)} = \$1,225,043$$

$$(4) \$1,225,043 \text{ (new subtotal)} \times 1.02 \text{ (bond/insurance)} = \$1,249,544$$

$$(5) \$1,249,544 \text{ (new subtotal)} \times 1.15 \text{ (contingency)} = \$1,436,975$$

Therefore, in this example, the total construction cost markup would be:

$$(6) \$1,436,975 - \$1,000,000 = \$436,975 \text{ (or a 44\% markup)}$$

Non-construction mark-ups for program management, engineering studies/basic design services, construction management services, and start-up costs totaling 30 percent are also included within the estimated capital costs unless otherwise noted. Therefore, in order to get the non-construction cost markup a factor of 0.30 should be multiplied by the construction cost estimate (without construction cost markups). In the above referenced example, this would yield:

$$(7) \$1,000,0000 \text{ (construction cost estimate)} \times 0.30 \text{ (non-construction cost markup)} \\ = \$300,000$$

Therefore, the total capital cost for this example project would equal:

$$(8) \text{ raw construction cost estimate} = \$1,000,0000$$

$$(9) \text{ construction cost markup, see equation (6)} = \$436,975$$

$$(10) \text{ non-construction cost markup, see equation (7)} = \$300,000$$

$$(11) \text{ total capital cost} = \$1,000,000 + \$436,975 + \$300,000 = 1,736,975$$

Further explanation of these costs and assumptions used to develop the original capital costs are provided in Technical Memorandum: Cost Estimate Approach for the IRP Facilities Plan dated May 12, 2003 (Appendix A) and Appendix S, Unit Costs (Wastewater, Recycled Water, and Runoff) of the *Facilities Plan, Volume 4: Alternatives Development and Analysis* dated July 2004.

6.3.2 Construction Cost Index Updates

The *Engineering News Record* (ENR) construction cost index (CCI) for Los Angeles was used to developed capital cost estimates for the IRP. Construction cost estimating involves using costs that were developed at multiple times. A CCI is necessary to adjust costs to a predetermined point in time. Cost indices vary geographically and are dependent upon multiple variables, including labor and material markets. Los Angeles was the most applicable CCI for the IRP. Capital cost estimates for projects developed as part of the IRP were originally developed in Volume 4 to September 2002 dollars with and ENR CCI of 7414 for Los Angeles. Volume 5 updated these costs to March 2006 dollars using and ENR CCI of 8552 for Los Angeles. To reflect the updated ENR CCI a factor of 1.153 was applied to all September 2002 capital costs.

6.4 Wastewater Projects

The Recommended Alternative includes components that are well defined and components that are more conceptual. The well-defined components for the Recommended Alternative are site specific and therefore, more detailed capital cost data is available. Conceptual components will require additional detailed study and environmental analysis resulting in the formation of conceptual cost data.

The Department of Public Works (DPW) is responsible for developing the 10-year Wastewater Capital Improvement Program (WCIP). This program includes replacement, rehabilitation, and expansion of the City's wastewater treatment and collection facilities.

Figure 6-1 shows the overview of treatment plants, service area, and proposed sewer lines.

6.4.1 Wastewater Go-Projects

Go-Projects represent projects from the Recommended Alternative that have been evaluated at a project-level in the EIR, and are recommended for immediate implementation because the flow or regulatory triggers have already been met. The following section presents a description of Go-Projects, expected online years, and estimated capital costs. These projects will be included in the WCIP as part of the annual budget process. The total estimated capital cost for the Go-Projects is \$662 million in March 2006 dollars. Table 6-1 provides a summary of estimated capital costs for the Go-Projects.

The components of the Go-Projects are described in greater detail *The Facilities Plan, Volume 5: Adaptive CIP*.

Table 6-1 IRP Recommended Alternative Wastewater Estimated Capital Costs - Go-Projects		
	Estimated Capital Cost (2006\$)¹ Millions	Forecast Operational Date
Go Projects		
<i>Treatment</i>		
Construct Wastewater Storage Facilities at Tillman (60 Million Gallon with Real Time Control)	\$120	2011
Construct Wastewater Storage Facilities at LAG (5 Million Gallon with Real Time Control)	\$19	2012
Recycled Water Storage at LAG (5 Million Gallon with Real Time Control)	\$8	2012
HTP Solids Handling/Truck Loading Facility	\$89	2012
<i>Collection System</i>		
Glendale Burbank Interceptor Sewer (GBIS), including air treatment	\$196	2016
North East Interceptor Sewer (NEIS) Phase 2	\$230	2016
Total Go Projects	\$662	
Notes: ¹ Costs are presented in 2006 dollars (March 2006 ENR CCI for Los Angeles). Capital costs include construction costs and non-construction costs including program management, engineering studies/design services, construction management, and start-up costs. Costs are expected to be greater than listed as a result of inflation as projects will be constructed in the future.		




Figure 6-1
Overview of Treatment Plants, Service Area, and Proposed Sewer Lines


6.4.2 Wastewater Go If Triggered Projects

The Recommended Alternative also includes potential projects that will go if triggered by an action, flow, or regulation. If triggered, these projects will be included in the WCIP as part of the annual budget process. Triggers will be monitored by staff as summarized in Section 6.8.1. The following section presents a description of Go If Triggered Projects, current estimated capital costs, previous capital costs from the Facilities Plan, and a description of the changes in capital costs that have occurred since the Facilities Plan was completed. These projects will be included in the WCIP as part of the annual budget process if they are triggered. Total estimated capital costs for the Go If Triggered projects are estimated at \$1,205 million in March 2006 dollars. Table 6-2 summarizes the estimated capital costs for the Goif Triggered Projects.


The components of the Go if Triggered Projects are described in greater detail The *Facilities Plan, Volume 5: Adaptive CIP*.

Table 6-2 IRP Alternative Four Wastewater Estimated Capital Costs - Go If Triggered Projects	
	Estimated Capital Cost (2006\$)¹ Millions
Tillman Upgrade to Advanced Treatment and UV Disinfection Phase 1 (current capacity 80 mgd)	\$339
Tillman Expansion to 100 mgd (Secondary, MF/RO, and UV) (add 20 mgd)	\$210
LAG Upgrade to Advanced Treatment and UV disinfection (existing - 20 mgd capacity) ²	\$105
HTP Secondary Clarifiers (add 100 mgd to get capacity to 450 mgd)	\$92
HTP Digesters (up to 12 total)	\$303
Valley Spring Lane Interceptor Sewer (VSLIS) including air treatment	\$156
Total Go If Triggered Projects	\$1,205
Notes: ¹ Costs are presented in 2006 dollars (March 2006 ENR CCI for Los Angeles). Capital costs include construction costs and non-construction costs including program management, engineering studies/design services, construction management, and start-up costs. Costs are expected to be greater than listed as a result of inflation as projects will be constructed in the future ² In the unlikely event that the overall framework for recycled water changes to disallow its use, then Alternative 1 becomes the Recommended Alternative and "Expansion of Hyperion to 500 mgd (add 50 mgd)" would replace the "Tillman Expansion to 100 mgd (Secondary, MF/RO, and UV) (add 20mgd)" project at a total estimated capital cost of \$46 million.	

IRP GO PROJECTS



GO IF TRIGGERED PROJECTS



LEGEND

Concept Study	
Pilot Testing	
Environmental Documentation	
Pre-design	
Design	
Right-of-Way Acquisition	
Bid/Award	
Construction	
Post Construction/Startup	

Figure 6-2 Possible Schedules

The implementation of these projects is contingent on their need, as determined through pertinent “triggers”. These triggers may be related to regulatory actions such as new discharge or recycled water permit requirements, population increases and associated wastewater flow increases, operational requirements, and/or changes in public perception. The primary mechanism for monitoring these triggers will be an IRP Implementation Strategy Committee that will meet quarterly to review the trigger status and determine project readiness for initiation. The *Facilities Plan, Volume 5: Adaptive CIP* discusses this trigger tracking process in detail.

6.4.3 Wastewater Leadership Projects

Leadership projects are projects that require study before large-scale implementation. They allow the City to confirm the “implementability” of a promising approach from technological, operability, results verification, scale-up effect, and public acceptance perspectives; and from City policy and agency coordination perspectives. Examples of types of leadership projects included in the wastewater estimated capital costs are pilot projects, feasibility studies, and demonstration projects. Further details regarding the leadership projects are available in the *Facilities Plan Volume 4: Alternative Development and Analysis* (Section 6). Capital costs for wastewater leadership projects are estimated at \$14 million.

6.4.4 Baseline Project Timing

Figure 6-2 provides a summary of the baseline project timing for-Go Project and Go-If-Triggered Projects. See The *Facilities Plan, Volume 5: Adaptive CIP* for additional discussion.

6.5 Runoff Management Projects

The Runoff Management projects were developed at a programmatic or conceptual level with the goal of creating a starting point in quantifying the potential to improve water quality and increase reuse of runoff. As such, additional efforts are needed to further develop the program, including identification of actual sites and locations for implementing the various runoff management options (as defined in detail in the *Facilities Plan, Volume 3: Runoff Management*) which will be done as part of the TMDL implementation planning process.

To provide progress on the programmatic elements of runoff management, Go-Policy Directions have been adopted as City policy. Go-Policy Directions are specific directions to staff on the next studies and evaluations required to develop the programmatic elements of the Recommended Alternative.

Public Works is responsible for watershed protection, which includes compliance with stormwater and urban runoff regulations (TMDLs and NPDES permits) and beneficial use of runoff. Staff develops a CIP for the watershed protection program as part of the annual budget process.

6.5.1 Runoff Management Programmatic Projects

Programmatic projects are currently broad in scope and require future refinement. The projects were evaluated at a programmatic level in the EIR requiring additional detailed studies to delineate specific projects and subsequent environmental analysis. Overall when refined the individual components of these projects could potentially manage up to 42 percent of the dry weather (41 mgd managed) and 47 percent of the wet weather urban runoff (791 mgd managed) generated in the City. The following section presents a description of the programmatic projects, expected online years, current estimated capital costs, and previous capital costs from the Facilities Plan.

Original capital costs estimates for the programmatic projects described in the Facilities Plan were based on unit costs developed for actual construction projects, such as the Santa Monica Urban Runoff Recycling Facility (SMURRF), Sun Valley recharge projects, and planned wastewater diversion structures. Mark-ups for construction and non-construction items were then applied to the unit costs where applicable and escalated to September 2002 dollars.

For wet weather runoff management projects the approach will be revisited upon approval of the Santa Monica Bay Beaches Bacteria Total Maximum Daily Load Implementation Plan by the Regional Board. The approved implementation change may change the described mix of wet weather projects that would be implemented.

Table 6-3 presents current estimated capital costs in March 2006 dollars for both dry and wet weather runoff management components and leadership projects of the IRP Recommended Alternative. The description of each option is detailed in Section 4 of this document, as well as the *Facilities Plan Volume 3: Runoff Management*.

6.5.2 Proposition O Conceptual Projects

The DPW has taken the lead in developing a Proposition O program that will improve water quality at the beaches, rivers, and lakes within the City. This program includes solicitation of project ideas from the public and the development of conceptual plans for those projects that are approved by the Citizen's Oversight Advisory Committee (COAC). In a multi-phase process, the City will allocate \$500 million in bond funds for these projects.

At the time of developing this Summary Report, numerous Proposition O projects aligned with runoff management were under development and funding review in a process parallel to the IRP process. Conceptual plans were being developed for projects that have been approved for funding by the Citizen's Oversight Advisory Committee. Other Proposition O projects were currently under review for potential approval. Capital costs have been developed for both the projects under development and those projects under funding review.

Table 6-3 IRP Alternative Four Runoff Management Estimated Capital Costs	
	Estimated Capital Cost (2006\$)¹ Millions
Dry Weather Urban Runoff	
Smart irrigation (reduce runoff by ~10 mgd)	\$119
Divert runoff from Compton Creek to URP (~2 mgd)	\$19
Divert runoff from Ballona Creek to URP (~3 mgd)	\$27
Divert runoff from Inland Creeks to URPs and Wetlands (15.9 mgd)	\$393
Subtotal Dry Weather Urban Runoff	\$558
Wet Weather Urban Runoff	
Treat and beneficially use/discharge (coastal area - 160 mgd)	\$1,039
Neighborhood recharge in vacant lots (east valley)	\$389
Neighborhood recharge in parks/open space	\$124
Neighborhood recharge in abandoned alleys	\$18
Onsite percolation - Schools	\$52
Onsite percolation - Government	\$17
Non-urban regional recharge (east valley)	\$87
Cisterns (onsite storage use) - Schools	\$71
Cisterns (onsite storage use) - Government	\$45
Onsite percolation - Schools	\$52
New/Redevelopment Areas - Onsite treat/discharge	\$0
Subtotal Wet Weather Urban Runoff	\$1,894
Leadership Projects	\$12
Total	\$2,463
Notes: ¹ Costs are presented in 2006 dollars (March 2006 ENR CCI for Los Angeles). Capital costs include construction costs and non-construction costs including program management, engineering studies/design services, construction management, and start-up costs. Costs are expected to be greater than listed as a result of inflation as projects will be constructed in the future. ² No costs are associated with new/redevelopment areas as onsite treatment and discharge would be included in the SUSMP requirements. SUSMP compliance is the responsibility of the property owner.	

6.6 Recycled Water

Potential recycled water projects included as part of the Recommended Alternative may result in the production and use of up to 56,000 acre-feet per year of recycled water for non-potable uses including the treatment and reuse of runoff. Recycled water uses would include industrial, irrigation, environmental and potential groundwater replenishment uses. If Tillman is upgraded to advanced treatment with MF/RO, then up to 35,000 acre-feet per year could potentially be used for groundwater replenishment. If public acceptance for groundwater replenishment is not secured or if Tillman is not expanded with advanced treatment, then DWP would implement recycled water projects consistent with IRP Alternative 1.

As part of the IRP, a detailed *Recycled Water Master Plan* was developed by DWP which examined these alternatives in more detail. Updated capital costs presented in this Volume of the IRP are for reference purposes only. Actual implementation of recycled water projects by DWP will be based on benefits, costs, regulations, and public acceptance. DWP will develop its CIP for recycled water based on its own budgeting process and using the *Recycled Water Master Plan* as its planning document.

Potential recycled water projects for the Recommended Alternative are presented in Section 6.5.1; while recycled water projects currently underway and conceptual projects included in DWP's *Recycled Water Master Plan* are presented in Section 6.5.2.

To provide progress on the programmatic elements of recycled water, Go-Policy Directions have been adopted as City policy. Go-Policy Directions are specific directions to staff on the next studies and evaluations required to develop the programmatic elements of the Recommended Alternative. These actions are listed in Section 6.6.

6.6.1 Potential Recycled Water Projects

To estimate the modified Recommended Alternative capital costs for recycled water, the IRP Alternative 1 was used for pipeline, pump stations, end user retrofits, and diurnal storage. This capital cost, updated to reflect March 2006 dollars, is \$492 million. Approximately \$4 million (not including costs of constructing advanced treatment at Tillman) in capital cost would be required to implement the groundwater replenishment component of the modified Recommended Alternative, bringing the total cost to \$496 million.

Table 6-4 presents current estimated capital costs in March 2006 dollars for the recycled water component of the IRP Recommended Alternative.

The description of each option is detailed in the *Facilities Plan Volume 5: Adaptive CIP*.

Table 6-4 IRP Recommended Alternative Recycled Water Estimated Capital Costs	
	Estimated Capital Cost (2006\$) ¹ Millions
Non-Potable Use	
Recycled Water Pipelines	\$286
Recycled Water Pumping	\$40
Diurnal Storage	\$83
End User Retrofit	\$83
Groundwater Replenishment	\$4
Total	\$496
Notes: ¹ Costs are presented in 2006 dollars (March 2006 ENR CCI for Los Angeles). Capital costs include construction costs and non-construction costs including program management, engineering studies/design services, construction management, and start-up costs. Costs are expected to be greater than listed as a result of inflation as projects will be constructed in the future.	

6.6.2 Parallel Projects Underway and Conceptual Projects

In a process parallel to the IRP the Master Plan has resulted in the development of multiple recycled water projects that are funded and underway and one conceptual project. These projects will continue to provide recycled water to irrigation customers and meet the overall IRP objectives and guiding principles.

6.7 Water Conservation Projects

As part of its 5-year update to the Urban Water Management Plan (UWMP), DWP staff included water conservation and runoff management options that are aligned with the IRP, demonstrating their commitment to collaboration with DPW on integrated resources planning.

To provide progress on the increasing water conservation in the City, Go-Policy Directions have been adopted as City policy, and are detailed in the *Facilities Plan, Volume 5: Adaptive CIP*. DWP has invested \$164 million in water conservation since 1991 with successful results. Water demand in 2004 was lower than 1984 levels even though the population has increased by over 750,000. Additionally, per capita water use in 2004 was 18 percent lower than in 1989 when DWP started its aggressive conservation campaign. The viability of water conservation programs is subject to funding, in the form of both outside and internal funding, and DWP's ability to implement the programs. DWP has made a stronger commitment to obtain outside funding for conservation projects. Current water conservation funding sources include:

- Water Rate Adjustments – An adjustment factor is applied to each bill to fund conservation and recycling projects
- Metropolitan Water District of Southern California Conservation Credits Program – MWD offers rebates of half of the project cost (an approximate rebate of \$154 per acre-foot saved) for the installation of specified conservation measures.
- Grant Funding – LADWP applies for and has received grant funding from a variety of sources for water conservation projects, such as Proposition 13 and Proposition 50.

The information on water conservation presented in the *Facilities Plan Volume 5: Adaptive CIP* is for reference purposes only as the UWMP is developed outside of the IRP process. However, the IRP process has resulted in valuable input towards the development of water conservation measures and in viewing water use in an integrated manner in conjunction with wastewater, runoff management, and recycled water. The 2005 UWMP should be consulted for a more in depth discussion of water conservation programs.

Water conservation is the responsibility of DWP. DWP is a separate department from DPW and operates independently. Any financial impacts related to water conservation are evaluated by DWP.

6.8 Implementation Tracking

Implementation of the projects and policies recommended through the IRP program will require a coordinated effort amongst the various Bureaus and Divisions within the DPW and DWP.

6.8.1 Trigger Tracking Tools

There are three tools that have been developed thus far that can assist in tracking the major project implications and requirements, and include the following items:

1. Plant Scenarios table (Table 6-5) – this table summarizes the key conditions and decisions that determine the plant expansion and upgrade identified in the IRP. Each of the conditions are linked by color to decision points shown in the IRP Implementation Flow Charts. For example, the first condition shown in orange font is that restrictive permits require advanced treatment. This is linked to decision points in the Permit Flow Chart (Figure 6-3) regarding the need for advanced treatment, to meet either discharge permit or recycled water permit requirements.

Permits

“Go if Triggered” Projects - Decision Tree




Figure 6-3
Permit Flow Chart

Table 6-5
Plant Scenario

OUTCOMES FOR TREATMENT PLANTS					CONDITIONS (KEY DECISIONS)					
IRP Alternative	Scenario	Plant Expansion & Other System Impacts	Amount Advanced Treatment at DCT	Amount Advanced Treatment at LAG	Implement GWR?	Restrictive Permits require AT ¹ ?	Additional WW treatment capacity needed in HSA?	Sufficient flow available in DCTSA for expanded DCT to treat?	DCT discharge limited to minimum LA River flow requirements?	
	4	1	DCT: 100 mgd expansion	Full	Full	Y	Y - Full	Y ²	Y ²	N
	4	2	DCT: 100 mgd expansion	Portion 3	Portion 2	Y	Y - Partial	Y ²	Y ²	N
	4	3	DCT: 100 mgd expansion	Portion 1	None	Y	N	Y ²	Y ²	N
	4	4	None	Full	Full	Y	Y - Full	N	N	N
	4	5	DCT: bypass remaining flow to HTP	Half	Full	Y	Y - Full	N	N	Y ³
	4	6	None	Portion 3	Portion 2	Y	Y - Partial	N	N	N
		7	DCT: bypass remaining flow to HTP	Portion 3	None	Y	Y - Partial	N	N	Y ³
	4	8	None	Portion 1	None	Y	N	N	N	N
	4	9	DCT: bypass remaining flow to HTP	Half	Full	N	Y - Full	N	n/a ⁴	Y ³
	4	10	None	Portion 2	Portion 2	N	Y - Partial	N	n/a ⁴	N
	4	11	DCT: bypass remaining flow to HTP	Portion 2	Portion 2	N	Y - Partial	N	n/a ⁴	Y ³
	1	12	HTP expansion ⁵ DCT: bypass remaining flow to HTP	Half	Full	N	Y - Full	Y	n/a ⁴	Y ⁶
	1	13	HTP expansion ⁵	Full	Full	N	Y - Full	Y	n/a ⁴	N
	1	14	HTP expansion ⁵ DCT: bypass remaining flow to HTP	Portion 2	Portion 2	N	Y - Partial	Y	n/a ⁴	Y ⁶
	1	15	HTP expansion ⁵	None	None	N	N	Y	n/a ⁴	N
Notes:										
¹ Applies to plant NPDES or WDR/WRR permits										
² Expansion at DCT would only occur if <u>both</u> additional wastewater treatment capacity in HSA and additional flows are available in DCTSA.										
³ Half of DCT mothballed due to excessive investment/O&M costs to comply with new permit requirements										
⁴ Assume DCT will not be expanded unless there is a need for additional capacity in HSA (i.e., RW demands alone would not drive plant expansion).										
⁵ HTP expansion requires additional environmental documentation										
⁶ HTP expansion could occur even when half of DCT is mothballed if the HSA flow increases occur downstream of the DCT service area.										
Amount of Advanced Treatment (AT):										
Full					Full plant flow					
Half					Half of plant flow					
Portion 1					Portion of total plant flow treated with A.T. for GWR and/or non-potable reuse					
Portion 2					Portion of total plant flow treated with A.T. for LAR discharge					
Portion 3					Portion of total plant flow treated with A.T. for GWR and LAR disch					
Current Plant Capacities:					DCT = 80 mgd, LAG = 20 mgd, HTP = 450 mgd					

2. IRP Implementation Flow Charts – these flow charts are intended to serve as decision trees to identify decisions necessary for implementation of the “Go If Triggered” projects.

The flow charts provide the linkages between the key conditions/decisions reflected in the Plant Scenarios table (item 1 above), the major activities necessary to make these decisions, and the organizations responsible for these activities.

3. Trigger Tracking Charts spreadsheet tools to monitor specific project triggers. The IRP Facilities Plan *Volume 5: Adaptive Capital Improvement Plan* provides detailed discussion of these tools.

Included in the preferred alternative is a listing of recommended policy directions for City staff to proceed with specific activities related to recycled water, water conservation, and runoff management. Staff is to provide periodic status updates to the City Council, along with identification of any impacts these actions might have on existing City. Each agency identified as lead will be invited to periodically report out to the IRP Implementation Strategy Committee on the activities and progress on these actions.

Table 6-6 summarizes these policy directions and the responsible party or parties leading the activities. These actions are grouped by service function. The General Go-Policy Directions listed are applicable to more than one resource area.

6.8.2 IRP Progress Reporting

The status of IRP project and policies is of great interest to the affected agencies within the City, as well as the stakeholders, including community and partner agencies, that have been engaged in this program since its inception in 1999. As the keepers of this program, WESD will lead the communications of program progress. At a minimum, minutes of the IRP Implementation Strategy Committee meetings will be prepared and distributed among the committee member organizations. In addition, on an annual basis, WESD will prepare a summary brochure that communicates the following:

- Highlights of key accomplishments in furthering IRP goals,
- Status summary of IRP Go Projects,
- Trigger status and implications to IRP Go If Triggered Projects,
- Status of actions associated with Go Policy Directions
- Short-term goals for the upcoming fiscal year

Table 6-6 IRP Go-Policy Directions		
	Policy Direction	Responsible Party (lead organization listed first)
Recycled Water		
	Non-Potable Uses:	
1.	Work together to maximize use of recycled water for non-potable uses in Terminal Island Treatment Plant service area, west side, and LAG services areas. DWP to conduct additional Tier 1 and 2 customer analysis to verify the potential demands and feasibility. Develop a long-range marketing strategy for recycled water that includes a plan for recruiting (and keeping) new customers.	DWP and DPW
2.	Evaluate and develop ordinances to require installation where feasible of dual plumbing for new multi-family, commercial and industrial developments, schools and government properties in the vicinity of existing or planned recycled water distribution systems in coordination with LA River Revitalization Master Plan. Consider proximity and demand when determining feasibility.	Dept. of Building and Safety
3.	Coordinate where feasible the design/construction of recycled water distribution piping (purple pipe) with other major public works projects, including street widening, and LA River Revitalization Master Plan project areas. Also coordinate with other agencies, including MTA and Caltrans on major transportation projects.	DWP and DPW
	Indirect Potable Uses:	
4.	Develop a public outreach program to explore the feasibility of implementing groundwater replenishment with advanced treated recycled water.	DWP
	Environmental Uses:	
5.	Continue to provide water from DCT to Lake Balboa, Wildlife Lake, and the Japanese Garden at Sepulveda Basin, and the LA River to meet baseline needs for habitat, i.e., approximately 27 mgd through flow-through lakes).	DWP and DPW
Water Conservation		
6.	Continue conservation efforts, including programs to reduce outdoor usage, including using smart irrigation devices on City properties, schools and large developments (those with 50 dwelling units or 50,000 gross square feet or larger), and to increase incentives to residential properties.	DWP
7.	Continue conservation efforts, including evaluating and considering new water conservation technologies, including no-flush urinal technology.	DWP and DBS
8.	Continue conservation efforts, including working with Building and Safety to evaluate and develop policy that requires developers to implement individual water meters for all new apartment buildings	DWP and DBS
9.	Continue conservation awareness efforts, including increasing education programs on the benefits of using climate-appropriate plants with an emphasis on California friendly plants for landscaping or landscaped areas developed in coordination with LA River Revitalization Master Plan, and to develop a program of incentives for implementation.	DWP
10.	Consider the development of City Directive to require the use of California friendly plants in all City projects where feasible and not in conflict with other facilities usage.	Planning Dept.

Table 6-6 IRP Go-Policy Directions		
	Policy Direction	Responsible Party (lead organization listed first)
Wet Weather Runoff Management		
11.	Review SUSMP requirements to require on-site infiltration instead of treat/discharge BMPs, where feasible, along with in-lieu fees where infiltration is infeasible.	DPW
12.	Evaluate and modify codes to encourage on-site capture and retention and/or infiltration, where feasible. Evaluate porous pavements in all new public facilities and large developments >1 acre.	DBS, DPW and Planning Dept.
13.	Evaluate ordinances to reduce area on private properties that can be paved with impervious pavement.	Planning Dept.
14.	Evaluate and implement integration of porous pavements into sidewalks and street programs where feasible.	DPW
15.	Prepare concept report and determine feasibility of developing power line easement demonstration project.	DPW, DWP, DRP
16.	Determine feasibility of developing projects for new and retrofitted schools, as well as government/city-owned facilities with stormwater BMPs.	DPW, DWP, LAUSD
17.	Identify sites that can provide onsite percolation in surplus properties, vacant lots, parks/open space, abandoned alleys in the East Valley, and along the LA River in the East Valley, where feasible.	DPW, DGS, DRP
18.	Maximize unpaved open space in City-owned properties and parking medians through use of all feasible BMPs and by removing all unnecessary pavement.	DPW, DGS, DOT
19.	Include all feasible BMPs in the construction or reconstruction of highway medians under City's jurisdiction.	DPW
20.	Coordinate with Million Trees LA team to identify potential locations of tree planting to provide stormwater benefits.	DPW
Dry Weather Runoff Management		
21.	Consider diversion of dry weather runoff from Ballona Creek to constructed wetlands, wastewater system or urban runoff plant for treatment and/or beneficial use in development of TMDL implementation plans.	DPW, DRP,
22.	Consider diversion of dry weather runoff from inland creeks and storm drains tributary to LA River to wastewater system, constructed wetlands, or treatment/retention/infiltration basins in development of TMDL implementation plans.	DPW
General		
23.	Consider opportunities to incorporate IRP policy decisions in the General Plan, Community Plan, and Specific Plan updates or revisions, and in the future LA River Revitalization Master Plan and Opportunity Areas.	Planning Dept.
24.	Coordinate to include stormwater BMPs in all new parks.	DRP, DPW
25.	Evaluate feasibility of all City properties identified as surplus for potential development of multiple-benefit projects to improve stormwater management, water quality and groundwater replenishment.	GS, Planning Dept., DPW
LEGEND: DPW – Dept. of Public Works DWP – Dept. of Water and Power DBS – Dept. of Building and Safety DRP – Dept. of Recreation and Parks DGS – Dept. of General Services LAUSD – Los Angeles Unified School District DOT – Dept. of Transportation		

This brochure will be distributed at the end of each fiscal year to the IRP stakeholders as well as the City leadership, i.e., City Council members, Commissioners of the Board of Public Works and DWP Board. In this manner, the IRP will continue as an evolving, adaptive plan that will continue to reflect the IRP guiding principles that have culminated through the IRP process in the recommended projects and policies described in this Adaptive CIP, and from which the next facilities plan can be launched.

Section 7

Public Participation

7.1 Introduction

One of the hallmarks of the IRP is that it was and continues to be a stakeholder driven process. From the beginning of the IRP in 2002, the City solicited the involvement of a large number of community, business, and environmental leaders in the development of the IRP, and their involvement has expanded considerably. The stakeholder involvement took the form of several stakeholder groups, each with a specific level of involvement in the IRP. These groups, the Steering Group, the Advisory Group, and the Information Group are described below. In addition, a forth group of stakeholders developed during the later stages of the IRP during the environmental process.

7.2 Roles of Stakeholders in the IRP Project

The three stakeholder groups participated throughout the four-year IRP planning process. The group members provided input and guidance, much of which was incorporated into the IRP alternatives, and support for the IRP process. The stakeholder groups served as resources to the City and consultant team in addressing concerns or resolving issues as future needs were addressed and solutions developed. Figure 7-1 shows the relationship between the City and stakeholder groups in the IRP process.




Figure 7-1
Role of Stakeholders Groups

7.3 Steering, Advisory, and Information Groups

The Steering Group, comprising approximately 125 community members and organizational representatives who could commit to active participation in a series of 13 half-day workshops held over four years, participated directly in the more detailed planning and alternatives development, which would ultimately result in a selected IRP Project and an associated Capital Improvements Program and implementation plan. These workshops were participatory decision-making workshops that were periodically held from November 2002 through 2006. Input and information developed in earlier workshops were addressed and built up in later workshops throughout the alternatives development process, which was completed in April 2004.

The Advisory Group, comprising community members who were interested in the IRP (the membership ranged from 74 to 218 stakeholders over time), provided feedback on IRP issues to be taken into consideration by the IRP team and the Steering Group throughout the facilities planning process. The Advisory Group members were considered closer to the various communities throughout the City and could provide community-relevant input. Meetings were held with the Advisory Group throughout 2003 and 2004.

The Information Group, comprising 232 people from organizations, agencies, neighborhoods, and other interests, were recipients of important IRP information and developments in the form of Newsletters so that they could, in turn, share that information with others in their organizations or offices. The Information Groups served as a means of conveying information to stakeholders and interested persons that may not have otherwise been informed. Four newsletters were circulated from 2003 and 2006.

7.4 Stakeholders and Focused Outreach Related to the Environmental Impact Report

In summer 2004, the IRP team began the yearlong environmental analysis of the four alternatives identified in collaboration with the Steering and Advisory groups. In parallel, the IRP outreach team began a series of presentations to organizations throughout Los Angeles to increase awareness of the overall integrated resources planning program. The outreach team contacted 35 Neighborhood Councils that would potentially have IRP facilities within their jurisdictions and gave presentations upon request.

Specific to the environmental process, extensive public outreach was conducted, including initial internal stakeholder briefings (primarily with Los Angeles City Council offices with parts of alternatives within their districts); two Scoping Meetings held in the afternoon and evening of July 28, 2004; focused outreach to neighborhood groups from Spring 2005 to the release of the draft EIR in November 2005; and four public hearings to receive comments on the draft EIR in January and February 2006.

Focused outreach brought in a new set of stakeholders, those that could be affected in the future by implementation of an IRP Alternative. This outreach effort focused on agencies, cities, community organizations, and other organizations that may have been located close to facilities proposed by one or more of the IRP Alternatives, or that were interested in areas that could be affected by the alternatives. The purpose of focused outreach was multi-fold:

- Ensure that these unique stakeholders – those who could be impacted by construction or operations – were aware of the IRP and the alternatives
- Answer questions about how the project alternatives could affect their neighborhoods and how impacts could be mitigated
- Invite these stakeholders to comment on the draft EIR

The focused outreach engaged many people from these organizations, some who were supportive from the start and others who remained concerned about certain aspects of the alternatives at the time of Final EIR certification. Outreach continued, particularly with City officials and residents of Burbank and Toluca Lake, throughout much of 2006. The cities of Los Angeles and Burbank coordinated on a route for the Glendale-Burbank Interceptor Sewer that would meet the wastewater system needs while avoiding residential areas to the maximum extent possible.

7.5 Public Hearings to Certify the Final EIR

In August 2006, the Final EIR was completed and released to the public. Notices were sent to all parties who sent comment letters, faxes and/or emails and/or attended the January 2006 public hearings or were included in the IRP stakeholder database. Other parties contacted by the City of Los Angeles about the Final EIR included all certified Neighborhood Councils. These councils were contacted via the Department of Neighborhood Empowerment and were apprised of the Final EIR contents, including the content of and rationale for the Recommended Alternative.

On October 4, 2006, the Board of Public Works recommended that the IRP EIR be approved and concurred with the staff recommendation that Alternative 4 be implemented. On November 1, 2006, the Energy and Environment Subcommittee agreed with the Board of Public Works recommendations and forwarded the EIR the City Council for certification and concurred with the staff recommendation that Alternative 4 be approved implemented. On November 7, 2006, the Board of Water and Power Commissioners concurred with the IRP EIR. Finally, on November 14, 2006 the Los Angeles City Council certified the EIR and approved the staff Recommended Alternative (IRP Alternative 4) for implementation.

Section 8

Environmental Impact Report

8.1 Introduction

This section summarizes the environmental process and environmental impact report (EIR) prepared for the IRP (more detailed information is contained the EIR for the IRP).

The California Environmental Quality Act (CEQA) was passed by the state legislature in 1970, with the primary intent of requiring decision-makers to consider the environmental effects of their actions. CEQA applies to all levels of government in the state of California, including local agencies such as the City of Los Angeles. The principal way that environmental effects are disclosed is through the preparation of environmental documents, including EIRs. An EIR must be considered and certified by decision-makers before they approve a project. In the case of the IRP, the decision-maker is the City Council. The environmental impacts of the four Project Alternatives, as well as a No Project Alternative (required by CEQA), were evaluated in an EIR for the IRP. The EIR, comprised of the *Integrated Resources Plan Draft Environmental Impact Report* (Draft EIR) and the *Integrated Resources Plan Final Environmental Impact Report* (Final EIR), identified the environmental impacts of the Alternatives so that the decision-makers (City Council) could consider the environmental effects of the Project Alternatives prior to selecting a Project Alternative for implementation.

The Draft EIR evaluated the Project Alternatives at a co-equal level and did not identify a preferred or recommended alternative for implementation. Rather, a Recommended Alternative was selected following public review of the Draft EIR. The identification of the Recommended Alternative and the factors that formed the basis of its recommendation were described in the Final EIR.

8.2 Draft EIR

The Draft EIR analyzed the four IRP Project Alternatives and the No Project Alternative required by CEQA, at a co-equal level. The No Project Alternative would result in not implementing integrated improvements to the wastewater treatment and collection, recycled water, and runoff systems.

Draft EIRs must be circulated for public review and comment for at least 30 days. The original comment period for the IRP Draft EIR was 90 days to afford adequate time for public review and response to the City of Los Angeles (City). The Draft EIR was initially circulated for public comment from November 30, 2005, through February 27, 2006.

A Notice of Completion (NOC) was submitted to the Office of Planning and Research and is included in the Administrative Record. A Notice of Availability (NOA) of the Draft EIR was mailed to over 8,000 agencies, organizations, and interested persons,

including residents within 500 feet of the NEIS II and GBIS alignments within the City of Los Angeles.

In addition, a notice was published in the Los Angeles Times on December 1, 2005, and the Draft EIR was distributed to the local libraries listed in the NOA.

Furthermore, on February 6, 2006, at the request of the City of Glendale, the NOA of the Draft EIR was sent to all persons on the mailing list that the City of Glendale provided to the City of Los Angeles.

During the public review period, various comments were received from residents along the GBIS alignments expressing concerns about potential impacts. As a result, the City made a minor modification to the GBIS Alignments by connecting the eastern portion of the GBIS South Alignment with the western portion of the GBIS North Alignment with a short connector along West Olive Avenue/Pass Avenue. The City of Los Angeles extended the comment period for an additional 32 days to allow additional public comment on this modification and the Draft EIR, and the comment period ended on March 31, 2006. On February 27, 2006, a public announcement of this extension was distributed to all persons who had received the original NOA.

The Draft EIR also was sent to governmental agencies including the State Water Resources Control Board (State Board), the Governor's Office of Planning and Research, applicable Responsible and Trustee agencies, and other jurisdictions. The Draft EIR also was posted on the IRP Web site for the City and was available for download and review.

The Draft EIR identified potentially significant impacts after mitigation to the following resource areas:

- Air Quality (during construction, operation)
- Cultural Resources (damage to paleontological and archaeological resources)
- Geology (sewer fault crossings, settlement above tunnels)
- Water Quality (degradation from possible earthquake induce tunnel rupture)
- Recreation (from tunnel shaft sites and air treatment facilities)

During the public review period for the Draft EIR, the City of Los Angeles conducted four public hearings on the following dates and locations:

San Fernando Valley Area
Van Nuys City Hall
6262 Van Nuys Boulevard
Van Nuys, CA 91401
Wednesday, January 4, 2006 @7:00 p.m.

Central Los Angeles Area
DWP - John Ferraro Building
111 N. Hope Street
Los Angeles, CA 90012
Wednesday, January 11, 2006 @10:00 a.m.

West Los Angeles Area
Council District 11
7166 W. Manchester Boulevard
Los Angeles, CA 90045
Saturday, January 7, 2006 @11:00 a.m.

Los Angeles Zoo
Witherbee Auditorium
5333 Zoo Drive
Los Angeles, CA 90027
Thursday, January 12, 2006 @6:00 p.m.

Public comments on the scope and content of the Draft EIR were accepted at the public hearings, including oral testimony recorded by court reporters and for which transcripts were prepared.

8.3 Final EIR

The Final EIR describes the process and rationale for identifying the City staff Recommended Alternative, which is also summarized below. The Final EIR also provides responses to comments received on the Draft EIR and provides updates, where applicable, to the Draft EIR.

In response to the Draft EIR, a total of 2,767 comment documents (letters, public hearing and other comment sheets, public hearing transcripts, form letters and petitions) were received by the City. A total of 27 letters were received from agencies and jurisdictions, and 19 were from organizations. The remaining documents contain comments submitted by individuals to the City. The majority of the comments received were concerning the GBIS alignments. Section 3 of the Final EIR provides responses to each comment submitted on the Draft EIR.

Based on the Final EIR and the Draft EIR, a Statement of Finding and Overriding Consideration and a Mitigation Monitoring and Reporting Program were prepared and made a part of the decision-making process. On November 14, 2006, the Los Angeles City Council certified the EIR and approved the staff Recommended Alternative (Alternative 4) for implementation.

8.4 Recommended Alternative

As described above, the City identified a Recommended Alternative after the public review of the Draft EIR. To select the Recommended Alternative from the alternatives analyzed in the Draft EIR, the City of Los Angeles relied on: (1) the information contained in the Draft and Final EIRs (including the Project objectives, environmental analysis, and public comments on the Draft EIR); and (2) the IRP Facilities Plan quadrant analysis that evaluated the preliminary Proposed Project Alternatives originally discussed in the IRP Facilities Plan (City of Los Angeles et al., 2004).

The Draft EIR identified Alternative 1 as the Environmentally Superior Alternative and determined that each of the four Proposed Project Alternatives would meet the long-term goals of protecting public health and safety, providing adequate wastewater treatment and conveyance capacity, and protecting the environment. Although Alternatives 1 through 4 would each result in short-term or temporary construction-related impacts, all of the alternatives were deemed to be superior to the

No Project Alternative because they: (1) are designed to ensure that adequate wastewater treatment and conveyance capacity exists to prevent sewage overflows, (2) would comply with effluent quality requirements of the National Pollutant Discharge Elimination System (NPDES), and (3) would meet the requirements of applicable laws and regulations. On the basis of the analysis conducted in the Draft EIR, Alternative 1, Hyperion Expansion to 500 mgd, was determined to be the Environmentally Superior Alternative.

As discussed in the Draft EIR, the majority of the potentially significant impacts are associated with components that are common to all of the alternatives, such as the proposed new sewer alignments. Differences in impacts are most prevalent when considering alternate locations of proposed IRP treatment facilities. For example, all the Proposed Project Alternatives would result in potential odor impacts related to increased wastewater treatment capacity, but the potential for impacts to occur would differ depending on where a given alternative focuses the expansion of treatment capacity. Alternative 1 was identified as the Environmentally Superior Alternative because it would result in lower use of energy and fewer air pollutant emissions.

In addition to considering the relative differences in environmental impacts among alternatives, the City considered the comments received on the Draft EIR. To help identify the Recommended Alternative, staff reviewed the comments that focused on systemwide issues.

To assist further in the identification of a Recommended Alternative, City staff revisited the previous alternatives ranking process conducted for the Facilities Plan IRP (IRP Facilities Plan, Volume 4: Alternatives Development and Analysis; City of Los Angeles; 2004). In this process, staff applied the comprehensive principles of the IRP facilities planning process using a quadrant analysis (modified cost-benefits analysis) method to evaluate the costs and benefits of the alternatives. The overall objectives of the IRP are to:

- Protect public health and safety
- Effectively manage system capacity
- Protect the environment
- Enhance cost efficiency
- Protect quality of life
- Promote education

In applying the quadrant approach for the alternatives, staff evaluated the alternatives based on the project objectives. Based on the evaluation of the alternatives and consideration of the information in the Draft EIR and the comments on the Draft EIR, the City selected Alternative 4 as the Recommended Alternative.

8.4.1 Final Selected Alternative

The staff Recommended Alternative in the Final EIR was Alternative 4 and included expanding Tillman to 100 mgd; adding storage to Tillman and LAG; and adding a truck-loading facility, digesters, and secondary clarifiers to Hyperion. Figure 8-1 shows the overall system components that make up the staff Recommended Alternative. Wastewater treatment capacity at Tillman would be expanded by increasing the assumed derated capacity of 64 mgd to 100 mgd and upgrading treatment processes to advanced treatment. Adding advance treatment at LAG would also be an option. Wastewater and recycled water storage would be added at LAG. The staff Recommended Alternative would use up to 56,100 acre-feet per year of recycled water (79,900 acre-feet with groundwater replenishment) and would manage 42 percent and 47 percent of the dry weather and wet weather urban runoff, respectively, generated in the City.

On November 14, 2006, the Los Angeles City Council certified the EIR and approved Alternative 4 for implementation, and Alternative 4 is now the final selected alternative.



Figure 8-1

Final Selected Alternative: Alternative 4 - Tillman Expansion

References

City of Los Angeles, Department of Public Works Bureau of Sanitation and Department of Water and Power. July 2006. *Integrated Resources Plan, Facilities Plan, Volume 1: Wastewater Management*.

_____. July 2004. *Integrated Resources Plan, Facilities Plan, Volume 2: Water Management*.

_____. July 2004. *Integrated Resources Plan, Facilities Plan, Volume 3: Runoff Management*.

_____. July 2004. *Integrated Resources Plan, Facilities Plan, Volume 4: Alternative Development and Analysis*.

_____. July 2005. *Technical Memorandum: Financial Impacts of Four Draft IRP Alternatives*.

_____. December 2006. *Integrated Resources Plan, Facilities Plan, Volume 5: Adaptive Capital Improvement Program*.

_____. December 2006. *Integrated Resources Plan, Facilities Plan, Executive Summary*.

_____. December 2006. *Integrated Resources Plan, Facilities Plan, Draft Environmental Impact Report*.

_____. December 2006. *Integrated Resources Plan, Facilities Plan, Financial Plan*.

_____. December 2006. *Integrated Resources Plan, Facilities Plan, Public Outreach Program Report*.