



NOTES:

1. SITE SOILS SHALL HAVE ADEQUATE DRAINAGE (AT LEAST 0.5 INCHES PER HOUR).
2. INFILTRATION SHALL NOT CAUSE GEOTECHNICAL HAZARDS RELATED TO EXPANSIVE SOIL MOVEMENT, TUNNEL EROSION, OR SLOPE STABILITY.
3. IF INFILTRATION HAZARDS ARE A CONCERN, AN UNDERDRAIN SHALL BE INSTALLED TO DRAIN WATER INTO STORM DRAIN INLET OR ONSITE BMP.
4. ANY OVERFLOW SHALL BE DISCHARGED PER BUREAU OF ENGINEERING AND BUILDING & SAFETY REQUIREMENTS.
5. SLOPE IS NOT GREATER THAN 3 PERCENT.
6. FLOW DIRECTED TO PERMEABLE PAVEMENT SHALL BE DISPERSED SO AS NOT TO BE CONCENTRATED AT A SMALL AREA OF PAVEMENT.
7. PRE-FABRICATED PRODUCTS HAVE BEEN INSTALLED PER ALL APPROPRIATE MANUFACTURER'S SPECIFICATIONS. IF REQUIRED, SUB-GRADE SOIL SHALL BE COMPACTED IN ACCORDANCE WITH PRODUCT INSTALLATION SPECIFICATION.
8. SEE PERMEABLE PAVERS FACT SHEET FOR MORE INFORMATION.